

# Annual Environmental Report

## 2024



Adare

D0312-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2024 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 ADARE WWTP - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - ADARE WWTP
  - 2.1.2 EFFLUENT MONITORING SUMMARY - ADARE WWTP -
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR ADARE WWTP
  - 2.1.5 SLUDGE/OTHER INPUTS TO ADARE WWTP

### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

### **7 APPENDIX**

- 7.1 AMBIENT MONITORING SUMMARY

Revision Number	Description of Change	Date of Approval
1	Changes to Section 2.1.4.2 Treatment Capacity Report Summary	03/07/2025

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2024 AER

This Annual Environmental Report has been prepared for D0312-01, Adare, in Limerick in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.  
There were no capital works, significant changes or operational improvements undertaken.

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Adare WWTP with a Plant Capacity PE of 2500, the treatment type is 3P - Tertiary P removal .

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF1900D0312SW001	Adare WWTP	Treated	Non-Compliant	Ammonia-Total (as N) mg/l Total Nitrogen mg/l

## 1.4 LICENCE SPECIFIC REPORTING

Assessment / Report
There are no Licence Specific Reports included in this AER.

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 ADARE WWTP - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - ADARE WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
COD-Cr mg/l	12	751	439
Total Phosphorus (as P) mg/l	12	7.10	4.07
Suspended Solids mg/l	12	595	173
BOD, 5 days with Inhibition (Carbonaceo mg/l	12	333	168
Total Nitrogen mg/l	12	55	33
Hydraulic Capacity	N/A	2031	508

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

#### Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

## 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF1900D0312SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	12	N/A	N/A	40	Pass
Suspended Solids mg/l	35	87.5	N/A	12	2	N/A	18	Pass
BOD, 5 days with Inhibition (Carbonaceo mg/l	25	50	N/A	12	1	N/A	10	Pass
Total Nitrogen mg/l	15	18	N/A	12	1	1	9.20	Fail
pH pH units	9	9	N/A	12	N/A	N/A	7.77	Pass
ortho- Phosphate (as P) - unspecified mg/l	1	1.2	N/A	12	N/A	N/A	0.186	Pass
Ammonia-Total (as N) mg/l	0.5	1	N/A	12	5	5	4.12	Fail
Total Oxidised Nitrogen (as N) mg/l	N/A	N/A	N/A	12	N/A	N/A	3.15	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>Total Phosphorus (as P) mg/l</b>	N/A	N/A	N/A	12	N/A	N/A	0.480	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

### Cause of Exceedance(s):

Refer to the incident section of this report.

### Significance of Results:

The Ammonia and total Nitrogen in this WWTP is not in compliance with the ELV, as set out in the WWDL.

## 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF1900D0312SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.



Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Upstream	147364, 146036	RS24M010960	No	No	No	No	Poor
Downstream	145979, 146639	TW36004127SN6001	No	No	No	No	Moderate

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**

### Significance of Results:

The coastal/transitional ambient monitoring results do not meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence for the following: Total Nitrogen mg/l, Ammonia-Total (as N) mg/l.

Based on ambient monitoring results a deterioration in Ammonia, ortho-Phosphate and Total Nitrogen, concentrations downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

Other causes of deterioration in water quality in the area are unknown.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

The discharge from the wastewater treatment plant does have an observable impact on the coastal/transitional water quality.

## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - ADARE WWTP

### 2.1.4.1 Treatment Efficiency Report - Adare WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
TN	5701	1590	72
cBOD	29064	1785	94
COD	76042	6895	91
SS	29962	3095	90
TP	705	83	88

Note: The above data is based on sample results for the number of dates reported

#### ***2.1.4.2 Treatment Capacity Report Summary - Adare WWTP***

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Adare WWTP	
Peak Hydraulic Capacity (m <sup>3</sup> /day) - As Constructed	1608
DWF to the Treatment Plant (m <sup>3</sup> /day)	450
Current Hydraulic Loading - annual max (m <sup>3</sup> /day)	2031
Average Hydraulic loading to the Treatment Plant (m <sup>3</sup> /day)	508
Organic Capacity (PE) - As Constructed	2500
Organic Capacity (PE) - Collected Load (peak week) <sup>Note1</sup>	1645
Organic Capacity (PE) - Remaining	855
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

## 2.1.5 SLUDGE / OTHER INPUTS - ADARE WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

### 3 COMPLAINTS AND INCIDENTS

#### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2024.			

#### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

##### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	Recurring (Y/N)	Closed (Y/N)
Breach of ELV	Inadequate Infrastructure	Yes	No
Spillage	Emergency overflow caused by power failure	No	Yes
Abatement equipment off-line	Dosing pump failure or maintenance at WWTP	No	Yes

Incident Type	Cause	Recurring (Y/N)	Closed (Y/N)
Spillage	Blocked Sewer	No	Yes
Monitoring Equipment offline	Plant or equipment breakdown at WWTP	No	Yes
Spillage	Blocked Sewer	No	No
Spillage	Emergency overflow caused by power failure	No	Yes

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2024	7
Number of Incidents reported to the EPA via EDEN in 2024	7
Explanation of any discrepancies between the two numbers above	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2024 (No. of events)	Total volume discharged in 2024 (m3)	Monitoring Status
There are no Storm Water Overflows in this Agglomeration.							

The contents presented in this table include the most up to date information available at the time of writing. Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much wastewater discharge by metered SWOs during the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	N/A
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0312-SIP:01</b>	Grease removal at WWTP	C	01/01/2014	Yes	Works Completed		
<b>D0312-SIP:02</b>	Outfall And flap valve repair	C	01/01/2014	Yes	At Planning Stage		
<b>D0312-SIP:03</b>	Storm water holding facilities at WWTP	C	01/01/2014	Yes	At Planning Stage		

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

### 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
<b>No additional improvements planned at this time.</b>				

**4.2.3 SEWER INTEGRITY RISK ASSESSMENT**

N/A



## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Included in this AER
There is no Licence Specific Report Required in this AER Annual Review.		

## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	N/A
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	N/A
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	No

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed:    Date: 27/05/2025

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Head of Environmental Regulation.

# 7 APPENDIX

Appendix
Appendix 7.1 - Ambient monitoring summary

### Ambient Points

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	EPA Feature Coding Tool code	Receiving Waters Designation (Y/N)				WFD Status
			Bathing Water	Drinking Water	FWPM	Shellfish	
RS24M010960	147364, 146036	TPEFF1900D0312SW001	No	No	No	No	Poor
TW36004127SN6001	145979, 146639	TPEFF1900D0312SW001	No	No	No	No	Moderate

### Ambient Impact Assessment Table

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS (Mean)	%EQS
BOD mg/l	RS24M010960	1.227	TW36004127SN6001	1.178	River: 1.5 TW: 4.0	
Ortho-Phosphate (as P) mg/l	RS24M010960	0.047	TW36004127SN6001	0.063	River: 0.035 TW: 0.060	
Ammonia (as N) mg/l	RS24M010960	0.028	TW36004127SN6001	0.036	0.065	
pH pH units	RS24M010960	8.225	TW36004127SN6001	8.150		
Dissolved Oxygen %saturation	RS24M010960	98.850	TW36004127SN6001	95.000	TW: 70 - 130	
Total Nitrogen (as N) mg/l	RS24M010960	1.518	TW36004127SN6001	1.692		
Temperature °C	RS24M010960	11.675	TW36004127SN6001	8.200		

## Ambient Data Tables

Monitored Entity	Station	Monitoring Point	Sample date	Ammonia NH3-N	Biological Oxygen Demand	Dissolved Oxygen	Ortho-Phosphate	pH	Temperature	Total Nitrogen N
				mg/l	mg/l	% saturation	mg/l	pH Units	°C	mg/l
Maigue	RS24M010960	Upstream	16-Jan-2024	< 0.04	< 2	105	0.041	8.3	4.7	2.19
Maigue	RS24M010960	Upstream	13-Feb-2024	< 0.04	< 2	104	0.068	8.1	6.7	1.74
Maigue	RS24M010960	Upstream	12-Mar-2024	< 0.04	< 2	90.6	0.057	8.1	11.9	1.82
Maigue	RS24M010960	Upstream	9-Apr-2024	< 0.04	< 2	97.9	0.094	8	8	1.68
Maigue	RS24M010960	Upstream	28-May-2024	< 0.04	< 2	119	0.014	8.4	14.7	1.28
Maigue	RS24M010960	Upstream	11-June-2024	< 0.04	2	107	< 0.01	8.3	14.5	1.22
Maigue	RS24M010960	Upstream	9-July-2024	< 0.04	< 2	85.4	0.02	8.2	16.6	1.05
Maigue	RS24M010960	Upstream	13-Aug-2024	< 0.04	< 2	108	0.019	8.4	19.2	0.748
Maigue	RS24M010960	Upstream	10-Sep-2024	< 0.04	< 2	80.2	< 0.01	8.1	15	0.892
Maigue	RS24M010960	Upstream	1-Oct-2024	< 0.04	< 2	100	0.063	8.3	12.5	1.54
Maigue	RS24M010960	Upstream	12-Nov-2024	< 0.04	< 2	99.1	0.097	8.3	9.3	1.4
Maigue	RS24M010960	Upstream	3-Dec-2024	< 0.04	< 2	90	0.08	8.2	7	2.66
Mean				0.028	1.227	98.850	0.047	8.225	11.675	1.518

Monitored Entity	Station	Monitoring Point	Sample date	Ammonia NH3-N	Biological Oxygen Demand	Dissolved Oxygen	Ortho-Phosphate	pH	Temperature	Total Nitrogen N
				mg/l	mg/l	% saturation	mg/l	pH Units	°C	mg/l
Maigue Estuary	TW36004127SN6001	Downstream	16-Jan-2024	< 0.035	< 1	102	0.05	8.3	4.2	2.4
Maigue Estuary	TW36004127SN6001	Downstream	13-Feb-2024	0.03	1	98.2	0.07	8.1	6.7	1.8
Maigue Estuary	TW36004127SN6001	Downstream	12-Mar-2024	< 0.035	1.3	91.1	0.06	8	12.1	1.9
Maigue Estuary	TW36004127SN6001	Downstream	9-Apr-2024	0.068	3.1	97.5	0.1	8.1	7.9	1.5
Maigue Estuary	TW36004127SN6001	Downstream	28-May-2024	< 0.035	1.1	115	< 0.01	8.5	14.7	1.5
Maigue Estuary	TW36004127SN6001	Downstream	11-June-2024	< 0.02	< 1	105	0.02	8.4	14.3	1.3
Maigue Estuary	TW36004127SN6001	Downstream	9-July-2024	< 0.035	1.3	85.9	< 0.01	8.2	16.7	1.2
Maigue Estuary	TW36004127SN6001	Downstream	13-Aug-2024	0.047	1.5	84.6	0.02	8.3	19	1
Maigue Estuary	TW36004127SN6001	Downstream	10-Sep-2024	0.12	< 1	94.2	< 0.01	8.4	14.8	1.3
Maigue Estuary	TW36004127SN6001	Downstream	1-Oct-2024	< 0.02	<1	101	0.06	8.4	12.6	2
Maigue Estuary	TW36004127SN6001	Downstream	12-Nov-2024	0.03	<1	92	0.11	8	7.1	2.7
Maigue Estuary	TW36004127SN6001	Downstream	3-Dec-2024	<0.03	1.3	98	0.25	8.3	9.3	1.7
Mean				0.036	1.178	95.000	0.063	8.150	8.200	1.692

Note: Where the concentration in the result is less than the limit of detection (LOD), a value of LOD/sqrt(2) was used in calculating the mean and 95%ile concentrations.