

Annual Environmental Report

2024



Belgooly

D0541-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2024 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 BELGOOLY SECONDARY DISCHARGE - UNTREATED DISCHARGE
 - 2.1.1 EFFLUENT MONITORING SUMMARY - BELGOOLY SECONDARY DISCHARGE -
 - 2.1.2 AMBIENT MONITORING SUMMARY FOR UNTREATED DISCHARGE -
- 2.2 CRAMERS CLOSE WWTP - UNTREATED DISCHARGE
 - 2.2.1 EFFLUENT MONITORING SUMMARY - CRAMERS CLOSE WWTP -
 - 2.2.2 AMBIENT MONITORING SUMMARY FOR UNTREATED DISCHARGE -
- 2.3 BELGOOLY - RIVERBANK ESTATE WWTP - TREATED DISCHARGE
 - 2.3.1 INFLUENT SUMMARY - BELGOOLY - RIVERBANK ESTATE WWTP
 - 2.3.2 EFFLUENT MONITORING SUMMARY - BELGOOLY - RIVERBANK ESTATE WWTP -
 - 2.3.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
 - 2.3.4 OPERATIONAL REPORTS SUMMARY FOR BELGOOLY - RIVERBANK ESTATE WWTP
 - 2.3.5 SLUDGE/OTHER INPUTS TO BELGOOLY - RIVERBANK ESTATE WWTP

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

5.1 PRIORITY SUBSTANCES ASSESSMENT

5.2 SHELLFISH IMPACT ASSESSMENT

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2024 AER

This Annual Environmental Report has been prepared for D0541-01, Belgooly, in Cork in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There were no major capital or operational changes undertaken.

1.2 TREATMENT SUMMARY

- Currently there is no treatment provided at Belgooly . Please refer to section 4 for details of the Programme of Improvements.
- Currently there is no treatment provided at Belgooly . Please refer to section 4 for details of the Programme of Improvements.
- Belgooly - Riverbank Estate WWTP with a Plant Capacity PE of 1000, the treatment type is 3P - Tertiary P removal .

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF0500D0541SW003	Belgooly Secondary Discharge	Untreated	Non-Compliant	BOD mg/l COD-Cr mg/l Suspended Solids mg/l
TPEFF0500D0541SW002	Cramers Close WWTP	Untreated	Non-Compliant	COD-Cr mg/l Suspended Solids mg/l
TPEFF0500D0541SW001	Belgooly - Riverbank Estate WWTP	Treated	Non-Compliant	Ammonia-Total (as N) mg/l ortho-Phosphate (as P) - unspecified mg/l

1.4 LICENCE SPECIFIC REPORTING

Assessment / Report
There are no Licence Specific Reports included in this AER.

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1.1 EFFLUENT MONITORING SUMMARY -

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
E. Coli no./100mls	N/A	N/A	N/A	3	N/A	N/A	24197	
Suspended Solids mg/l	35	N/A	N/A	6	5	N/A	112	Fail
Enterococci (Intestinal) no./100mls	N/A	N/A	N/A	3	N/A	N/A	24197	
Faecal coliforms no./100mls	N/A	N/A	N/A	3	N/A	N/A	N/A	
COD-Cr mg/l	125	N/A	N/A	6	5	N/A	366	Fail
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	25	N/A	N/A	6	5	N/A	153	Fail
pH pH units	9	N/A	N/A	6	0	N/A	7.50	Pass

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

Cause of Exceedance(s):

Refer to incident section of this report

Significance of Results:

The WWTP is non-compliant with the ELV's set in the wastewater Discharge License. The impact on receiving waters is assessed further in Section2.

2.1.2 AMBIENT MONITORING SUMMARY FOR THE UNTREATED DISCHARGE TPEFF0500D0541SW003

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WDDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Upstream	166771,54081	RS20B690960	No	No	No	No	Good
Downstream	166300, 52125	TW05003164OY1001	No	No	No	Yes	Moderate

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**

Significance of Results:

The coastal/transitional ambient monitoring results meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The WWTP discharge was non-compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009

Based on ambient monitoring results a deterioration in Ammonia, BOD, pH, Dissolved Oxygen, Suspended Solids, Temperature, E. Coli, Faecal Coliforms concentrations downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

Other causes of deterioration in water quality in the area are unknown.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

2.1.3 EFFLUENT MONITORING SUMMARY -

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	6	6	2	305	Fail
Suspended Solids mg/l	35	87.5	N/A	6	5	2	69	Fail
pH pH units	9	9	N/A	6	N/A	N/A	7.70	Pass
Faecal coliforms no./100mls	N/A	N/A	N/A	3	N/A	N/A	N/A	
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	N/A	N/A	N/A	6	N/A	N/A	108	
Enterococci (Intestinal) no./100mls	N/A	N/A	N/A	3	N/A	N/A	14684	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
E. Coli no./100mls	N/A	N/A	N/A	3	N/A	N/A	24197	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

Cause of Exceedance(s):

Refer to Incident Section of Report

Significance of Results:

The WWTP is non-compliant with the ELV's set in the Wastewater Discharge Licence. The impact on receiving waters is assessed further in Section 2.

2.1.4 AMBIENT MONITORING SUMMARY FOR THE UNTREATED DISCHARGE TPEFF0500D0541SW002

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Upstream	166771,54081	RS20B690960	No	No	No	No	Good
Downstream	166300, 52125	TW05003164OY1001	No	No	No	Yes	Moderate

Significance of Results:

The coastal/transitional ambient monitoring results meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The WWTP discharge was non-compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009

Based on ambient monitoring results a deterioration in Ammonia, BOD, pH, Dissolved Oxygen, Suspended Solids, Temperature, E. Coli, Faecal Coliforms concentrations downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

Other causes of deterioration in water quality in the area are unknown.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

2.2 BELGOOLY - RIVERBANK ESTATE WWTP - TREATED DISCHARGE

2.2.1 INFLUENT MONITORING SUMMARY - BELGOOLY - RIVERBANK ESTATE WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	6	374	238
Suspended Solids mg/l	6	459	199
COD-Cr mg/l	6	656	400

Parameters	Number of Samples	Annual Max	Annual Mean
Hydraulic Capacity	N/A	314	175

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

2.2.2 EFFLUENT MONITORING SUMMARY - TPEFF0500D0541SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Suspended Solids mg/l	35	87.5	N/A	6	1	N/A	16	Pass
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	25	50	N/A	6	N/A	N/A	10	Pass
pH pH units	9	9	N/A	6	N/A	N/A	7.48	Pass
Ammonia-Total (as N) mg/l	3	3.6	N/A	6	5	5	15	Fail

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
ortho-Phosphate (as P) - unspecified mg/l	1	1.2	N/A	6	4	4	2.12	Fail
Enterococci (Intestinal) no./100mls	N/A	N/A	N/A	3	N/A	N/A	463	
COD-Cr mg/l	N/A	N/A	N/A	6	N/A	N/A	40	
Faecal coliforms no./100mls	N/A	N/A	N/A	3	N/A	N/A	4829	
E. Coli no./100mls	N/A	N/A	N/A	2	N/A	N/A	1318	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

Cause of Exceedance(s):

Refer to Incident Section of Report

Significance of Results:

The WWTP is non compliant with the ELV's set in the Wastewater Discharge Licence. The impact on receiving waters is assessed further in Section 2.

2.2.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE

TPEFF0500D0541SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Upstream	166326, 54277	RS20S030800	No	No	No	No	Good
Upstream	166771,54081	RS20B690960	No	No	No	No	Good
Downstream	166300, 52125	TW05003164OY1001	No	No	No	Yes	Moderate

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**.

Significance of Results:

The coastal/transitional ambient monitoring results meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The WWTP discharge was non-compliant with the ELV's set in the wastewater discharge licence.

The RS20B690960 ambient monitoring results meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009

The RS20S030800 ambient monitoring results do not meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009

Based on ambient monitoring results a deterioration in Ammonia, BOD, pH, Dissolved Oxygen, Suspended Solids, Temperature, E. Coli, Faecal Coliforms concentrations downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

Other causes of deterioration in water quality in the area are unknown.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

2.2.4 OPERATIONAL PERFORMANCE SUMMARY - BELGOOLY - RIVERBANK ESTATE WWTP

2.2.4.1 Treatment Efficiency Report - Belgooly - Riverbank Estate WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
cBOD	15380	667	96
TP	N/A	N/A	N/A
SS	12863	1004	92
COD	25850	2563	90
TN	N/A	N/A	N/A

Note: The above data is based on sample results for the number of dates reported

2.2.4.2 Treatment Capacity Report Summary - Belgooly - Riverbank Estate WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Belgooly - Riverbank Estate WWTP	
Peak Hydraulic Capacity (m³/day) - As Constructed	675
DWF to the Treatment Plant (m³/day)	225
Current Hydraulic Loading - annual max (m³/day)	314
Average Hydraulic loading to the Treatment Plant (m³/day)	175.45
Organic Capacity (PE) - As Constructed	1000
Organic Capacity (PE) - Collected Load (peak week) ^{Note1}	829
Organic Capacity (PE) - Remaining	171
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.2.5 SLUDGE / OTHER INPUTS - BELGOOLY - RIVERBANK ESTATE WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2024.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	Recurring (Y/N)	Closed (Y/N)
Breach of ELV	WWTP upgrade required to meet ELV	Yes	No

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2024	1
Number of Incidents reported to the EPA via EDEN in 2024	1
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2024 (No. of events)	Total volume discharged in 2024 (m3)	Monitoring Status
There are no Storm Water Overflows in this Agglomeration.							

The contents presented in this table include the most up to date information available at the time of writing. Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much wastewater discharge by metered SWOs during the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	N/A
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0541-SIP:01	Improvements to ensure compliance with the ELVs as specified in Schedule A by 31/12/2019	C	31/12/2019	Yes	At Planning Stage	2029	
D0541-SIP:02	Provide sufficient capacity in the wastewater works to satisfy the requirements of this licence	C	31/12/2019	Yes	At Planning Stage	2029	
D0541-SIP:03	SW002 Secondary Discharge Point to be Discontinued	C	31/12/2019	Yes	At Planning Stage	2029	
D0541-SIP:04	SW003 Secondary Discharge Point to be discontinued	C	31/12/2019	Yes	At Planning Stage	2029	

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
No additional improvements planned at this time.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

N/A

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Included in this AER
D0541-01-Priority Substances Assessment	Yes	No
D0541-01-Shellfish Impact Assessment	Yes	No

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	N/A
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	N/A
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	No

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 08/04/2025

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Head of Environmental Regulation.

7 APPENDIX

Appendix

Appendix 7.1 - Ambient monitoring summary

Ambient Points

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	EPA Feature Coding Tool code	Receiving Waters Designation (Y/N)				WFD Status
			Bathing Water	Drinking Water	FWPM	Shellfish	
RS20S030800	166326, 54277	TPEFF0500D0541SW001	No	No	No	No	Good
RS20B690960	166771, 54081	TPEFF0500D0541SW001	No	No	No	No	Good
TW05003164OY1001	166300, 52125	TPEFF0500D0541SW001	No	No	No	No	Moderate

Ambient Impact Assessment Table

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS (Mean)	%EQS
BOD mg/l	RS20S030800	1.403	TW05003164OY1001	2.452	River: 1.5 TW: 4.0	
BOD mg/l	RS20B690960	2.102	TW05003164OY1001			
Ortho-Phosphate (as P) mg/l	RS20S030800	0.026	TW05003164OY1001	0.021	River: 0.35 TW: 0.06	
Ortho-Phosphate (as P) mg/l	RS20B690960	0.023	TW05003164OY1001			
Ammonia (as N) mg/l	RS20S030800	0.050	TW05003164OY1001	0.063	River: 0.065	
Ammonia (as N) mg/l	RS20B690960	0.093	TW05003164OY1001			
pH pH units	RS20S030800	7.633	TW05003164OY1001	7.850		
pH pH units	RS20B690960	7.675	TW05003164OY1001			
Dissolved Oxygen %saturation	RS20S030800	98.800	TW05003164OY1001	100.900	TW: 70 - 130	
Dissolved Oxygen %saturation	RS20B690960	94.875	TW05003164OY1001			
Suspended Solids mg/l	RS20S030800	4.134	TW05003164OY1001	72.750		
Suspended Solids mg/l	RS20B690960	21.500	TW05003164OY1001			
Temperature °C	RS20S030800	13.740	TW05003164OY1001	15.375		
Temperature °C	RS20B690960	13.625	TW05003164OY1001			
E. Coli no./100mls	RS20S030800	206.000	TW05003164OY1001			

E. Coli no./100mls	RS20B690960	1,323.500	TW05003164OY1001	397.500		
Enterococci (Intestinal) no./100mls	RS20S030800	60.500	TW05003164OY1001	31.000		
Enterococci (Intestinal) no./100mls	RS20B690960	930.000	TW05003164OY1001			
Faecal Coliforms no./100mls	RS20S030800	194.500	TW05003164OY1001	274.500		
Faecal Coliforms no./100mls	RS20B690960	258.000	TW05003164OY1001			

Ambient Data Tables

				Ammonia-Total (as N)	BOD - 5 days (Total)	Dissolved Oxygen	E. Coli	Enterococci (Intestinal)	Faecal coliforms	ortho-Phosphate (as P) - unspecified	pH	Suspended Solids	Temperat ure
Monitored Entity	Station	Monitoring Point	Sample date	mg/l	mg/l	% Saturation	no./100 mls	no./100mls	no./100mls	mg/l	pH Units	mg/l	°C
Oyster Haven	TW05003164OY 1001	Downstream	13/03/202 4	0.162	4.8	101.6				0.04	7.6	109	15.4
Oyster Haven	TW05003164OY 1001	Downstream	08/05/202 4	<0.035	<1.0	94.9	754	52	464	<0.020	7.7	58	14.2
Oyster Haven	TW05003164OY 1001	Downstream	03/07/202 4	0.041	2.1	107.6	41	10	85	<0.020	8.1	84	17.4
Oyster Haven	TW05003164OY 1001	Downstream	12/09/202 4	<0.035	2.2	99.5				<0.020	8	40	14.5
Mean				0.063	2.452	100.900	397.500	31.000	274.500	0.021	7.850	72.750	15.375

Note: Where the concentration in the result is less than the limit of detection (LOD), a value of LOD/sqrt(2) was used in calculating the mean and 95%ile concentrations.