

# Annual Environmental Report

## 2024



Lower Liffey Valley Regional Sewerage Scheme  
D0004-02

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2024 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 LEIXLIP/LOWER LIFFEY VALLEY WWTP - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - LEIXLIP/LOWER LIFFEY VALLEY WWTP
  - 2.1.2 EFFLUENT MONITORING SUMMARY - LEIXLIP/LOWER LIFFEY VALLEY WWTP
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR LEIXLIP/LOWER LIFFEY VALLEY WWTP
  - 2.1.5 SLUDGE/OTHER INPUTS TO LEIXLIP/LOWER LIFFEY VALLEY WWTP

### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

- 5.1 PRIORITY SUBSTANCES ASSESSMENT
- 5.2 TOXICITY/LEACHATE MANAGEMENT

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

### **7 APPENDIX**

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2024 AER

This Annual Environmental Report has been prepared for D0004-02, Lower Liffey Valley Regional Sewerage Scheme, in Kildare in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Leixlip/Lower Liffey Valley WWTP with a Plant Capacity PE of 150000, the treatment type is 3NP - Tertiary N&P removal.

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF1400D0004SW001	Leixlip/Lower Liffey Valley WWTP	Treated	Compliant	N/A

## 1.4 LICENCE SPECIFIC REPORTING

Assessment / Report
There are no Licence Specific Reports included in this AER.

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 LEIXLIP/LOWER LIFFEY VALLEY WWTP - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - LEIXLIP/LOWER LIFFEY VALLEY WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
ortho-Phosphate (as P) - unspecified mg/l	17	7.50	2.33
Total Phosphorus (as P) mg/l	26	7.84	2.87
COD-Cr mg/l	26	886	316
Total Nitrogen mg/l	26	70	35
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	26	342	169
Ammonia-Total (as N) mg/l	17	61	27
pH pH units	17	7.55	7.28
Suspended Solids mg/l	26	454	180
Hydraulic Capacity	N/A	60040	37337

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

## Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

### 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF1400D0004SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>COD-Cr mg/l</b>	125	250	N/A	26	N/A	N/A	13	Pass
<b>Suspended Solids mg/l</b>	35	87.5	N/A	26	N/A	N/A	2.61	Pass
<b>pH pH units</b>	6	9	N/A	26	N/A	N/A	6.63	Pass
<b>BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l</b>	4	8	N/A	26	N/A	N/A	1.16	Pass
<b>Total Phosphorus (as P) mg/l</b>	1	1.2	N/A	26	N/A	N/A	0.106	Pass
<b>Ammonia-Total (as N) mg/l</b>	0.5	1	N/A	26	N/A	N/A	0.075	Pass
<b>ortho-Phosphate (as P) - unspecified mg/l</b>	0.1	0.2	N/A	26	1	N/A	0.076	Pass

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Appearance (on Sampling) Descriptive	N/A	N/A	N/A	18	N/A	N/A	N/A	
Nitrate (as N) mg/l	N/A	N/A	N/A	18	N/A	N/A	20	
Fluoride mg/l	N/A	N/A	N/A	26	N/A	N/A	2.05	
Total Nitrogen mg/l	N/A	N/A	N/A	18	N/A	N/A	20	
Total Oxidised Nitrogen (as N) mg/l	N/A	N/A	N/A	18	N/A	N/A	20	
True Colour PtCo Units	N/A	N/A	N/A	18	N/A	N/A	12	
Nitrite (as N) mg/l	N/A	N/A	N/A	18	N/A	N/A	0.017	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

### Cause of Exceedance(s):

Not applicable

### Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

### 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE

#### TPEFF1400D0004SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Upstream	301516, 235804	RS09L011940	No	No	No	No	Poor
Downstream	302295, 235190	RS09L012040	No	No	No	No	Poor

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient Monitoring Summary**.

#### Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results do not meet the required EQS at the upstream and the downstream monitoring locations. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in Ortho-P and Ammonia concentrations downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

Other causes of deterioration in water quality in the area are unknown.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.



## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - LEIXLIP/LOWER LIFFEY VALLEY WWTP

### 2.1.4.1 Treatment Efficiency Report - Leixlip/Lower Liffey Valley WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
<b>cBOD</b>	2210711	15180	99
<b>COD</b>	4308513	177441	96
<b>TN</b>	456454	289331	37
<b>SS</b>	2349791	34059	99
<b>TP</b>	37437	1388	96

Note: The above data is based on sample results for the number of dates reported.

#### 2.1.4.2 Treatment Capacity Report Summary - Leixlip/Lower Liffey Valley WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Leixlip/Lower Liffey Valley WWTP	
Peak Hydraulic Capacity (m <sup>3</sup> /day) - As Constructed	65405
DWF to the Treatment Plant (m <sup>3</sup> /day)	48500
Current Hydraulic Loading - annual max (m <sup>3</sup> /day)	60040
Average Hydraulic loading to the Treatment Plant (m <sup>3</sup> /day)	37337
Organic Capacity (PE) - As Constructed	150000
Organic Capacity (PE) - Collected Load (peak week) <sup>Note1</sup>	124524
Organic Capacity (PE) - Remaining	25476
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

## 2.1.5 SLUDGE / OTHER INPUTS - LEIXLIP/LOWER LIFFEY VALLEY WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
<b>Landfill Leachate (delivered by tanker)</b>	23199	Volume (m <sup>3</sup> )	282	0.17	Yes	Yes	Yes
<b>Industrial / Commercial Sludge</b>	7014	Volume (m <sup>3</sup> )	85	0.05	Yes	Yes	Yes
<b>Domestic /Septic Tank Sludge</b>	17702	Volume (m <sup>3</sup> )	216	0.13	Yes	Yes	Yes

## 3 COMPLAINTS AND INCIDENTS

### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2024.			

### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	Recurring (Y/N)	Closed (Y/N)
Abatement equipment off-line	Plant or equipment breakdown at WWTP	No	Yes
Abatement equipment off-line	Shock load to the WWTP	No	Yes
Uncontrolled release	SWO exceptional rainfall and overflow expected	No	Yes

Incident Type	Cause	Recurring (Y/N)	Closed (Y/N)
Abatement equipment off-line	Plant or equipment breakdown at WWTP	No	Yes
Spillage	Network Infrastructure	No	Yes
Monitoring Equipment offline	Plant or equipment calibration at WWTP	No	No
Abatement equipment off-line	Plant or equipment breakdown at WWTP	No	Yes
Abatement equipment off-line	Plant or equipment breakdown at WWTP	No	Yes
Uncontrolled release	Inadequate Operational Procedures/Training	No	Yes
Abatement equipment off-line	Plant or equipment breakdown at WWTP	No	No

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2024	10
Number of Incidents reported to the EPA via EDEN in 2024	10
Explanation of any discrepancies between the two numbers above	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2024 (No. of events)	Total volume discharged in 2024 (m <sup>3</sup> )	Monitoring Status
<b>SW002</b>	TBC	Yes	Low Significance	Meeting Criteria	Unknown	51073	Monitored
<b>SW003</b>	288852 239591	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
<b>SW004</b>	294407 238711	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
<b>SW005</b>	293552 237349	Yes	Low Significance	Not Meeting Criteria	Unknown	Unknown	Not Monitored
<b>SW006</b>	298236 233802	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Monitored
<b>SW007</b>	297590 233306	Yes	Low Significance	Not Meeting Criteria	Unknown	Unknown	Not Monitored

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2024 (No. of events)	Total volume discharged in 2024 (m³)	Monitoring Status
<b>SW008</b>	297584 233306	Yes	Low Significance	Not Meeting Criteria	Unknown	Unknown	Not Monitored
<b>SW009</b>	297379 232919	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
<b>SW010</b>	298651 233371	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
<b>SW011</b>	298651 233385	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
<b>SW012</b>	296932 232421	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
<b>SW013</b>	301155 TBC	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
<b>SW014</b>	292832 229607	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
<b>SW015</b>	300408 235903	Yes	Low Significance	Not Meeting Criteria	Unknown	Unknown	Not Monitored
<b>SW016</b>	30653 TBC	Yes	Low Significance	Not Meeting Criteria	Unknown	Unknown	Not Monitored
<b>TBC</b>	297590 233306	Yes	Low Significance	Not yet Assessed	Unknown	Unknown	Not Monitored





WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2024 (No. of events)	Total volume discharged in 2024 (m³)	Monitoring Status
TBC	286684 240780	Yes	Low Significance	Not yet Assessed	Unknown	Unknown	TBC
TBC	TBC TBC	Yes	Low Significance	Not yet Assessed	Unknown	Unknown	TBC
TBC	TBC TBC	Yes	Low Significance	Not yet Assessed	Unknown	Unknown	Not Monitored
TBC	TBC TBC	Yes	Low Significance	Not yet Assessed	Unknown	Unknown	Not Monitored
TBC	TBC TBC	Yes	Low Significance	Not yet Assessed	Unknown	Unknown	Not Monitored
TBC	TBC TBC	Yes	Low Significance	Not yet Assessed	Unknown	Unknown	Not Monitored
TBC	TBC TBC	Yes	Low Significance	Not yet Assessed	Unknown	Unknown	Monitored
TBC	298236 233802	Yes	Low Significance	Not yet Assessed	Unknown	Unknown	Not Monitored
TBC	288434 238610	Yes	Low Significance	Not yet Assessed	Unknown	Unknown	TBC
TBC	288177 239026	Yes	Low Significance	Not yet Assessed	Unknown	Unknown	TBC

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2024 (No. of events)	Total volume discharged in 2024 (m <sup>3</sup> )	Monitoring Status
TBC	287770 240274	Yes	Low Significance	Not yet Assessed	Unknown	Unknown	TBC
TBC	299292 234119	Yes	Low Significance	Not yet Assessed	Unknown	Unknown	TBC
TBC	300469 235248	Yes	Low Significance	Not yet Assessed	Unknown	Unknown	TBC
TBC	293095 238364	Yes	TBC	Not yet Assessed	Unknown	Unknown	TBC
TBC	296916 232422	Yes	TBC	Not yet Assessed	Unknown	Unknown	TBC

The contents presented in this table include the most up to date information available at the time of writing. Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much wastewater discharge by metered SWOs during the year (m <sup>3</sup> )?	51073
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	Yes
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	No

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0004-SIP:01</b>	Upgrading of Storm Water Overflows to comply with the criteria outlined in the DoECLG "Procedures and Criteria in relation to Storm Water Overflows, 1995".	C	31/12/2020	No	At Construction		
<b>D0004-SIP:02</b>	Waste Water capacity improvement works	C	08/05/2020	Yes	Works Completed		
<b>D0004-SIP:03</b>	Waste Water Treatment plant improvement and ancillary works to meet the requirements of Schedule A.1 and condition 3.4	C	31/12/2019	Yes	Works Completed		

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

### 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
No additional improvements planned at this time.				

### 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.

## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Included in this AER
D0004-02-Priority Substances Assessment	Yes	No
D0004-02-Toxicity/Leachate Management	Yes	No

## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	Yes
List reason e.g. additional SWO identified	Additional SWOs
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	No
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Date: 23/07/2025

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of,

Eleanor Roche

Head of Environmental Regulation.

## 7 APPENDIX

### Appendix

#### Appendix 7.1 - Ambient Monitoring Summary



## Lower Liffey Valley WWTP Ambient Monitoring Summary 2024

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish National Grid Reference (Easting, Northing)	EPA Feature Coding Tool code	Receiving Waters Designation (Yes/No)				Current WFD Status	Mean (mg/l)		
			Bathing Water	Drinking Water	FWPM	Shellfish		cBOD	o-Phosphate (as P)	Ammonia (as N)
Upstream Monitoring Point	301516, 235804	RS09L011940	No	No	No	No	Poor	1.018	0.0235	0.0806
Downstream Monitoring Point	302295, 235190	RS09L012040	No	No	No	No	Poor	1.005	0.0305	0.0915
<i>Difference</i>								-0.0127	0.0070	0.0108
EQS								1.500	0.035	0.065
% of EQS								-0.849%	19.876%	16.656%

## Lower Liffey Valley WWTP Ambient Monitoring Summary 2024

Upstream Results														
Date		Temp oC	pH pH units	BOD mg/l	COD mg/l	Suspended solids mg/l	Total Nitrogen mg/l	Total Phosphorus mg/l	Ammonia mg/l	Ortho- Phosphat e mg/l	Nitrite mg/l	Nitrate mg/l	DO mg/l	DO % sat
30/01/2024	U/S	10.8	8.1	< 1		5		0.08	0.044	< 0.01			9.8	89.1
15/02/2024	U/S		7.8	1		6		0.06	0.031	0.01			9.8	88.2
06/03/2024	U/S		7.4	1		3		0.07	< 0.01	0.01				
20/03/2024	U/S	10.6	7.01	1	21	4	16.8	0.09	0.17	0.05	0.01	2.22	10.1	93.2
17/04/2024	U/S	11.7	7.38	1	17	4	1.8	0.05	0.11	0.04	0.01	1.81	10.2	93
24/04/2024	U/S	13.4	7.36	1	2	2	2.3	0.05	0.17	0.03	0.01	2.34	10.6	100
01/05/2025	U/S	13.7	7.24	1	11	2	2.2	0.05	0.07	0.03	0.01	2.22	10.4	98
15/05/2024	U/S	16.8	7.04	1	4	2	2.1	0.04	0.04	0.02	0.02	2.05	9.1	95
29/05/2024	U/S	15.7	7.29	1	12	1	2	0.05	0.04	0.03	0.01	2.01	9.4	94.4
19/06/2024	U/S	17	7.69	1	29	4	1.7	0.05	0.1	0.03	0.01	1.7	9.9	101
26/06/2024	U/S	19.7	7.84	1	4	4	1.7	0.05	0.1	0.03	0.02	1.68	8.6	94.1
03/07/2024	U/S	16.4	7.83	1	7	3	1.9	0.05	0.07	0.02	0.02	1.86	9.4	96.8
17/07/2024	U/S	17.9	7.3	1	26	2	1.7	0.05	0.06	0.03	0.01	1.69	9.6	100
21/08/2024	U/S	17.8	7.45	1	5	1	1.6	0.03	0.09	0.02	0.01	1.54	9.6	101
28/08/2024	U/S	17.6	7.06	1	8	3	1.8	0.03	0.09	0.01	0.01	1.82	9.46	99.4
04/09/2024	U/S	17.4	7.15	1	9	2	1.5	0.06	0.13	0.04	0.01	1.48	9.47	90.4
11/09/2024	U/S	15.7	7.41	1	8	3	1.4	0.05	0.1	0.03	0.01	1.37	8.5	86.2
02/10/2024	U/S	14.5	6.84	1	7	1	2.8	0.05	0.06	0.03	0.01	2.68	9.4	91.5
16/10/2024	U/S	13.8	6.47	1	6	2	1.8	0.05	0.09	0.03	0.01	1.8	9.35	91.8
23/10/2024	U/S	12.3	6.85	1	9	1	1.6	0.03	0.1	0.01	0.01	1.54	10.6	97.3
06/11/2024	U/S	12.7	7.08	1	12	4	1.7	0.05	0.12	0.02	0.01	1.55	9.35	86.7
20/11/2024	U/S		8.1	2		16		0.09	0.052	< 0.01				
11/12/2024	U/S		8	< 1		2		0.09	< 0.015	< 0.01				
Mean		15.026	7.378	1.018	10.944	3.348	2.689	0.055	0.081	0.024	0.012	1.853	9.632	94.355
95%ile		18.080	8.090	1.000	26.450	5.900	4.900	0.090	0.166	0.040	0.020	2.391	10.600	101.000

Downstream Results														
Date		Temp oC	pH pH units	BOD mg/l	COD mg/l	Suspended solids mg/l	Total Nitrogen mg/l	Total Phosphorus mg/l	Ammonia mg/l	Ortho- Phosphat e mg/l	Nitrite mg/l	Nitrate mg/l	DO mg/l	DO % sat
30/01/2024	D/S	9.9	8.1	< 1		7		0.09	0.039	0.04			10.1	89.9
15/02/2024	D/S		7.8	1		6		0.05	0.041	0.01			10.1	89.2
06/03/2024	D/S		7.8	< 1		< 2		0.06	< 0.01	< 0.01				
20/03/2024	D/S	11.1	7.21	1	12	6	2.6	0.08	0.16	0.05	0.01	2.64	10.6	94.2
17/04/2024	D/S	10.8	7.56	1	16	3	2.4	0.07	0.12	0.05	0.02	2.42	10.5	93.9
24/04/2024	D/S	13	7.55	1	3	2	3.8	0.04	0.14	0.02	0.01	3.7	10.6	99.4
01/05/2025	D/S	13.1	7.46	1	13	2	3.1	0.04	0.06	0.02	0.01	3.07	10.9	103.8
15/05/2024	D/S	16.2	7.08	1	1	3	3.1	0.05	0.03	0.03	0.02	3.1	9.2	94
29/05/2024	D/S	16.4	7.47	1	11	1	4.1	0.06	0.05	0.04	0.01	4.01	9.5	96.8
19/06/2024	D/S	16.8	7.92	1	16	2	4.8	0.04	0.08	0.02	0.01	4.66	10.3	104
26/06/2024	D/S	19.3	7.92	1	12	4	3	0.06	0.11	0.04	0.02	3.01	9.46	102.8
03/07/2024	D/S	16.8	7.93	1	10	3	4.5	0.05	0.05	0.03	0.02	4.44	9.5	98.6
17/07/2024	D/S	18.2	7.41	1	9	2	4.7	0.08	0.05	0.06	0.01	4.6	9.3	98
21/08/2024	D/S	16.8	7.54	1	4	1	4.2	0.05	0.08	0.03	0.01	4.13	9.7	100
28/08/2024	D/S	17.7	7.25	1	9	4	3.5	0.05	0.1	0.02	0.01	3.45	9.3	98.1
04/09/2024	D/S	16.2	6.85	1	13	3	2.2	0.09	0.12	0.06	0.01	2.18	9.8	99.1
11/09/2024	D/S	14.3	7.49	1	7	3	1.8	0.05	0.1	0.03	0.01	1.76	10.1	99
02/10/2024	D/S	14	7.04	1	18	1	4.1	0.05	0.08	0.03	0.02	4.09	9.83	94.6
16/10/2024	D/S	13.8	6.63	1	4	1	4.9	0.07	0.33	0.04	0.01	4.87	9.44	91.4
23/10/2024	D/S	12.5	6.94	1	10	6	2.7	0.05	0.12	0.03	0.01	2.58	10.4	95.7
06/11/2024	D/S	13	7.24	1	9	1	2.4	0.06	0.14	0.03	0.01	2.34	10.52	94.5
20/11/2024	D/S		8.1	2		19		0.14	0.086	< 0.01				
11/12/2024	D/S		8	< 1		< 2		0.06	< 0.015	< 0.01				
Mean		14.732	7.491	1.005	9.833	3.701	3.439	0.063	0.0915	0.0305	0.013	3.392	9.958	96.850
95%ile		18.310	8.090	1.000	16.300	6.950	4.815	0.090	0.158	0.059	0.020	4.692	10.615	103.810

*Note: Where the concentration in the result is less than the limit of detection (LOD), a value of LOD/sqrt(2) was used in calculating the mean and 95%ile concentrations.*