

# Annual Environmental Report

## 2024



Nenagh

D0027-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2024 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 NENAGH NEW WWTP - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - NENAGH NEW WWTP
  - 2.1.2 EFFLUENT MONITORING SUMMARY - NENAGH NEW WWTP -
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR NENAGH NEW WWTP
  - 2.1.5 SLUDGE/OTHER INPUTS TO NENAGH NEW WWTP

### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

- 5.1 HABITATS IMPACT ASSESSMENT
- 5.2 PRIORITY SUBSTANCES ASSESSMENT

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

### **7 APPENDIX**

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2024 AER

This Annual Environmental Report has been prepared for D0027-01, Nenagh, in Tipperary in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There were no major capital or operational changes undertaken.

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Nenagh New WWTP with a Plant Capacity PE of 11000, the treatment type is 3P - Tertiary P removal .

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF2800D0027SW001	Nenagh New WWTP	Treated	Non-Compliant	Ammonia-Total (as N) mg/l

## 1.4 LICENCE SPECIFIC REPORTING

Assessment / Report
There are no Licence Specific Reports included in this AER.

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 NENAGH NEW WWTP - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - NENAGH NEW WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Total Phosphorus (as P) mg/l	12	16	4.50
Suspended Solids mg/l	12	1300	308
COD-Cr mg/l	12	2165	490
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	12	546	154
Total Nitrogen mg/l	12	53	23
Ammonia-Total (as N) mg/l	12	32	14
ortho-Phosphate (as P) - unspecified mg/l	12	2.60	0.797
Hydraulic Capacity	N/A	15428	6593

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

### Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

### 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF2800D0027SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	100	200	N/A	13	N/A	N/A	19	Pass
Suspended Solids mg/l	30	75	N/A	13	N/A	N/A	9.17	Pass
Temperature °C	25	25	N/A	12	N/A	N/A	12	Pass
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	20	40	N/A	13	N/A	N/A	2.45	Pass
Fats, Oils and Greases mg/l	15	18	N/A	4	N/A	N/A	9.13	Pass
pH pH units	9	9	N/A	13	N/A	N/A	7.76	Pass
Ammonia-Total (as N) mg/l	1.4	1.68	N/A	13	2	2	1.04	Fail
Total Phosphorus (as P) mg/l	1	1.2	N/A	13	N/A	N/A	0.115	Pass

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
ortho-Phosphate (as P) - unspecified mg/l	0.75	0.9	N/A	13	N/A	N/A	0.110	Pass
Nitrate (as N) mg/l	N/A	N/A	N/A	13	N/A	N/A	7.48	
Sulphate mg/l	N/A	N/A	N/A	12	N/A	N/A	59	
Total Nitrogen mg/l	N/A	N/A	N/A	12	N/A	N/A	9.53	

Notes:

- 1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied
- 2 – For pH the WWDA specifies a range of pH 6 - 9

### Cause of Exceedance(s):

Refer to Incident Section of this report.

### Significance of Results:

The WWTP is non compliant with the ELV's set in the Wastewater Discharge Licence. The impact on receiving waters is assessed further in Section 2.

## 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF2800D0027SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
<b>Upstream</b>	187349, 179986	RS25N010605	No	No	No	No	Moderate
<b>Downstream</b>	187229, 180175	RS25N010620	No	No	No	No	Moderate

The table below provides a summary of monitoring results for designated ambient monitoring points. The upstream and downstream annual mean values are shown (mg/l), and the difference between both monitoring stations is given as a percentage of the Environmental Quality Standard (EQS) where relevant.

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
<b>BOD - 5 days (Total) mg/l</b>	RS25N010605	0.780	RS25N010620	1.35	1.50	38.2
<b>Ammonia-Total (as N) mg/l</b>	RS25N010605	0.030	RS25N010620	0.031	0.065	2.2
<b>ortho-Phosphate (as P) - unspecified mg/l</b>	RS25N010605	0.007	RS25N010620	0.008	0.035	3.8
<b>Temperature °C</b>	RS25N010605	12	RS25N010620	12	N/A	
<b>Coliform Bacteria (Total) MPN/100ml</b>	RS25N010605	36294	RS25N010620	63732	N/A	
<b>Dissolved Oxygen % O2</b>	RS25N010605	94	RS25N010620	92	N/A	
<b>Total Nitrogen mg/l</b>	RS25N010605	4.33	RS25N010620	3.69	N/A	
<b>E. Coli MPN/100ml</b>	RS25N010605	386	RS25N010620	3102	N/A	



Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
Dissolved Oxygen mg/l	RS25N010605	10	RS25N010620	9.86	N/A	
pH pH units	RS25N010605	7.85	RS25N010620	7.80	N/A	

### Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence for the following: Ammonia-Total (as N) mg/l.

The ambient monitoring results meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in Ammonia, BOD, Coliform Bacteria, E. Coli, ortho-Phosphate, concentrations downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

Other causes of deterioration in water quality in the area are unknown.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - NENAGH NEW WWTP

### 2.1.4.1 Treatment Efficiency Report - Nenagh New WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
TP	9565	252	97

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
SS	653499	20070	97
COD	1040361	41051	96
TN	49437	21784	56
cBOD	328280	5358	98

Note: The above data is based on sample results for the number of dates reported

#### ***2.1.4.2 Treatment Capacity Report Summary - Nenagh New WWTP***

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Nenagh New WWTP	
Peak Hydraulic Capacity (m <sup>3</sup> /day) - As Constructed	12960
DWF to the Treatment Plant (m <sup>3</sup> /day)	4320
Current Hydraulic Loading - annual max (m <sup>3</sup> /day)	15428
Average Hydraulic loading to the Treatment Plant (m <sup>3</sup> /day)	6593
Organic Capacity (PE) - As Constructed	11000
Organic Capacity (PE) - Collected Load (peak week) <sup>Note1</sup>	12372
Organic Capacity (PE) - Remaining	0
Will the capacity be exceeded in the next three years? (Yes/No)	Yes

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

### 2.1.5 SLUDGE / OTHER INPUTS - NENAGH NEW WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

### 3 COMPLAINTS AND INCIDENTS

#### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2024.			

#### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

##### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	Recurring (Y/N)	Closed (Y/N)
Uncontrolled release	Inadequate Infrastructure	Yes	No
Abatement equipment off-line	Plant or equipment breakdown at WWTP	No	Yes
Breach of ELV	WWTP biological sludge issue	Yes	Yes

Incident Type	Cause	Recurring (Y/N)	Closed (Y/N)
Abatement equipment off-line	Plant or equipment breakdown at WWTP	No	Yes

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2024	4
Number of Incidents reported to the EPA via EDEN in 2024	4
Explanation of any discrepancies between the two numbers above	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2024 (No. of events)	Total volume discharged in 2024 (m3)	Monitoring Status
<b>SW002</b>	187285, 180078	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
<b>SW003</b>	187435, 179320	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
<b>SW004</b>	186823, 178826	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
<b>SW005</b>	185069, 180171	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
<b>TBC</b>	186817, 178069	No	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored

The contents presented in this table include the most up to date information available at the time of writing. Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much wastewater discharge by metered SWOs during the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0027-SIP:01</b>	Upgrade of sewer network to ensure SWOs comply with DoE criteria	C	31/12/2020	No	Not Started		Network SWOs meet DEHLG Criteria
<b>D0027-SIP:02</b>	Waste water sewer network improvements	C	31/12/2020	No	Not Started		Not required

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0027-SIP:03</b>	WWTP upgrade/improvements	C	01/01/2015	Yes	At Planning Stage	2029	

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

#### 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
<b>No additional improvements planned at this time.</b>				

#### 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.



## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Included in this AER
D0027-01-Habitats Impact Assessment	Yes	No
D0027-01-Priority Substances Assessment	Yes	No

## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	Yes
List reason e.g. additional SWO identified	Capital upgrade
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	N/A
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	No
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	No

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed:    Date: 30/06/2025

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Head of Environmental Regulation.

## 7 APPENDIX

There are no Appendices included