Annual Environmental Report 2024



Newport

D0224-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2024 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 Newport (Mayo) Septic Tank 1 Untreated Discharge
 - 2.1.1 EFFLUENT MONITORING SUMMARY NEWPORT (MAYO) SEPTIC TANK 1 -
 - 2.1.2 Ambient Monitoring Summary for Untreated Discharge -
- 2.2 NEWPORT (MAYO) SEPTIC TANK 2 UNTREATED DISCHARGE
 - 2.2.1 EFFLUENT MONITORING SUMMARY NEWPORT (MAYO) SEPTIC TANK 2 -
 - 2.2.2 Ambient Monitoring Summary for Untreated Discharge -

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SHMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 Specified Improvement Programme Summary
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 PRIORITY SUBSTANCES ASSESSMENT
- 5.2 SHELLFISH IMPACT ASSESSMENT

6 CERTIFICATION AND SIGN OFF

5.1 SUMMARY OF AER CONTENTS

7 APPENDIX

7.1 Ambient monitoring summary

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2024 AER

This Annual Environmental Report has been prepared for D0224-01, Newport, in Mayo in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

1.2 TREATMENT SUMMARY

- Currently there is no treatment provided at Newport . Please refer to section 4 for details of the Programme of Improvements.
- Currently there is no treatment provided at Newport . Please refer to section 4 for details of the Programme of Improvements.

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference Treatment Plant		Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF2200D0224SW001 Newport (Mayo) Septic Tank 1		Untreated Non-Compliant		N/A
TPEFF2200D0224SW002	NEWPORT (MAYO) SEPTIC TANK 2	Untreated	Non-Compliant	N/A

1.4 LICENCE SPECIFIC REPORTING

Assessment / Report

There are no Licence Specific Reports included in this AER.

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1.1 EFFLUENT MONITORING SUMMARY -

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)			
There is no	There is no Effluent data included in the AER.										

Notes:

- 1 This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied
- 2 For pH the WWDA specifies a range of pH 6 9

Cause of Exceedance(s):

There is no treatment provided at Newport.

Significance of Results:

There is no effluent monitoring carried out at the Newport Wastewater Treatment Plant.

2.1.2 AMBIENT MONITORING SUMMARY FOR THE UNTREATED DISCHARGE TPEFF2200D0224SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Upstream	99510, 294141	RS32N010100	No	No	No	Yes	High
Downstream	96139, 293892	TW22005284NB2003	No	No	No	Yes	High
Downstream	97561, 294086	TW22005284NB2002	No	No	No	Yes	High

The results for ambient results and / or additional monitoring data sets are included in the Appendix 7.1 - Ambient monitoring summary

Significance of Results:

The coastal/transitional ambient monitoring results do not meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence for the following: .

The ambient monitoring results do not meet the required EQS at the upstream and the downstream monitoring locations. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

Other causes of deterioration in water quality in the area are unknown.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

The discharge from the wastewater treatment plant does not have an observable impact on the designated shellfish water quality.

The discharge from the wastewater treatment plant does not have an observable impact on the coastal/transitional water quality.

2.1.3 EFFLUENT MONITORING SUMMARY -

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)			
There is no	There is no Effluent data included in the AER.										

Notes:

- 1 This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied
- 2 For pH the WWDA specifies a range of pH 6 9

Cause of Exceedance(s):

There is no treatment provided at Newport.

Significance of Results:

There is no effluent monitoring carried out at the Newport Wastewater Treatment Plant.

2.1.4 AMBIENT MONITORING SUMMARY FOR THE UNTREATED DISCHARGE TPEFF2200D0224SW002

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status

The results for ambient results and / or additional monitoring data sets are included in the Appendix 7.1 - Ambient monitoring summary

Significance of Results:

The coastal/transitional ambient monitoring results do not meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence for the following: .

The ambient monitoring results do not meet the required EQS at the upstream and the downstream monitoring locations. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

Other causes of deterioration in water quality in the area are unknown.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

The discharge from the wastewater treatment plant does not have an observable impact on the designated shellfish water quality.

The discharge from the wastewater treatment plant does not have an observable impact on the coastal/transitional water quality.

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environme	ental complaints in 2024.		

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	Recurring (Y/N)	Closed (Y/N)
There were no reportable incidents in 20)24.		

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2024	0
Number of Incidents reported to the EPA via EDEN in 2024	0
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2024 (No. of events)	Total volume discharged in 2024 (m3)	Monitoring Status
SW005	98187, 293726	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
SW006	98371, 293886	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
SW007	99241, 293998	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored

The contents presented in this table include the most up to date information available at the time of writing. Any TBC SWO(s) were identified as part of the ongoing National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much wastewater discharge by metered SWOs during the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	No
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0224-SIP:01	Improvement works to increase the organic and hydraulic treatment capacity of the plant to ensure compliance with Condition 1.7 of this licence.	С	31/12/2018	Yes	At Planning Stage	2030	

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
No additional improve	ments planned at this time.			

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Included in this AER
D0224-01-Priority Substances Assessment	Yes	No
D0224-01-Shellfish Impact Assessment	Yes	No

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	N/A
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	N/A
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 16/07/2025

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Head of Environmental Regulation.

7 APPENDIX

Appendix

Appendix 7.1 - Ambient monitoring summary

County	Licence Ref.	Agglomeration	Receiving Water B	Monitoring Location	Monitoring Result Source	Date																															
							рН	Temperature (°C)	BOD mg/l	COD mg/l	SS mg/l	Total Nitrogen (as N) mg/l	Total Phosphorus (as P) mg/l	Ammonia (as N) mg/l	Orthophosphate (as P) mg/l	Dissolved Oxygen%	Total Oxidised Nitrogen (as N) mg/l	Dissolved Inorganic Nitrogen (as N) mg/l	Faecal Coliforms cfu/100ml	Escherichia coli cfu/100ml	Intestinal Enterococci cfu/100ml	Visual Inspection	SSPS	Water level	Conductivity	Nitrate	Chloride	Fluoride	Ammonium (NH4)	Major anions	Major Cations	Priority Subs	Metals & Organic Compounds	Salinity	Nitrate	Nitrite	Chlorophyll
Mayo	D0224-01	Newport	Newport Bay	Number of samples Required					0	0	0	6	0	0	6	0.0	6	Œ	0	6	6	6	0														
Issued on	20/11/2015								L	L														L				L	L	L	L						
				Newport Upstream	Email	27-Feb-2024			<1	1	< 4			0.05		104.9	< 0.2		236	101	50								L	1				< 0.1			
				Newport Downstream SP1	Email	27-Feb-2024			< 1		20			0.27		135.1	< 0.2		365	138	69									I				9			
				Newport Downstream SP2	Email	27-Feb-2024			1.7		4			0.07		131.0	0.28		1733	138	68			L	L		L		L					< 0.1			
				Newport Downstream SP2	Email	10-May-2024	L		< 1		4	L	L	0.04		102.9	0.41		> 201	> 201	> 201			L	L		L		L				LL	1.5		L	
				Newport Downstream SP1	Email	10-May-2024			<1		38						< 0.2		78	> 201	109								L	_				22.3			
				Newport Upstream	Email	10-May-2024			< 1		< 2					99.7	< 0.2		14	12	4																
				Newport Downstream SP2	Email	25-July-2024	L		1.3		26			< 0.035		124.7	< 0.02		<1	9	167			L				_		_			L	29.7			
				Newport Downstream SP1	Email	25-July-2024	L		1.5		10			0.06		85.2	0.26		641	641	192			L				L		_			LI	457			
				Newport Upstream	Email	25-July-2024	L		< 1		8		L	0.1		104.8	< 0.2		62	44	9			L			<u> </u>	1	L	1	L		<u> </u>	< 0.1			
				Newport Downstream SP1	Email	10-Oct-2024	L	L	< 1	_	< 10		L	0.0		96.2	< 0.2		221.0	727.0	114.0			L			L	L	L	1	L		L	2.4			
				Newport Upstream	Email	10-Oct-2024			< 1		< 10		L	0.1		106.0	< 0.2		102.0	109.0	19.0			L			L	_	L	_			LI	< 0.1			
				Newport Downstream SP2	Email	10-Oct-2024	L	<u> </u>	<1		56.0	L	L	< 0.035		111.1	< 0.02	L	<1	<1	7.0		L	L	L	L	<u> </u>				L	<u> </u>	L	34.8		L	↓
										1								L						L			L	L		_	L		L			L	—
							<u> </u>	L	<u> </u>	<u> </u>	<u> </u>	L	L	L		L	L	L	L	L	L		L	L	L	L	L	L	L	L	L	L	L			L	