

Annual Environmental Report

2024



Tarbert

D0283-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2024 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 TARBERT WWTP (NEW) - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - TARBERT WWTP (NEW)
 - 2.1.2 EFFLUENT MONITORING SUMMARY - TARBERT WWTP (NEW) -
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR TARBERT WWTP (NEW)
 - 2.1.5 SLUDGE/OTHER INPUTS TO TARBERT WWTP (NEW)

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 PRIORITY SUBSTANCES ASSESSMENT

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

- 7.1 AMBIENT MONITORING SUMMARY

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2024 AER

This Annual Environmental Report has been prepared for D0283-01, Tarbert, in Kerry in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There were no major capital or operational changes undertaken.

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- TARBERT WWTP (NEW) with a Plant Capacity PE of 1300, the treatment type is 2 - Secondary treatment .

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF1300D0283SW001	TARBERT WWTP (NEW)	Treated	Compliant	N/A

1.4 LICENCE SPECIFIC REPORTING

Assessment / Report
There are no Licence Specific Reports included in this AER.

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 TARBERT WWTP (NEW) - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - TARBERT WWTP (NEW)

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Suspended Solids mg/l	6	99	47
pH pH units	6	7.80	7.52
ortho-Phosphate (as P) - unspecified mg/l	4	2.83	1.45
COD-Cr mg/l	6	299	127
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	6	282	71
Hydraulic Capacity	N/A	988	448

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF1300D0283SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
pH pH units	9	9	N/A	6	N/A	N/A	7.40	Pass
ortho-Phosphate (as P) - unspecified mg/l	8	9.6	N/A	6	N/A	N/A	1.08	Pass
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	N/A	N/A	N/A	6	N/A	N/A	1.61	
COD-Cr mg/l	N/A	N/A	N/A	6	N/A	N/A	19	
Suspended Solids mg/l	N/A	N/A	N/A	6	N/A	N/A	3.26	
Visual Inspection Descriptive	N/A	N/A	N/A	6	N/A	N/A	N/A	
Salinity(Lab) 0/oo	N/A	N/A	N/A	4	N/A	N/A	0.310	
Conductivity @20°C µS/cm	N/A	N/A	N/A	4	N/A	N/A	841	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

Cause of Exceedance(s):

Not applicable

Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF1300D0283SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Downstream	106594, 147751	RS24T010100	No	No	No	No	Moderate
Downstream	107821, 151031	TW19004123SN3008	No	No	No	No	Good

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**

Significance of Results:

The coastal/transitional ambient monitoring results do not meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

The discharge from the wastewater treatment plant does not have an observable impact on the coastal/transitional water quality.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - TARBERT WWTP (NEW)

2.1.4.1 Treatment Efficiency Report - TARBERT WWTP (NEW)

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
COD	19237	2870	85
TN	N/A	N/A	N/A
SS	7051	505	93
cBOD	10784	249	98
TP	N/A	N/A	N/A

Note: The above data is based on sample results for the number of dates reported

2.1.4.2 Treatment Capacity Report Summary - TARBERT WWTP (NEW)

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

TARBERT WWTP (NEW)	
Peak Hydraulic Capacity (m ³ /day) - As Constructed	879
DWF to the Treatment Plant (m ³ /day)	293

TARBERT WWTP (NEW)	
Current Hydraulic Loading - annual max (m³/day)	988
Average Hydraulic loading to the Treatment Plant (m³/day)	447.58
Organic Capacity (PE) - As Constructed	1300
Organic Capacity (PE) - Collected Load (peak week) ^{Note1}	991
Organic Capacity (PE) - Remaining	309
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - TARBERT WWTP (NEW)

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2024.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	Recurring (Y/N)	Closed (Y/N)
There were no reportable incidents in 2024.			

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2024	0
Number of Incidents reported to the EPA via EDEN in 2024	0
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2024 (No. of events)	Total volume discharged in 2024 (m3)	Monitoring Status
SW002	106977, 147733	Yes	Low Significance	Meeting Criteria	Unknown	57	Monitored
SW003	106880, 147748	Yes	Low Significance	Meeting Criteria	Unknown	66702	Monitored
SW004	106977, 147733	Yes	Low Significance	Meeting Criteria	Unknown	2	Monitored
TBC	106581, 147736	No	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored

The contents presented in this table include the most up to date information available at the time of writing. Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much wastewater discharge by metered SWOs during the year (m3)?	66761

SWO Summary	
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0283-SIP:01	Any improvement works required to ensure compliance with the emission limit values as set out in Schedule A: Discharges & Discharge Monitoring	C	31/12/2019	Yes	Works Completed		
D0283-SIP:02	Primary Discharge Point (SW001) to be discontinued.	C	31/12/2019	Yes	Works Completed		

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0283-SIP:03	Secondary Discharge Point (SW002) to be discontinued	C	31/12/2019	Yes	Works Completed		

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
No additional improvements planned at this time.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Included in this AER
D0283-01-Priority Substances Assessment	Yes	No

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	N/A
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	N/A
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	No

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 09/07/2025

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Head of Environmental Regulation.

7 APPENDIX

Appendix
Appendix 7.1 - Ambient monitoring summary

Ambient Points

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	EPA Feature Coding Tool code	Receiving Waters Designation (Y/N)				WFD Status
			Bathing Water	Drinking Water	FWPM	Shellfish	
RS24T010100	106594, 147751	TPEFF1300D0283SW001	No	No	No	No	Moderate
TW19004123SN3008	107821, 151031	TPEFF1300D0283SW001	No	No	No	No	Good

Ambient Impact Assessment Table

Parameter Name	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS (Mean)	%EQS
Alkalinity-total (as CaCO ₃) mg/l	RS24T010100	141.750	TW19004123SN3008			
Ammonia (as N) mg/l	RS24T010100	0.056	TW19004123SN3008	0.028	River: 0.065	
BOD mg/l	RS24T010100	1.729	TW19004123SN3008	0.707	River: 1.5 TW: 4.0	
Chloride mg/l	RS24T010100	31.375	TW19004123SN3008			
Conductivity µS/cm	RS24T010100	397.500	TW19004123SN3008			
Depth m	RS24T010100		TW19004123SN3008	24.967		
Dissolved Oxygen %saturation	RS24T010100	98.343	TW19004123SN3008	96.667	TW: 70 -130	
Dissolved Oxygen mg/l	RS24T010100	10.575	TW19004123SN3008			
Ortho-Phosphate (as P) mg/l	RS24T010100	0.072	TW19004123SN3008	0.083	River: 0.035 TW: 0.060	
pH pH units	RS24T010100	7.957	TW19004123SN3008	7.967		
Salinity PSU	RS24T010100	12.685	TW19004123SN3008	30.700		
Salinity(Lab) 0/oo	RS24T010100	0.071	TW19004123SN3008	29.500		
Silica (as SiO ₂)	RS24T010100		TW19004123SN3008	0.380		
Station Depth	RS24T010100		TW19004123SN3008	31.267		
Suspended Solids mg/l	RS24T010100	8.276	TW19004123SN3008			

Temperature	RS24T010100	10.850	TW19004123SN3008	15.933		
Total Hardness (as CaCO3) mg/l	RS24T010100	158.000	TW19004123SN3008			
Total Oxidised Nitrogen (as N) mg/l	RS24T010100	1.060	TW19004123SN3008	0.074		
Transparency m	RS24T010100		TW19004123SN3008	2.167		
True Colour mg/litre Pt Co	RS24T010100	76.000	TW19004123SN3008			

Ambient Data Tables

				Ammonia- Total (as N)	BOD - 5 days (Total)	Dep th	Dissolved Oxygen	ortho-Phosphate (as P) - unspecified	pH	Salin ity	Salinity(Lab)	Silica (as SiO2)	StationD epth	Temper ature	Total Oxidised Nitrogen (as N)	Transpar ency
Monitored Enity	Station	Monitoring Point	Sample Date	mg/l	mg/l	m	% Saturation	mg/l	pH Uni ts	PSU	0/oo	mg/l	m	°C	mg/l	m
Lower Shannon Estruary	TW19004123 SN3008	Downstrea m	25/05/2 023	0.026	<1	24.7	98	0.22	7.9	31.2	29.6	0.35	34	13.5	0.1	3.2
Lower Shannon Estruary	TW19004123 SN3008	Downstrea m	13/07/2 023	0.02		23	96	0.018	8	31.4	30.4	0.2	27.9	17.6	0.08	1.5
Lower Shannon Estruary	TW19004123 SN3008	Downstrea m	24/08/2 023	0.039		27.2	96	0.01	8	29.5	28.5	0.59	31.9	16.7	0.043	1.8
			Mean	0.028	0.707	24.9 67	96.667	0.083	7.9 67	30.7 00	29.500	0.380	31.267	15.933	0.074	2.167

Note: Where the concentration in the result is less than the limit of detection (LOD), a value of LOD/sqrt(2) was used in calculating the mean and 95%ile concentrations