

Annual Environmental Report

2018



Achill Island Central Waste Water Treatment
Plant

D0072-01

TABLE OF CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2018 AER

- 1.1 LICENCE SPECIFIC REPORTING INCLUDED IN AER
- 1.2 TREATMENT TYPE
 - 1.2.1 ACHILL ISLAND CENTRAL WWTP
- 1.3 ELV OVERVIEW
 - 1.3.1 ACHILL ISLAND CENTRAL WWTP
- 1.4 SLUDGE REMOVAL

2 MONITORING REPORTS SUMMARY

- 2.1 SUMMARY REPORT ON MONTHLY INFLUENT MONITORING
 - 2.1.1 INFLUENT MONITORING SUMMARY - ACHILL ISLAND CENTRAL WWTP
- 2.2 DISCHARGES FROM THE AGGLOMERATION
 - 2.2.1 EFFLUENT MONITORING SUMMARY - ACHILL ISLAND CENTRAL WWTP
- 2.3 AMBIENT MONITORING SUMMARY
 - 2.3.1 AMBIENT MONITORING REPORT SUMMARY - ACHILL ISLAND CENTRAL WWTP
 - 2.3.2 AMBIENT MONITORING PARAMETER MEAN (MG/L) - ACHILL ISLAND CENTRAL WWTP

3 OPERATIONAL REPORTS SUMMARY

- 3.1 TREATMENT EFFICIENCY REPORT
 - 3.1.1 TREATMENT EFFICIENCY REPORT SUMMARY - ACHILL ISLAND CENTRAL WWTP
- 3.2 TREATMENT CAPACITY REPORT SUMMARY
- 3.3 COMPLAINTS SUMMARY
- 3.4 REPORTED INCIDENTS SUMMARY
 - 3.4.1 SUMMARY OF INCIDENTS
 - 3.4.2 SUMMARY OF OVERALL INCIDENTS
- 3.5 SLUDGE / OTHER INPUTS TO THE WWTP

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION
 - 4.1.2 INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

- 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
- 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
- 4.2.3 SEWER INTEGRITY RISK ASSESSMENT SUMMARY

5 LICENCE SPECIFIC REPORTS

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS
- 6.2 DECLARATION BY IRISH WATER

7 APPENDIX

- 7.1 AMBIENT MONITORING SUMMARY

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2018 AER

This Annual Environmental Report has been prepared for D0072-01, Achill Island Central Waste Water Treatment Plant, in Mayo in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports are included as an appendix to the AER as follows:

1.1 Licence specific reporting included in AER

| Assessment / Report | Included in AER |
|-----------------------------------------------------------|-----------------|
| There is no Licence Specific Reports included in the AER. | |

1.2 Treatment Type

The agglomeration is served by a wastewater treatment plant ACHILL ISLAND CENTRAL WWTP with a Plant Capacity PE of 4000. The treatment process includes the following:

1.2.1 ACHILL ISLAND CENTRAL WWTP

| Treatment type | Yes / No | Details |
|-----------------------|----------|---------------------------------------------|
| Preliminary Treatment | Yes | Screen + Grit trap |
| Primary Treatment | No | |
| Secondary Treatment | Yes | Aeration + clarification (activated sludge) |
| Nutrient Removal | No | |
| Tertiary Treatment | No | |

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.2 Discharges from the agglomeration.

1.3 ELV Overview

1.3.1 ACHILL ISLAND CENTRAL WWTP

| Compliance Status | |
|------------------------------------------------------------------------------|-----|
| Were all parameters compliant for ACHILL ISLAND CENTRAL WWTP treatment plant | Yes |
| Where noncompliant see table 2.2.1 for details of parameters | |

1.4 Sludge Removal

The amount of sludge removed from the wastewater treatment plant is shown below along with the transported destination of the sludge from the treatment plant.

| Treatment Plant | Sludge type | Quantity | Unit | % Dry Solids | Destination |
|----------------------------|-------------|----------|-----------------|--------------|-----------------------------------------|
| ACHILL ISLAND CENTRAL WWTP | Cake Sludge | 14.75 | Weight (Tonnes) | 11.9 | Laragan, Elphin, Co. Roscommon |
| ACHILL ISLAND CENTRAL WWTP | Cake Sludge | 3.34 | Weight (Tonnes) | 11.9 | Tibohine, Ballaghadereen, Co. Roscommon |

Annual Statement of Measures

None undertaken and none planned.

2 MONITORING REPORTS SUMMARY

2.1 Summary report on monthly influent monitoring

A summary of influent monitoring for the treatment plant is presented in below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

2.1.1 Influent Monitoring Summary - ACHILL ISLAND CENTRAL WWTP

| Parameters | Number of Samples | Annual Max | Annual Mean |
|-----------------------------------------------------|-------------------|------------|-------------|
| Total Phosphorus (as P) mg/l | 13 | 10.1 | 1.71 |
| Total Nitrogen mg/l | 13 | 73 | 14.62 |
| COD-Cr mg/l | 13 | 878 | 189.33 |
| BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l | 13 | 140 | 39.44 |
| Suspended Solids mg/l | 13 | 485 | 82.89 |
| Hydraulic Capacity | 0 | 3537 | 997 |

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 3.5 if applicable

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity as detailed further in Section 3.2. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity as detailed further in Section 3.2. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

2.2 Discharges from the agglomeration

2.2.1 Effluent Monitoring Summary - ACHILL ISLAND CENTRAL WWTP

| Parameter | WWDL ELV (Schedule A) | ELV with Condition 2 Interpretation included ^{Note 1} | Interim % reduction from influent concentration | Number of sample results | Number of exceedances | Number of exceedances with Condition 2 Interpretation included | Annual Mean | Overall Compliance (Pass/Fail) |
|-----------------------------------------------------|-----------------------|----------------------------------------------------------------|-------------------------------------------------|--------------------------|-----------------------|----------------------------------------------------------------|-------------|--------------------------------|
| Total Oxidised Nitrogen (as N) mg/l | 10 | 12 | 0 | 13 | 2 | 0 | 5.77 | Pass |
| BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l | 25 | 50 | 0 | 13 | 0 | 0 | 2.7 | Pass |
| COD-Cr mg/l | 125 | 250 | 0 | 13 | 0 | 0 | 38.31 | Pass |
| Ammonia-Total (as N) mg/l | 10 | 12 | 0 | 13 | 0 | 0 | 1.19 | Pass |
| pH pH units | 0 | 0 | 0 | 13 | 0 | 0 | 7.61 | Pass |
| Suspended Solids mg/l | 35 | 87.5 | 0 | 13 | 0 | 0 | 5.18 | Pass |
| ortho-Phosphate (as P) - unspecified mg/l | 0 | 0 | 0 | 13 | 0 | 0 | 0.26 | Pass |
| Total Nitrogen mg/l | 0 | 0 | 0 | 13 | 0 | 0 | 10.15 | Pass |

| Parameter | WWDL ELV (Schedule A) | ELV with Condition 2 Interpretation included ^{Note 1} | Interim % reduction from influent concentration | Number of sample results | Number of exceedances | Number of exceedances with Condition 2 Interpretation included | Annual Mean | Overall Compliance (Pass/Fail) |
|--------------------------------------|-----------------------|----------------------------------------------------------------|-------------------------------------------------|--------------------------|-----------------------|----------------------------------------------------------------|-------------|--------------------------------|
| Total Phosphorus (as P) mg/l | 0 | 0 | 0 | 13 | 0 | 0 | 0.51 | Pass |
| Visual Inspection Descriptive | 0 | 0 | 0 | 6 | 0 | 0 | 0 | Pass |
| Fats, Oils & Greases mg/l | 0 | 0 | 0 | 1 | 0 | 0 | 2.5 | Pass |

Notes:

1- This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 - For parameters where a mean ELV applies

Cause of Exceedance(s):

Not Applicable

Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

2.3 Ambient monitoring summary

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

2.3.1 Ambient Monitoring Report Summary - ACHILL ISLAND CENTRAL WWTP

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

| Ambient Monitoring Point from WWDL (or as agreed with EPA) | Irish Grid Reference | Code | Bathing Water | Drinking Water | FWPM | Shellfish | WFD Status |
|------------------------------------------------------------|----------------------|---------------------|---------------|----------------|------|-----------|------------|
| Upstream | 56089, 304134 | TPEFF2200D0072SW001 | Yes | No | No | No | Unassigned |
| Downstream | 63761, 304492 | TPEFF2200D0072SW001 | Yes | No | No | No | Unassigned |

2.3.2 Ambient Monitoring Parameter Summary - ACHILL ISLAND CENTRAL WWTP

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**

Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results did not meet the required EQS.

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

3 OPERATIONAL REPORTS SUMMARY

3.1 Treatment Efficiency Report

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

3.1.1 Treatment Efficiency Report Summary - ACHILL ISLAND CENTRAL WWTP

| Parameter | Influent mass loading (kg/year) | Effluent mass emission (kg/year) | Efficiency (% reduction of influent load) | Comment |
|-------------|---------------------------------|----------------------------------|-------------------------------------------|---------|
| cBOD | 15946.96 | 1093.74 | 93.14 | |
| TN | 5909.88 | 4105.21 | 30.54 | |
| COD | 76559.9 | 15491.98 | 79.76 | |
| TP | 689.87 | 205.36 | 70.23 | |
| SS | 33515.82 | 2093.26 | 93.75 | |

Note: The above data is based on sample results for the number of dates reported

3.2 Treatment Capacity Report Summary

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

| ACHILL ISLAND CENTRAL WWTP | |
|----------------------------------------------------------|------|
| Peak Hydraulic Capacity (m3/day) - As Constructed | 1680 |

| ACHILL ISLAND CENTRAL WWTP | |
|-----------------------------------------------------------------|------|
| DWF to the Treatment Plant (m3/day) | 559 |
| Current Hydraulic Loading - annual max (m3/day) | 3537 |
| Average Hydraulic loading to the Treatment Plant (m3/day) | 997 |
| Organic Capacity (PE) - As Constructed | 4000 |
| Organic Capacity (PE) - Collected Load (peak week) | 1147 |
| Organic Capacity (PE) - Remaining | 2853 |
| Will the capacity be exceeded in the next three years? (Yes/No) | No |

3.3 Complaints Summary

A summary of complaints of an environmental nature is included below.

| Number of Complaints | Nature of Complaint | Number Open Complaints | Number Closed Complaints |
|-------------------------------------------------|---------------------|------------------------|--------------------------|
| There is no Complaint data included in the AER. | | | |

3.4 Reported Incidents Summary

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.4.1 Summary of Incidents

| Incident Type | Cause | No. of incident occurrences | Recurring (Y/N) | Closed (Y/N) |
|------------------------------------------------|-------|-----------------------------|-----------------|--------------|
| There is no Incident data included in the AER. | | | | |

3.4.2 Summary of Overall Incidents

| Question | Answer |
|----------------------------------------------------------------|--------|
| Number of Incidents in 2018 | 0 |
| Number of Incidents reported to the EPA via EDEN in 2018 | 0 |
| Explanation of any discrepancies between the two numbers above | |

3.5 Sludge / Other inputs to the WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

| Input type | Quantity | Unit | P.E. | % of load to WWTP | Included in Influent Monitoring (Y/N)? | Is there a leachate/sludge acceptance procedure for the WWTP? | Is there a dedicated leachate/sludge acceptance facility for the WWTP?(Y/N) |
|------------------------------|----------|-------------|------|-------------------|----------------------------------------|---------------------------------------------------------------|-----------------------------------------------------------------------------|
| Other | 466.4 | Volume (m3) | 5.68 | 0.13 | Yes | Yes | No |
| Other | 229.1 | Volume (m3) | 2.79 | 0.06 | Yes | Yes | No |
| Domestic /Septic Tank Sludge | 8.2 | Volume (m3) | 0.1 | 0 | Yes | Yes | No |

| Input type | Quantity | Unit | P.E. | % of load to WWTP | Included in Influent Monitoring (Y/N)? | Is there a leachate/sludge acceptance procedure for the WWTP? | Is there a dedicated leachate/sludge acceptance facility for the WWTP?(Y/N) |
|------------|----------|-------------|------|-------------------|----------------------------------------|---------------------------------------------------------------|-----------------------------------------------------------------------------|
| Other | 227 | Volume (m3) | 2.76 | 0.06 | Yes | Yes | No |

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 Storm Water Overflow Identification and Inspection Report

A summary of the operation of the storm water overflows and their significance where known is included below:

No Appendix Included

4.1.1 SWO Identification

| WWDL Name / Code for Storm Water Overflow | Irish Grid Ref. | Included in Schedule A4 of the WWDL | Significance of the overflow(High / Medium / Low) | Assessed against DoEHLG Criteria | No. of times activated in 2018 (No. of events) | Total volume discharged in 2018 (m3) | Monitoring Status |
|-------------------------------------------|-----------------|-------------------------------------|---------------------------------------------------|----------------------------------|------------------------------------------------|--------------------------------------|-------------------|
| SW005 | 61942, 303731 | Yes | Low | Meeting | | | Not Monitored |

4.1.2 Inspection Summary Report

| SWO Summary | |
|-------------------------------------------------------------------------------------------------------|-----|
| How much sewage was discharged via SWOs in the agglomeration in the year (m3)? | |
| Is each SWO identified as non meeting DoEHLG Guidance included in the Programme of Improvements? | Yes |
| The SWO Assessment included the requirements of relevant of WWDL schedules? | No |
| Have the EPA been advised of any additional SWOs / charges to Schedule C3 and A4 under Condition 1.7? | No |

4.2 Report on progress made and proposals being developed to meet the improvement programme requirements.

4.2.1 Specified Improvement Programme Summary

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

| Specified Improvement Programmes (under Schedule A and C of WWDL) | Licence Schedule | Licence Completion Date | Date Expired? (N/NA/Y) | Status of Works | Timeframe for Completing the Work | Comments |
|------------------------------------------------------------------------------|------------------|-------------------------|------------------------|-----------------|-----------------------------------|----------|
| There are no Specified Improvement Programmes for this Agglomeration. | | | | | | |

A summary of the status of any improvements identified by under Condition 5.2 is included below.

4.2.2 Improvement Programme Summary

| Improvement Identifier | Improvement Description | Improvement Source | Expected Completion Date | Comments |
|--------------------------------------------------------------------|-------------------------|--------------------|--------------------------|----------|
| There are no Improvements Programme for this Agglomeration. | | | | |

4.2.3 Sewer Integrity Risk Assessment

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table".

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

| Licence Specific Report | Required by licence | Year included in AER | Included in this AER | Reference to relevant section of AER (e.g. Appendix X). |
|--------------------------------------------------------------------------------|---------------------|----------------------|----------------------|---------------------------------------------------------|
| There is no Licence Specific Report Required in this AER Annual Review. | | | | |

6 CERTIFICATION AND SIGN OFF

6.1 Summary of AER Contents

| Parameter | Answer |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------|
| Does the AER include an Executive Summary? | Yes |
| Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)? | Yes |
| Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence? | No |
| List reason e.g. additional SWO identified | |
| Is there a need to request/advise the EPA of any modifications to the existing WWDL? | No |
| List reason e.g. changes to monitoring requirements | |
| Have these processes commenced? | |
| Are all outstanding reports and assessments from previous AERs included as an appendix to this AER | N/A |

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 04/03/2019

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Acting Head of Environmental Regulation.

7 APPENDIX

Appendix

Appendix 7.1 - Ambient monitoring summary

Ambient Monitoring Results 2018

Upstream (Keel Beach)

| Date | Colour (mg/l Pt Co) | TON (mg/l) | NH4 – N (mg/l) | E.Coli (MPN/100ml) | Enterococci (cfu/100ml) | Faecal Coliforms (cfu/100ml) |
|-----------|---------------------------|---------------|-------------------|-----------------------|----------------------------|------------------------------------|
| 10-Jan-18 | <4 | 0.108 | <0.01 | | | |
| 08-Feb-18 | <4 | 0.134 | 0.01 | | | |
| 08-Mar-18 | <4 | 0.114 | <0.01 | | | |
| 10-Apr-18 | <4 | 0.015 | 0.014 | 0 | 0 | <1 |
| 03-May-18 | <4 | 0.011 | 0.01 | 3 | 0 | 3 |
| 06-Jun-18 | <4 | 0.021 | <0.010 | 0 | 0 | <1 |
| 25-Jul-18 | | <0.15 | 0.939 | 0 | 7 | 29 |
| 28-Aug-18 | | <0.15 | 0.056 | 3 | 32 | 14 |
| 13-Sep-18 | | <0.15 | 0.125 | 1300 | 0 | 1700 |
| 27-Sep-18 | | <0.15 | 0.415 | 0 | 4 | 6 |
| 17-Oct-18 | | <0.15 | 0.395 | 0 | 2 | 2 |
| 07-Nov-18 | | <0.15 | 0.467 | 0 | 10 | 4 |
| 04-Dec-18 | | <0.15 | 0.441 | 0 | 0 | <1 |

Downstream (Keem Beach)

| Date | Colour (mg/l Pt Co) | TON (mg/l) | NH4 – N (mg/l) | E.Coli (MPN/100ml) | Enterococci (cfu/100ml) | Faecal Coliforms (cfu/100ml) |
|-----------|---------------------------|---------------|-------------------|-----------------------|----------------------------|------------------------------------|
| 10-Jan-18 | <4 | 0.108 | <0.01 | | | |
| 08-Feb-18 | <4 | 0.137 | <0.01 | | | |
| 08-Mar-18 | <4 | 0.129 | <0.01 | | | |
| 10-Apr-18 | <4 | 0.021 | 0.018 | 3 | 0 | 3 |
| 03-May-18 | <4 | 0.034 | 0.01 | 3 | 0 | 3 |
| 06-Jun-18 | <4 | 0.026 | 0.016 | 9 | 300 | 9 |
| 25-Jul-18 | | <0.15 | 0.806 | 0 | 12 | 3 |
| 28-Aug-18 | | <0.15 | 0.048 | 0 | 0 | 4 |
| 13-Sep-18 | | <0.15 | 0.103 | 100 | 0 | 100 |
| 27-Sep-18 | | <0.15 | 0.403 | 0 | 20 | 1 |
| 17-Oct-18 | | <0.15 | 0.43 | 0 | 1 | 4 |
| 07-Nov-18 | | <0.15 | 0.442 | 0 | 5 | 10 |
| 04-Dec-18 | | <0.15 | 0.454 | 0 | 0 | <1 |