

# Annual Environmental Report

2018



Cashel

D0171-01

## **TABLE OF CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2018 AER**

- 1.1 LICENCE SPECIFIC REPORTING INCLUDED IN AER
- 1.2 TREATMENT TYPE
  - 1.2.1 CASHEL WWTP
- 1.3 ELV OVERVIEW
  - 1.3.1 CASHEL WWTP
- 1.4 SLUDGE REMOVAL

### **2 MONITORING REPORTS SUMMARY**

- 2.1 SUMMARY REPORT ON MONTHLY INFLUENT MONITORING
  - 2.1.1 INFLUENT MONITORING SUMMARY - CASHEL WWTP
- 2.2 DISCHARGES FROM THE AGGLOMERATION
  - 2.2.1 EFFLUENT MONITORING SUMMARY - CASHEL WWTP
- 2.3 AMBIENT MONITORING SUMMARY
  - 2.3.1 AMBIENT MONITORING REPORT SUMMARY - CASHEL WWTP
  - 2.3.2 AMBIENT MONITORING PARAMETER MEAN (MG/L) - CASHEL WWTP

### **3 OPERATIONAL REPORTS SUMMARY**

- 3.1 TREATMENT EFFICIENCY REPORT
  - 3.1.1 TREATMENT EFFICIENCY REPORT SUMMARY - CASHEL WWTP
- 3.2 TREATMENT CAPACITY REPORT SUMMARY
- 3.3 COMPLAINTS SUMMARY
- 3.4 REPORTED INCIDENTS SUMMARY
  - 3.4.1 SUMMARY OF INCIDENTS
  - 3.4.2 SUMMARY OF OVERALL INCIDENTS
- 3.5 SLUDGE / OTHER INPUTS TO THE WWTP

### **4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION
  - 4.1.2 INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

4.2.3 SEWER INTEGRITY RISK ASSESSMENT SUMMARY

**5 LICENCE SPECIFIC REPORTS**

5.1 DRINKING WATER ABSTRACTION POINT RISK ASSESSMENT

5.2 PRIORITY SUBSTANCES ASSESSMENT

**6 CERTIFICATION AND SIGN OFF**

6.1 SUMMARY OF AER CONTENTS

6.2 DECLARATION BY IRISH WATER

**7 APPENDIX**

7.1 AMBIENT MONITORING SUMMARY

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2018 AER

This Annual Environmental Report has been prepared for D0171-01, Cashel, in Tipperary in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports are included as an appendix to the AER as follows:

## 1.1 Licence specific reporting included in AER

Assessment / Report	Included in AER
---------------------	-----------------

## 1.2 Treatment Type

The agglomeration is served by a wastewater treatment plant CASHEL WWTP with a Plant Capacity PE of 9000. The treatment process includes the following:

### 1.2.1 CASHEL WWTP

Treatment type	Yes / No	Details
Preliminary Treatment	Yes	Automatic Inlet Screen
Primary Treatment	Yes	Inlet sump
Secondary Treatment	Yes	Acivated Sludge Process
Nutrient Removal	Yes	Chemical dosing
Tertiary Treatment	No	

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.2 Discharges from the agglomeration.

### 1.3 ELV Overview

#### 1.3.1 CASHEL WWTP

Compliance Status	
Were all parameters compliant for CASHEL WWTP treatment plant	Yes
Where noncompliant see table 2.2.1 for details of parameters	

### 1.4 Sludge Removal

The amount of sludge removed from the wastewater treatment plant is shown below along with the transported destination of the sludge from the treatment plant.

Treatment Plant	Sludge type	Quantity	Unit	% Dry Solids	Destination
CASHEL WWTP	Cake Sludge	134.04	Weight (Tonnes)	19.4	Molaisin Composting
CASHEL WWTP	Cake Sludge	612.84	Weight (Tonnes)	19.45	Clonmel Sludge Dryer
CASHEL WWTP	Cake Sludge	75.94	Weight (Tonnes)	19.5	Ormonde Organics

#### Annual Statement of Measures

No Significant works or changes were undertaken in 2018

## 2 MONITORING REPORTS SUMMARY

### 2.1 Summary report on monthly influent monitoring

A summary of influent monitoring for the treatment plant is presented in below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

#### 2.1.1 Influent Monitoring Summary - CASHEL WWTP

Parameters	Number of Samples	Annual Max	Annual Mean
Total Nitrogen mg/l	12	71.2	40.09
COD-Cr mg/l	12	1196	578.99
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	12	560	228.54
Total Phosphorus (as P) mg/l	12	11.52	5.62
Suspended Solids mg/l	12	1124	363.57
Hydraulic Capacity	0	5206	1894

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 3.5 if applicable

#### Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity as detailed further in Section 3.2. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity as detailed further in Section 3.2. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

### 2.2 Discharges from the agglomeration

#### 2.2.1 Effluent Monitoring Summary - CASHEL WWTP

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedences	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l</b>	25	50	0	12	0	0	2.84	Pass
<b>Ammonia-Total (as N) mg/l</b>	5	6	0	12	0	0	0.8	Pass
<b>ortho-Phosphate (as P) - unspecified mg/l</b>	1.5	1.8	0	12	0	0	0.13	Pass
<b>Total Nitrogen mg/l</b>	0	0	0	12	0	0	15.39	Pass
<b>COD-Cr mg/l</b>	125	250	0	12	0	0	24.63	Pass
<b>pH pH units</b>	0	0	0	12	0	0	7.19	Pass
<b>Suspended Solids mg/l</b>	35	87.5	0	12	0	0	5.66	Pass
<b>Total Phosphorus (as P) mg/l</b>	0	0	0	12	0	0	0.24	Pass

Notes:

1- This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 - For parameters where a mean ELV applies

Cause of Exceedance(s):

Not Applicable

Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

## 2.3 Ambient monitoring summary

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

### 2.3.1 Ambient Monitoring Report Summary - CASHEL WWTP

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	204077, 141137	TPEFF2900D0171SW001	No	No	No	No	Good
Downstream	203992, 140823	TPEFF2900D0171SW001	No	No	No	No	Good

### 2.3.2 Ambient Monitoring Parameter Summary - CASHEL WWTP

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**

#### Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results meet the required EQS.

The discharge from the wastewater treatment plant do not have an observable impact on the water quality.

The discharge from the wastewater treatment plant do not have an observable negative impact on the Water Framework Directive status.

Other Potential cause of deterioration in water quality relevant to this area are: None. The EQS assessed relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009, as amended.

### 3 OPERATIONAL REPORTS SUMMARY

#### 3.1 Treatment Efficiency Report

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

##### 3.1.1 Treatment Efficiency Report Summary - CASHEL WWTP

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)	Comment
<b>cBOD</b>	165324.16	2056.26	98.76	
<b>TP</b>	4064.58	176.65	95.65	
<b>SS</b>	263006.74	4091.66	98.44	
<b>COD</b>	418843.31	17816.93	95.75	
<b>TN</b>	28998.71	11134.81	61.6	

Note: The above data is based on sample results for the number of dates reported

#### 3.2 Treatment Capacity Report Summary

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

CASHEL WWTP	
<b>Peak Hydraulic Capacity (m3/day) - As Constructed</b>	6072

<b>DWF to the Treatment Plant (m3/day)</b>	2024
<b>Current Hydraulic Loading - annual max (m3/day)</b>	5206
<b>Average Hydraulic loading to the Treatment Plant (m3/day)</b>	1894
<b>Organic Capacity (PE) - As Constructed</b>	9000
<b>Organic Capacity (PE) - Collected Load (peak week)</b>	4938
<b>Organic Capacity (PE) - Remaining</b>	4062
<b>Will the capacity be exceeded in the next three years? (Yes/No)</b>	No

### 3.3 Complaints Summary

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
6	Blocked Sewer	0	6

### 3.4 Reported Incidents Summary

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.4.1 Summary of Incidents

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
There is no Incident data included in the AER.				

### 3.4.2 Summary of Overall Incidents

Question	Answer
Number of Incidents in 2018	0
Number of Incidents reported to the EPA via EDEN in 2018	0
Explanation of any discrepancies between the two numbers above	

### 3.5 Sludge / Other inputs to the WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)? <sup>3</sup>	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? <sup>2</sup> (Y/N)
Landfill Leachate (delivered by tanker)	3295	Volume (m3)		100	Yes	Yes	Yes

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 Storm Water Overflow Identification and Inspection Report

A summary of the operation of the storm water overflows and their significance where known is included below:

**No Appendix Included**

#### 4.1.1 SWO Identification

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2018 (No. of events)	Total volume discharged in 2018 (m3)	Monitoring Status
<b>SWO02</b>	206640, 140594	Yes	Low	Meeting			Not Monitored

#### 4.1.2 Inspection Summary Report

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	
Is each SWO identified as non meeting DoEHLG Guidance included in the Programme of Improvements?	Yes
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / charges to Schedule C3 and A4 under Condition 1.7?	No

## 4.2 Report on progress made and proposals being developed to meet the improvement programme requirements.

### 4.2.1 Specified Improvement Programme Summary

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>There are no Specified Improvement Programmes for this Agglomeration.</b>						

A summary of the status of any improvements identified by under Condition 5.2 is included below.

### 4.2.2 Improvement Programme Summary

Improvement Identifier	Improvement Description	Improvement Source	Expected Completion Date	Comments
<b>There are no Improvements Programme for this Agglomeration.</b>				

### 4.2.3 Sewer Integrity Risk Assessment

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table".

## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER (e.g. Appendix X).
<b>Drinking Water Abstraction Point Risk Assessment</b>	Yes	N/A	No	Will be completed for 2019 Reporting
<b>Priority Substances Assessment</b>	Yes	N/A	No	Will be completed for 2019 Reporting

## 6 CERTIFICATION AND SIGN OFF

### 6.1 Summary of AER Contents

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	
Is there a need to request/advise the EPA of any modifications to the existing WWDL?	No
List reason e.g. changes to monitoring requirements	
Have these processes commenced?	
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	No

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed:    Date: 29/03/2019

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Acting Head of Environmental Regulation.

## 7 APPENDIX

In the appendix include all the detailed or site specific reports that are relevant to the AER. Reports omitted from previous AERs should also be appended here.

### Appendix

#### Appendix 7.1 - Ambient monitoring summary

Cashel Ambient Monitoring Data 2018

Category	Entity	Station	Station Reference	Easting	Northing	Sample Refere	Sample Date	Analyst Conclu	Ammonia N	Biological Oxyg	COD Chemical	Dissolved Oxyg	Ortho-Phosph	pH	Temperature
									mg/l	mg/l	mg/l	mg/l	mg/l	pH units	Degrees C
Ambient Monitoring	River Suir	Upstream @ Cashel WWTP	RS16S021510	204077	141137	18550071	24/01/2018	-	0.03	2		9.6	0.03	7.8	8.1
Ambient Monitoring	River Suir	Downstream @ Cashel WWTP	RS16S021410	203992	140823	18550070	24/01/2018	-	0.05	2		9.46	0.03	7.7	8.6
Ambient Monitoring	River Suir	Upstream @ Cashel WWTP	RS16S021510	204077	141137	18550160	13/02/2018	-	0.06	5		11.2	0.03	8	4.3
Ambient Monitoring	River Suir	Downstream @ Cashel WWTP	RS16S021410	203992	140823	18550161	13/02/2018	-	0.09	5		11.6	0.03	7.9	3.5
Ambient Monitoring	River Suir	Upstream @ Cashel WWTP	RS16S021510	204077	141137	18550571	17/04/2018	-	0.3	2			0.1	7.4	
Ambient Monitoring	River Suir	Downstream @ Cashel WWTP	RS16S021410	203992	140823	18550572	17/04/2018	-	0.08	3			0.06	7.7	
Ambient Monitoring	River Suir	Upstream @ Cashel WWTP	RS16S021510	204077	141137	18550827	12/06/2018	-	0.04	2		8.87	0.02	8.3	
Ambient Monitoring	River Suir	Downstream @ Cashel WWTP	RS16S021410	203992	140823	18550828	12/06/2018	-	0.02	2		8.9	0.02	8.2	
Ambient Monitoring	River Suir	Upstream @ Cashel WWTP	RS16S021510	204077	141137	18550958	18/07/2018	-	0.01	1		10.7	0.007	8.3	18.9
Ambient Monitoring	River Suir	Downstream @ Cashel WWTP	RS16S021410	203992	140823	18550957	18/07/2018	-	0.02	1.7		9.95	0.061	8.2	19.2
Ambient Monitoring	River Suir	Upstream @ Cashel WWTP	RS16S021510	204077	141137	18551037	07/08/2018	-	0.07	2.4		17.4	0.029	8.2	9.48
Ambient Monitoring	River Suir	Downstream @ Cashel WWTP	RS16S021410	203992	140823	18551038	07/08/2018	-	0.08	2.994		9.71	0.114	8.2	17.9
Ambient Monitoring	River Suir	Upstream @ Cashel WWTP	RS16S021510	204077	141137	18551227	12/09/2018	-	0.02	3		9.91	0.07	8.33	14.7
Ambient Monitoring	River Suir	Downstream @ Cashel WWTP	RS16S021410	203992	140823	18551228	12/09/2018	-	0.04	2		8.7	0.1	8.32	13.9
Ambient Monitoring	River Suir	Upstream @ Cashel WWTP	RS16S021510	204077	141137	18551427	15/10/2018	-	0.02	2	5	8.73	0.15	7.94	11.3
Ambient Monitoring	River Suir	Downstream @ Cashel WWTP	RS16S021410	203992	140823	18551428	15/10/2018	-	0.02	2	5	8.79	0.24	7.83	11.7
Ambient Monitoring	River Suir	Upstream @ Cashel WWTP	RS16S021510	204077	141137	18551596	13/11/2018	-	0.051	0.6		10.06	0.096	7.9	7.5
Ambient Monitoring	River Suir	Downstream @ Cashel WWTP	RS16S021410	203992	140823	18551597	13/11/2018	-	0.026	1.2		9.52	0.077	8	8.6
Ambient Monitoring	River Suir	Upstream @ Cashel WWTP	RS16S021510	204077	141137	18551604	21/11/2018	-	0.26	0.1	40	11.12	0.064	7.9	7.1
Ambient Monitoring	River Suir	Downstream @ Cashel WWTP	RS16S021410	203992	140823	18551605	21/11/2018	-	0.23	0.1	36	10.48	0.047	7.9	9.2