

Annual Environmental Report

2018



Aughrim

D0222-01

TABLE OF CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2018 AER

- 1.1 LICENCE SPECIFIC REPORTING INCLUDED IN AER
- 1.2 TREATMENT TYPE
 - 1.2.1 AUGHRIM WWTP
- 1.3 ELV OVERVIEW
 - 1.3.1 AUGHRIM WWTP
- 1.4 SLUDGE REMOVAL

2 MONITORING REPORTS SUMMARY

- 2.1 SUMMARY REPORT ON MONTHLY INFLUENT MONITORING
 - 2.1.1 INFLUENT MONITORING SUMMARY - AUGHRIM WWTP
- 2.2 DISCHARGES FROM THE AGGLOMERATION
 - 2.2.1 EFFLUENT MONITORING SUMMARY - AUGHRIM WWTP
- 2.3 AMBIENT MONITORING SUMMARY
 - 2.3.1 AMBIENT MONITORING REPORT SUMMARY - AUGHRIM WWTP
 - 2.3.2 AMBIENT MONITORING PARAMETER MEAN (MG/L) - AUGHRIM WWTP

3 OPERATIONAL REPORTS SUMMARY

- 3.1 TREATMENT EFFICIENCY REPORT
 - 3.1.1 TREATMENT EFFICIENCY REPORT SUMMARY - AUGHRIM WWTP
- 3.2 TREATMENT CAPACITY REPORT SUMMARY
- 3.3 COMPLAINTS SUMMARY
- 3.4 REPORTED INCIDENTS SUMMARY
 - 3.4.1 SUMMARY OF INCIDENTS
 - 3.4.2 SUMMARY OF OVERALL INCIDENTS
- 3.5 SLUDGE / OTHER INPUTS TO THE WWTP

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION
 - 4.1.2 INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

4.2.3 SEWER INTEGRITY RISK ASSESSMENT SUMMARY

5 LICENCE SPECIFIC REPORTS

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

6.2 DECLARATION BY IRISH WATER

7 APPENDIX

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2018 AER

This Annual Environmental Report has been prepared for D0222-01, Aughrim, in Wicklow in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports are included as an appendix to the AER as follows:

1.1 Licence specific reporting included in AER

Assessment / Report	Included in AER
There is no Licence Specific Reports included in the AER.	

1.2 Treatment Type

The agglomeration is served by a wastewater treatment plant AUGHRIM WWTP with a Plant Capacity PE of 1500. The treatment process includes the following:

1.2.1 AUGHRIM WWTP

Treatment type	Yes / No	Details
Preliminary Treatment	Yes	Coarse and Fine Screening
Primary Treatment	No	
Secondary Treatment	Yes	Extended Aeration SBR
Nutrient Removal	No	
Tertiary Treatment	No	

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.2 Discharges from the agglomeration.

1.3 ELV Overview

1.3.1 AUGHRIM WWTP

Compliance Status	
Were all parameters compliant for AUGHRIM WWTP treatment plant	No
Where non compliant see Table 2.2.1 for details of parameters	

1.4 Sludge Removal

The amount of sludge removed from the wastewater treatment plant is shown below along with the transported destination of the sludge from the treatment plant.

Treatment Plant	Sludge type	Quantity	Unit	% Dry Solids	Destination
AUGHRIM WWTP	Liquid Sludge	558	Volume (m ³)	1.2	Enniskerry
AUGHRIM WWTP	Liquid Sludge	198	Volume (m ³)	1.2	Wicklow
AUGHRIM WWTP	Liquid Sludge	144	Volume (m ³)	1.2	Athy

Annual Statement of Measures

The Sequence Batch Process (SBR) in Aughrim is a batch process. The stages in the process are Fill, Aeration, Settlement, Decant and Sludge transfer. The operational time in each stage was reduced to enable the SBR to take more influent forward for treatment and this has been a success. The effluent discharge pipe was also enlarged to reduce the decant time.

2 MONITORING REPORTS SUMMARY

2.1 Summary report on monthly influent monitoring

A summary of influent monitoring for the treatment plant is presented in below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

2.1.1 Influent Monitoring Summary - AUGHRIM WWTP

Parameters	Number of Samples	Annual Max	Annual Mean
COD-Cr	10	1160	304.92
Total Phosphorus (as P)	10	13.4	5.03
Total Nitrogen	10	92.4	32.32
BOD, 5 days with Inhibition (Carbonaceous BOD)	10	608	154.56
Suspended Solids	10	572	105.34
Hydraulic Capacity		1481	550.26

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 3.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity as detailed further in Section 3.2. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity as detailed further in Section 3.2.

2.2 Discharges from the agglomeration

2.2.1 Effluent Monitoring Summary - AUGHRIM WWTP

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included ^{Note 1}	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Nitrite (as N)	0	0	0	9	0	0	0.06	N/A
ortho-Phosphate (as P) - unspecified	5	6	0	9	1	0	1.13	Pass
COD-Cr	125	250	0	9	0	0	40.97	Pass
Suspended Solids	25	62.5	0	9	1	0	11.22	Pass
Temperature	0	0	0	3	0	0	5.14	N/A
Ammonia-Total (as N)	5	6	0	9	6	6	10.77	Fail
Nitrate (as N)	0	0	0	9	0	0	1.61	N/A
pH	6 to 9	6 to 9	0	9	0	0	6.98	Pass
BOD, 5 days with Inhibition (Carbonaceous BOD)	25	50	0	9	2	0	14.8	Pass
Total Phosphorus (as P)	0	0	0	9	0	0	1.45	N/A

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included ^{Note 1}	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Total Nitrogen	0	0	0	9	0	0	14.15	N/A

Notes:

1- This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

Cause of Exceedance(s):

WWTP not designed for N removal.

Significance of Results:

The WWTP was not compliant with the ELV's set in the Wastewater Discharge Licence. Six samples exceeded the Condition 2 Ammonia ELV. The impact on receiving waters is assessed further in Section 2.3.

2.3 Ambient monitoring summary

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

2.3.1 Ambient Monitoring Report Summary - AUGHRIM WWTP

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	313194, 179477	TPEFF3400D0222SW001	No	No	No	No	Moderate
Downstream	313228, 179470	TPEFF3400D0222SW001	No	No	No	No	Moderate

2.3.2 Ambient Monitoring Parameter Summary - AUGHRIM WWTP

The table below provides a summary of monitoring results for designated ambient monitoring points. The upstream and downstream annual mean values are shown (mg/l), and the difference between both monitoring stations is given as a percentage of the Environmental Quality Standard (EQS) where relevant.

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
ortho-Phosphate (as P) - unspecified	RS10A020130	0.01	RS10A020140	0.01	0.075	-0.3
Temperature	RS10A020130	10.18	RS10A020140	10.2		
Dissolved Oxygen	RS10A020130	56.83	RS10A020140	57.06		
Total Oxidised Nitrogen (as N)	RS10A020130	1.37	RS10A020140	1.4		
Nitrite (as N)	RS10A020130	0.02	RS10A020140	0.02		
pH	RS10A020130	7.14	RS10A020140	7.19		
BOD - 5 days (Total)	RS10A020130	1.28	RS10A020140	2.15	2.6	33.7
Ammonia-Total (as N)	RS10A020130	0.06	RS10A020140	0.04	0.15	-9.3
Conductivity 20 C	RS10A020130	106.25	RS10A020140	103.25		

Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results meet the required EQS. Where the ambient monitoring results meet the EQS this relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

An increase in BOD was noted d/s of the WWTP plant, however the plant was compliant with its BOD ELV. It is also noted that the EQS for BOD was met d/s of the WWTP discharge.

Based on the ambient monitoring results for 2018, the discharge from the wastewater treatment plant does appear to be having an observable negative impact on the water quality.

The discharge from the WWTP has no observable negative impact on the Water Framework Directive status.

It is noted that consistent achievement with the ELVs would benefit the quality of the receiving water.

3 OPERATIONAL REPORTS SUMMARY

3.1 Treatment Efficiency Report

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

3.1.1 Treatment Efficiency Report Summary - AUGHRIM WWTP

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
SS	19566.08	2219.36	88.66
cBOD	28708.53	2927.5	89.8
TN	6002.56	2799.67	53.36
TP	933.75	287.26	69.24
COD	56638.55	8102.57	85.69

Note: The above data is based on sample results for the number of dates reported

3.2 Treatment Capacity Report Summary

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

AUGHRIM WWTP	
Peak Hydraulic Capacity (m ³ /day) - As Constructed	810
DWF to the Treatment Plant (m ³ /day)	270
Current Hydraulic Loading - annual max (m ³ /day)	1481
Average Hydraulic loading to the Treatment Plant (m ³ /day)	550.26
Organic Capacity (PE) - As Constructed	1500
Organic Capacity (PE) - Collected Load (peak week)	1782
Organic Capacity (PE) - Remaining	0
Will the capacity be exceeded in the next three years? (Yes/No)	Yes

3.3 Complaints Summary

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
2	Blocked Sewer	0	2

3.4 Reported Incidents Summary

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.4.1 Summary of Incidents

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Non-compliance	WWTP not designed for N removal	1	Yes	No
Other	Other	1	No	Yes
Uncontrolled release	Plant or equipment breakdown at WWTP	1	No	Yes

3.4.2 Summary of Overall Incidents

Question	Answer
Number of Incidents in 2018	3
Number of Incidents reported to the EPA via EDEN in 2018	3
Explanation of any discrepancies between the two numbers above	N/A

3.5 Sludge / Other inputs to the WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP?(Y/N)
Domestic /Septic Tank Sludge	36	Volume (m ³)	0.4	0.02	Yes	Yes	No
Domestic /Septic Tank Sludge	18	Volume (m ³)	0.2	0.01	Yes	Yes	No

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 Storm Water Overflow Identification and Inspection Report

A summary of the operation of the storm water overflows and their significance where known is included below:

No Appendix Included.

4.1.1 SWO Identification

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2018 (No. of events)	Total volume discharged in 2018 (m ³)	Monitoring Status
SW003	313159, 179473	Yes	Low	Not Meeting	1189	10289.4	Monitored

4.1.2 Inspection Summary Report

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m ³)?	10,289.4
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	No
The SWO Assessment included the requirements of relevant of WWDL schedules?	No
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	No

4.2 Report on progress made and proposals being developed to meet the improvement programme requirements.

4.2.1 Specified Improvement Programme Summary

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
Cease the discharge of partially treated waste water from the primary settlement tank at the WWTP.	C	31/12/2017	Yes	Works Completed		
Relocate the emergency overflow associated with Roddenagh Road pumping station from Aughrim fishing lake to the Aughrim River	C	30/07/2015	Yes	Work ongoing on-site		This specified improvement and expected completion date is currently under review by Irish Water.
Secondary Discharge Point to be discontinued	C	31/12/2017	Yes	Work ongoing on-site		This specified improvement and expected completion date is currently under review by Irish Water.
Upgrade Aughrim WWTP to provide sufficient treatment capacity to cater for the volume of waste water arising in the agglomeration	C	31/12/2017	Yes	Works Completed		

A summary of the status of any improvements identified by under Condition 5.2 is included below.

4.2.2 Improvement Programme Summary

Improvement Identifier	Improvement Description	Improvement Source	Expected Completion Date	Comments
There are no Improvements Programme for this Agglomeration.				

4.2.3 Sewer Integrity Risk Assessment

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
Priority Substances Assessment	Yes	2014	No	

6 CERTIFICATION AND SIGN OFF

6.1 Summary of AER Contents

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modifications to the existing WWDL?	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Date: 21/03/2019

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of,

Eleanor Roche

Acting Head of Environmental Regulation.

7 APPENDIX

There are no Appendices included.