

Annual Environmental Report

2018



Borrisokane

D0326-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2018 AER

1.1 TREATMENT SUMMARY

1.1.1 BORRISOKANE WWTP

1.2 ELV OVERVIEW

1.3 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMAND AND IMPACT SUMMARY

2.1 BORRISOKANE WWTP - TREATED DISCHARGE

2.1.1 INFLUENT SUMMARY - BORRISOKANE WWTP

2.1.2 EFFLUENT MONITORING SUMMARY - BORRISOKANE WWTP -

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -

2.1.4 OPERATIONAL REPORTS SUMMARY FOR BORRISOKANE WWTP

2.1.5 SLUDGE/OTHER INPUTS TO BORRISOKANE WWTP

2.1.6 SLUDGE REMOVAL BORRISOKANE WWTP

3 COMPLAINTS SUMMARY

3.1 REPORTED INCIDENTS SUMMARY

3.1.1 SUMMARY OF INCIDENTS

3.1.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

7.1 AMBIENT MONITORING SUMMARY

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2018 AER

This Annual Environmental Report has been prepared for D0326-01, Borrisokane, in Tipperary in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Borrisokane WWTP with a Plant Capacity PE of 1500

The treatment process includes the following:

1.1.1 BORRISOKANE WWTP

Treatment type	Yes / No	Details
Preliminary Treatment	Yes	Automatic Screening
Primary Treatment	No	
Secondary Treatment	Yes	Conventional Activated Sludge
Nutrient Removal	Yes	Chemical dosing for Phosphorus Removal
Tertiary Treatment	No	

1.2 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF2800D0326SW001	Borrisokane WWTP	Treated	Non-Compliant	Shock load to the WWTP

1.3 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
There is no Licence Specific Reports included in the AER.	

2 TREATMENT PLANT PERFORMAND AND IMPACT SUMMARY

2.1 BORRISOKANE WWTP - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - BORRISOKANE WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Suspended Solids mg/l	6	828	422.07
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	6	446	270.19
COD-Cr mg/l	6	1038	612.47
Hydraulic Capacity	N/A	1583	337.6

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF2800D0326SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	0	6	0	0	26.27	Pass
Suspended Solids mg/l	35	87.5	0	6	0	0	11.85	Pass
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	12	24	0	6	0	0	5.52	Pass
Ammonia-Total (as N) mg/l	5	6	0	6	1	1	2.07	Fail
ortho-Phosphate (as P) - unspecified mg/l	2	2.4	0	6	0	0	0.89	Pass
Total Oxidised Nitrogen (as N) mg/l	0	0	0	6	0	0	5.44	
Nitrite (as N) mg/l	0	0	0	6	0	0	0.15	
Nitrate (as N) mg/l	0	0	0	6	0	0	5.28	
pH pH units	0	0	0	6	0	0	7.85	
Temperature °C	0	0	0	1	0	0	18	

Notes:

1- This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 - For parameters where a mean ELV applies

Cause of Exceedance(s):

Shock load to the WWTP

Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	191048, 194172	TPEFF2800D0326SW001	No	No	No	No	Moderate
Downstream	190896, 194074	TPEFF2800D0326SW001	No	No	No	No	Moderate

The results for ambient results and / or additional monitoring data sets are included in the **Appendix IW.Eims.AERReportPortal.Models.AppendixModel**

Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results meet the required EQS.

The discharge from the wastewater treatment plant do not have an observable impact on the water quality.

The discharge from the wastewater treatment plant do not have an observable negative impact on the Water Framework Directive status.

Other Potential cause of deterioration in water quality relevant to this area are: The EQS assessed relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009, as amended.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY

2.1.4.1 Treatment Efficiency Report

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)	Comment
TP				
COD	0	2052.03	95.71	
SS	0	925.25	97.19	
cBOD	0	431.49	97.96	
TN				

Note: The above data is based on sample results for the number of dates reported

2.1.4.2 Treatment Capacity Report Summary

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Borrisokane WWTP	
Peak Hydraulic Capacity (m3/day) - As Constructed	1080

Borrisokane WWTP	
DWF to the Treatment Plant (m3/day)	360
Current Hydraulic Loading - annual max (m3/day)	1583
Average Hydraulic loading to the Treatment Plant (m3/day)	337.6
Organic Capacity (PE) - As Constructed	1500
Organic Capacity (PE) - Collected Load (peak week)	1325
Organic Capacity (PE) - Remaining	175
Will the capacity be exceeded in the next three years? (Yes/No)	No

2.1.5 SLUDGE / OTHER INPUTS

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

2.1.6 SLUDGE REMOVAL

The amount of sludge removed from the wastewater treatment plant is shown below along with the transported destination of the sludge from the treatment plant.

Treatment Plant	Sludge type	Quantity	Unit	% Dry Solids	Destination
Borrisokane WWTP	Liquid Sludge	427.5	Weight (Tonnes)	4	Bunlicky WWTP D0013-01
Borrisokane WWTP	Liquid Sludge	1009	Weight (Tonnes)	4	Nenagh WWTP

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
2	Blocked Sewer	0	2

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Non-compliance	Shock load to WWTP	1	No	No
Non-compliance	Shock load to WWTP	1	No	Yes

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2018	2
Number of Incidents reported to the EPA via EDEN in 2018	2
Explanation of any discrepancies between the two numbers above	

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2018 (No. of events)	Total volume discharged in 2018 (m3)	Monitoring Status
There are no Storm Water Overflows in this Agglomeration.							

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	No
The SWO Assessment included the requirements of relevant of WWDL schedules?	No
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	No

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0326-SIP:01	Implementation of the measures identified in Condition 5.1(f) as specified in Condition 5.4	C	31/12/2019	No	Works Completed		
D0326-SIP:02	Installation of primary screening	C	31/12/2019	No	Works Completed		
D0326-SIP:03	Installation of storm water holding tank	C	31/12/2019	No	Not Started		The improvement programme will be reviewed by IW to assess the works required to comply with the licence condition on a prioritized basis.

A summary of the status of any improvements identified by under Condition 5.2 is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description	Improvement Source	Expected Completion Date	Comments
There are no Improvements Programme for this Agglomeration.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
There is no Licence Specific Report Required in this AER Annual Review.				

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	
Is there a need to request/advise the EPA of any modifications to the existing WWDL?	No
List reason e.g. changes to monitoring requirements	
Have these processes commenced?	
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	No

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 29/04/2019

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Acting Head of Environmental Regulation.

7 APPENDIX

Appendix
Appendix 7.1 - Ambient monitoring summary

borrisokane upstream 2018

borrisokane upstream 2018								Parameter	Ammonia N	BOD	D.O.	D.O. % Saturation	Ortho-Phosphate P	pH	Temperature	Total Nitrogen N
Category	River	Station	Station Refere	Easting	Northing	Sample Reference	Sample Date	Analyst Conclusion	mg/l	mg/l	mg/l	% O2	mg/l	pH units	Degrees C	mg/l
Ambient Monitoring	Ballyfinboy	Upstream @ Borrisokane WWTP	RS25B020570	191048	194172	1855WW0059	8-Feb-2018	-	0.036	1.7	10.98	92	0.02	8.02	7.4	4.1
Ambient Monitoring	Ballyfinboy	Upstream @ Borrisokane WWTP	RS25B020570	191048	194172	1855WW0263	14-June-2018	-	0.021	1.5	10.21	100.2	0.013	8.05	14	3.5
Ambient Monitoring	Ballyfinboy	Upstream @ Borrisokane WWTP	RS25B020570	191048	194172	1855WW0358	2-Aug-2018	-	0.038	3.8	8.89	93	0.019	8.1	17.2	3
Ambient Monitoring	Ballyfinboy	Upstream @ Borrisokane WWTP	RS25B020570	191048	194172	1855WW0568	6-Dec-2018	-	0.019	1.6	9.8	88	0.019	7.96	10.2	6.6

borrisokane downstream 2018

borrisokane downstream 2018								Parameter	Ammonia N	BOD	D.O.	D.O. % Saturation	Ortho-Phosphate P	pH	Temperature	Total Nitrogen N
Category	River	Station	Station Refere	Easting	Northing	Sample Reference	Sample Date	Analyst Conclusion	mg/l	mg/l	mg/l	% O2	mg/l	pH units	Degrees C	mg/l
Ambient Monitoring	Ballyfinboy	Downstream @ Borrisokane WWTP	RS25B020580	190897	194075	1855WW0060	8-Feb-2018	-	0.048	1.8	10.97	92.6	0.02	8.04	7.7	4.4
Ambient Monitoring	Ballyfinboy	Downstream @ Borrisokane WWTP	RS25B020580	190897	194075	1855WW0264	14-June-2018	-	0.053	1.3	9.86	97.9	0.014	7.98	14.4	3.5
Ambient Monitoring	Ballyfinboy	Downstream @ Borrisokane WWTP	RS25B020580	190897	194075	1855WW0359	2-Aug-2018	-	0.073	3	8.73	89.3	0.093	8.06	16.4	3.3
Ambient Monitoring	Ballyfinboy	Downstream @ Borrisokane WWTP	RS25B020580	190897	194075	1855WW0569	6-Dec-2018	-	0.021	1.6	10.03	90.3	0.021	7.97	10.4	6.5