

# Annual Environmental Report

2019



Lehinch

D0080-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2019 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 LAHINCH WWTP - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - LAHINCH WWTP
  - 2.1.2 EFFLUENT MONITORING SUMMARY - LAHINCH WWTP -
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR LAHINCH WWTP
  - 2.1.5 SLUDGE/OTHER INPUTS TO LAHINCH WWTP

### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

### **7 APPENDIX**

- 7.1 AMBIENT MONITORING SUMMARY

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2019 AER

This Annual Environmental Report has been prepared for D0080-01, Lehinch, in Clare in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- LAHINCH WWTP with a Plant Capacity PE of 8400, the treatment type is 2 - Secondary treatment

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF0300D0080SW001	LAHINCH WWTP	Treated	Non-Compliant	Ammonia-Total (as N) mg/l BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l COD-Cr mg/l Suspended Solids mg/l Total Oxidised Nitrogen (as N) mg/l Total Phosphorus (as P) mg/l

## 1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
There are no Licence Specific Reports included in the AER.	

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 LAHINCH WWTP - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - LAHINCH WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Total Phosphorus (as P) mg/l	12	13.6	4.22
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	12	428	149.44
Total Nitrogen mg/l	12	50	21.29
COD-Cr mg/l	12	1242	379.51
Suspended Solids mg/l	12	784	195.05
Hydraulic Capacity	N/A	1441	647

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

#### Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

## 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF0300D0080SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>COD-Cr mg/l</b>	125	250	N/A	12	3	2	282.34	Fail
<b>Suspended Solids mg/l</b>	35	87.5	N/A	12	8	4	266.97	Fail
<b>BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l</b>	25	50	N/A	12	6	2	82.3	Fail
<b>Temperature °C</b>	25	N/A	N/A	8	N/A	N/A	12.55	Pass
<b>Total Oxidised Nitrogen (as N) mg/l</b>	15	18	N/A	12	2	2	4.7	Fail
<b>Ammonia-Total (as N) mg/l</b>	10	12	N/A	12	3	2	10.57	Fail
<b>pH pH units</b>	9	9	N/A	12	N/A	N/A	6.8	Pass
<b>Total Phosphorus (as P) mg/l</b>	2	2.4	N/A	12	7	6	5.08	Fail
<b>Faecal coliforms no./100mls</b>	N/A	N/A	N/A	2	N/A	N/A	N/A	
<b>Total Nitrogen mg/l</b>	N/A	N/A	N/A	12	N/A	N/A	15.55	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>Conductivity @25°C µS/cm</b>	N/A	N/A	N/A	12	N/A	N/A	595.94	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

### Cause of Exceedance(s):

**Inadequate infrastructure**

### Significance of Results:

The WWTP was non-compliant with the ELVs set in the wastewater discharge licence. There were exceedances in relation to COD, 8 exceedances in relation to Suspended Solids, 6 in relation to BOD, 2 in relation to TON, 3 in relation to Ammonia and 7 in relation to Total Phosphorus.

## 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF0300D0080SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
<b>Downstream</b>	109150, 189327	RS28I010600	No	No	No	No	Unassigned

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**. No upstream monitoring data is available.

### Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - LAHINCH WWTP

### 2.1.4.1 Treatment Efficiency Report - LAHINCH WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
<b>COD</b>	84809	63096	26
<b>SS</b>	43588	59661	0%
<b>cBOD</b>	33396	18392	45

Note: The above data is based on sample results for the number of dates reported

### 2.1.4.2 Treatment Capacity Report Summary - LAHINCH WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

LAHINCH WWTP	
<b>Peak Hydraulic Capacity (m<sup>3</sup>/day) - As Constructed</b>	2034
<b>DWF to the Treatment Plant (m<sup>3</sup>/day)</b>	678
<b>Current Hydraulic Loading - annual max (m<sup>3</sup>/day)</b>	1441
<b>Average Hydraulic loading to the Treatment Plant (m<sup>3</sup>/day)</b>	647
<b>Organic Capacity (PE) - As Constructed</b>	8400
<b>Organic Capacity (PE) - Collected Load (peak week)<sup>Note1</sup></b>	3045
<b>Organic Capacity (PE) - Remaining</b>	5355
<b>Will the capacity be exceeded in the next three years? (Yes/No)</b>	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

### 2.1.5 SLUDGE / OTHER INPUTS - LAHINCH WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
<b>There is no Sludge and Other Input data for the Treatment Plant included in the AER.</b>							

## 3 COMPLAINTS AND INCIDENTS

### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
1	Blocked Sewer	1	0

### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Breach of ELV	WWTP upgrade required to meet ELV	1	Yes	No

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2019	1
Number of Incidents reported to the EPA via EDEN in 2019	1
Explanation of any discrepancies between the two numbers above	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2019 (No. of events)	Total volume discharged in 2019 (m3)	Monitoring Status
TBC	110244, 188237	No	Unknown	Meeting	Unknown	Unknown	Not Monitored
TBC	TBC	No	Unknown	Meeting	Unknown	Unknown	Not Monitored
TBC	TBC	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
TBC	TBC	No	Unknown	Not yet Assessed	Unknown	Unknown	Unknown

#### SWO Summary

How much sewage was discharged via SWOs in the agglomeration in the year (m3)?

Unknown

Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	N/A
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	No

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>There are no Specified Improvement Programmes for this Agglomeration.</b>							

A summary of the status of any improvements identified by under Condition 5.2 is included below.

## 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
-	WWTP upgrade required. At Assessment and planning stage - Conceptual design progressing	other	25/01/2024	N/A

## 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.

## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

### 5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
<b>There is no Licence Specific Report Required in this AER Annual Review.</b>				

## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	Yes
List reason e.g. changes to monitoring requirements	Change to Ambient monitoring locations: Upstream & Downstream
Have these processes commenced?	No
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	No

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed:    Date: 22/04/2020

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Katherine Walshe

Acting Head of Environmental Regulation.

## 7 APPENDIX

Appendix

**Appendix 7.1 - Ambient monitoring summary**

Parameter	Ammonia N	Dissolved Oxygen % Saturation	Dissolved Oxygen	Temperature	Total Nitrogen N	Biological Oxygen Demand	Ortho-Phosphate P	pH	Visual Inspection
Max.	--	120	--	--	--	--	--	9	--
Min.	--	80	--	--	--	--	--	6	--
Test Method	--	--	--	--	--	--	--	--	--

Station	Laboratory	Station Reference	Sample Reference	Sample Date	Comments	Analyst	Conclusion	mg/l	% O2	mg/l	Degrees C	mg/l	mg/l	mg/l	pH units	Descriptive
O'Briens Bridge	Clare Co Co New Rd	RS28I010600	19-0363	28-Feb-2019	-	-	-	0.11	96.5	10.37	9.2	1.2	< 2	0.013	7.77	Clear
O'Briens Bridge	Clare Co Co New Rd	RS28I010600	19-1148	19-June-2019	-	-	-	0.478	96	8.49	21.3	0.3	< 2	< 0.01	8.19	Clear
O'Briens Bridge	Clare Co Co New Rd	RS28I010600	19-1740	11-Sep-2019	-	-	-	< 0.02	95.1	9.49	15.8	1	< 2	0.018	8.1	Clear
O'Briens Bridge	Clare Co Co New Rd	RS28I010600	19-2348	11-Dec-2019	-	-	-	< 0.02	94.8	11.28	7.4	0.8	< 2	0.018	7.42	Clear

D0080-01

Lahinch

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish National Grid Reference (Easting, Northing)	EPA Feature Coding Tool code	Receiving Waters Designation (Yes/No)				Current WFD Status	Mean (mg/l)		
			Bathing Water	Drinking Water	FWPM	Shellfish		cBOD	o-Phosphate (as P)	Ammonia (as N)
Upstream Monitoring Point							Moderate	2.000	0.038	0.030
Downstream Monitoring Point	109148, 189333	RS28I010600	No	No	No	No	Moderate	2.000	0.015	0.157
<i>Difference</i>								0.000	-0.023	0.127
EQS								2.600	0.075	0.140
% of EQS								0.000%	-30.000%	90.714%

Surrogate DS Location