

Annual Environmental Report

2019



Enfield

D0131-01

CONTENTS

- 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2019 AER**
 - 1.1 ANNUAL STATEMENT OF MEASURES
 - 1.2 TREATMENT SUMMARY
 - 1.3 ELV OVERVIEW
 - 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER
- 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**
 - 2.1 ENFIELD WWTP - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - ENFIELD WWTP
 - 2.1.2 EFFLUENT MONITORING SUMMARY - ENFIELD WWTP
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR ENFIELD WWTP
 - 2.1.5 SLUDGE/OTHER INPUTS TO ENFIELD WWTP
- 3 COMPLAINTS AND INCIDENTS**
 - 3.1 COMPLAINTS SUMMARY
 - 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS
- 4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**
 - 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
 - 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT
- 5 LICENCE SPECIFIC REPORTS**
 - 5.1 PRIORITY SUBSTANCES ASSESSMENT
- 6 CERTIFICATION AND SIGN OFF**
 - 6.1 SUMMARY OF AER CONTENTS
- 7 APPENDIX**

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2019 AER

This Annual Environmental Report has been prepared for D0131-01, Enfield, in Meath in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Enfield WWTP with a Plant Capacity PE of 3500, the treatment type is 3P - Tertiary P removal

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF2300D0131SW001	Enfield WWTP	Treated	Non-Compliant	ortho-Phosphate (as P) - unspecified mg/l Suspended Solids mg/l Total Phosphorus (as P) mg/l

1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
There are no Licence Specific Reports included in the AER.	

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 ENFIELD WWTP - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - ENFIELD WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	12	673	328.07
Total Nitrogen mg/l	12	65	45.21
Total Phosphorus (as P) mg/l	12	12.3	6.74
COD-Cr mg/l	12	1509	677.27
Suspended Solids mg/l	12	966	275.12
Hydraulic Capacity	N/A	4425	1718

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF2300D0131SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	12	N/A	N/A	40.07	Pass
Suspended Solids mg/l	30	75	N/A	12	3	N/A	20.06	Fail
Temperature °C	25	N/A	N/A	2	N/A	N/A	11.46	Pass
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	20	40	N/A	12	2	N/A	12.95	Pass
pH pH units	9	9	N/A	1	N/A	N/A	6.4	Pass
Ammonia-Total (as N) mg/l	3	3.6	N/A	12	N/A	N/A	0.19	Pass
ortho-Phosphate (as P) - unspecified mg/l	N/A	N/A	N/A	12	N/A	N/A	0.34	
Total Phosphorus (as P) mg/l	0.5	0.6	N/A	12	6	4	0.5	Fail
Total Nitrogen mg/l	N/A	N/A	N/A	12	N/A	N/A	18.29	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

Cause of Exceedance(s):

The ferric dosing location was in a non-effective location, this was changed in September 2019 to an optimum location for ferric dosing. This should improve the overall compliance for Total Phosphorus in the future. The TSS non-compliances were likely due to the WWTP operating above capacity.

Significance of Results:

The WWTP is non-compliant with the ELV's set in the Wastewater Discharge Licence. The impact on receiving waters is assessed further in Section 2.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF2300D0131SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	276618, 239946	RS07B020100	No	No	No	No	Moderate
Downstream	275982, 240339	RS07B020120	No	No	No	No	Unassigned

The table below provides a summary of monitoring results for designated ambient monitoring points. The upstream and downstream annual mean values are shown (mg/l), and the difference between both monitoring stations is given as a percentage of the Environmental Quality Standard (EQS) where relevant.

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
BOD - 5 days (Total) mg/l	RS07B020100	1.31	RS07B020120	1.255	1.5	-3.7
Ammonia-Total (as N) mg/l	RS07B020100	0.061	RS07B020120	0.055	0.065	-9.6
ortho-Phosphate (as P) - unspecified mg/l	RS07B020100	0.051	RS07B020120	0.047	0.035	-13.2
Dissolved Oxygen % Saturation	RS07B020100	91.63	RS07B020120	97.5		
Alkalinity-total (as CaCO3) mg/l	RS07B020100	274.25	RS07B020120			
Dissolved Oxygen mg/l	RS07B020100	9.5	RS07B020120	9.96		
Total Hardness (as CaCO3) mg/l	RS07B020100	346.75	RS07B020120			
True Colour mg/litre Pt Co	RS07B020100	84.5	RS07B020120			
pH pH units	RS07B020100	7.67	RS07B020120	7.58		
Temperature °C	RS07B020100	11.18	RS07B020120			
Conductivity @25°C µS/cm	RS07B020100	673.25	RS07B020120			
Total Oxidised Nitrogen (as N) mg/l	RS07B020100	2.73	RS07B020120			

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
Nitrate (as N) mg/l	RS07B020100	2.68	RS07B020120			
Chloride mg/l	RS07B020100	23.43	RS07B020120			
Total Nitrogen mg/l	RS07B020100	3.03	RS07B020120	3.29		
Nitrite (as N) µg/l	RS07B020100	20.5	RS07B020120			

Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results does not meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

The WFD status d/s of the discharge is Unassigned. Therefore it is unknown if the discharge from the wastewater treatment plant is having an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - ENFIELD WWTP

2.1.4.1 Treatment Efficiency Report - Enfield WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
TP	4349	324	93
SS	177582	12946	93
cBOD	211757	8358	96
TN	29180	11805	60
COD	437158	25864	94

Note: The above data is based on sample results for the number of dates reported

2.1.4.2 Treatment Capacity Report Summary - Enfield WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Enfield WWTP	
Peak Hydraulic Capacity (m ³ /day) - As Constructed	2363
DWF to the Treatment Plant (m ³ /day)	787
Current Hydraulic Loading - annual max (m ³ /day)	4425
Average Hydraulic loading to the Treatment Plant (m ³ /day)	1718
Organic Capacity (PE) - As Constructed	3500
Organic Capacity (PE) - Collected Load (peak week) ^{Note¹}	4690
Organic Capacity (PE) - Remaining	0
Will the capacity be exceeded in the next three years? (Yes/No)	Yes

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - ENFIELD WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
7	Blocked Sewer	0	7

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Breach of ELV	Dosing pump failure or maintenance at WWTP	1	No	Yes
Uncontrolled release	EO caused by pump failure	1	No	Yes
Breach of ELV	Inadequate Infrastructure	1	Yes	Yes

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Uncontrolled release	Plant or equipment breakdown at WWTP	1	No	Yes
Abatement Equipment offline	Plant or equipment breakdown at WWTP	1	No	Yes
Breach of ELV	WWTP operating above capacity	1	No	Yes
Uncontrolled release	Adverse Weather	1	No	Yes

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2019	7
Number of Incidents reported to the EPA via EDEN in 2019	7
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2019 (No. of events)	Total volume discharged in 2019 (m3)	Monitoring Status
TBC	TBC	No	Low	Not yet Assessed	Unknown	Unknown	Not Monitored
SW2	276344, 240094	Yes	Low	Meeting	Unknown	Unknown	Monitored

SWO Summary

How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	No
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0131-SIP:01	Reduction of TP conc. of primary discharge to 0.5mg/l	C	01/01/2011	Yes	Works Completed		

A summary of the status of any improvements identified by under Condition 5.2 is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
D0131-IP:8	Ferric dosing point changed by MCC to optimal dosing location to improve P removal efficiency.	Incident Reduction	25/09/2019	These works are completed and included the upgrade of existing pipework. The dosing points were changed to the aeration tank outlets, this has improved P removal efficiency.
D0131-IP:9	Johnstown Road PS received an upgrade with included a new electrical panel, VSD and HDMI for PS control.	Improved Operational Control	30/01/2019	Works were completed in 2019.

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
Priority Substances Assessment	Yes	2014	No	

5.1 PRIORITY SUBSTANCES ASSESSMENT

The Priority Substances Assessment Report has been included in the AER 2014.

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	Yes
List reason e.g. changes to monitoring requirements	Downstream sampling location is 2.5km away which is not representative of the impact on the water body.
Have these processes commenced?	No
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Date: 05/03/2020

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of,

Katherine Walshe

Acting Head of Environmental Regulation.

7 APPENDIX

There are no Appendices included.