

# Annual Environmental Report

2020



Campile

D0409-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 CAMPILE WWTP - 2020 - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - CAMPILE WWTP - 2020
  - 2.1.2 EFFLUENT MONITORING SUMMARY - CAMPILE WWTP - 2020 -
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR CAMPILE WWTP - 2020
  - 2.1.5 SLUDGE/OTHER INPUTS TO CAMPILE WWTP - 2020

### **3 COMPLAINTS SUMMARY**

- 3.1 REPORTED INCIDENTS SUMMARY
  - 3.1.1 SUMMARY OF INCIDENTS
  - 3.1.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

- 5.1 PRIORITY SUBSTANCES ASSESSMENT
- 5.2 SHELLFISH IMPACT ASSESSMENT

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

### **7 APPENDIX**

## 7.1 AMBIENT MONITORING SUMMARY

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

This Annual Environmental Report has been prepared for D0409-01, Campile, in Wexford in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There were no significant changes or operation improvements in 2020 and no additional process improvements are possible pending upgrade. There are currently no envisaged or planned works in the next 3 years.

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- CAMPILE WWTP - 2020 with a Plant Capacity PE of 150, the treatment type is 1 - Primary treatment

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
<b>TPEFF3300D0409SW001</b>	CAMPILE WWTP - 2020	Treated	Non-Compliant	BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l Suspended Solids mg/l

## 1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
<b>There are no Licence Specific Reports included in the AER.</b>	

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 CAMPILE WWTP - 2020 - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - CAMPILE WWTP - 2020

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
COD-Cr mg/l	6	1491	442.5
Total Phosphorus (as P) mg/l	6	9.33	4.86
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	6	697	235.5
Suspended Solids mg/l	6	203	90.73
Hydraulic Capacity	N/A	602.1	125.44

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

#### Significance of Results:

The annual mean hydraulic loading is greater than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

## 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF3300D0409SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Suspended Solids mg/l	35	87.5	N/A	6	3	N/A	36.88	Fail
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	25	50	N/A	6	4	2	46.15	Fail
Temperature °C	25	25	N/A	6	N/A	N/A	13	Pass
pH pH units	9	9	N/A	6	N/A	N/A	7.06	Pass
Visual Inspection Descriptive	N/A	N/A	N/A	6	N/A	N/A	N/A	
ortho-Phosphate (as P) - unspecified mg/l	N/A	N/A	N/A	6	N/A	N/A	2.06	
COD-Cr mg/l	N/A	N/A	N/A	6	N/A	N/A	164.83	
Ammonia-Total (as N) mg/l	N/A	N/A	N/A	6	N/A	N/A	14.45	
Total Phosphorus (as P) mg/l	N/A	N/A	N/A	6	N/A	N/A	2.73	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

### Cause of Exceedance(s):

Treatment upgrade required to achieve ELVs, no additional process optimisation possible pending upgrade

### Significance of Results:

The discharge was consistently non-compliant with ELV for cBOD, COD and TSS in 2020

## 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF3300D0409SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	272291, 115645	RS13C220990	No	No	No	No	Unassigned
Downstream	272014, 115446	TW33002097SR6001	No	No	No	Yes	Moderate

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**

### Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results does not meet the required EQS for BOD only. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in Ammonia and Ortho-phosphate, concentrations downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

Other causes of deterioration in water quality in the area are: There are potential influences from tidal effect and local agricultural activities contributing to detected reduction in water quality regarding ammonia and ortho-phosphate.

The discharge from the wastewater treatment plant does have an observable negative impact on the Water Framework Directive status.

## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - CAMPILE WWTP - 2020

### 2.1.4.1 Treatment Efficiency Report - CAMPILE WWTP - 2020

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
TP	178	100	44
cBOD	8626	1690	80
TN	N/A	N/A	N/A
SS	3323	1351	59
COD	16208	6037	63

Note: The above data is based on sample results for the number of dates reported

### 2.1.4.2 Treatment Capacity Report Summary - CAMPILE WWTP - 2020

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

CAMPILE WWTP - 2020	
Peak Hydraulic Capacity (m <sup>3</sup> /day) - As Constructed	102
DWF to the Treatment Plant (m <sup>3</sup> /day)	34
Current Hydraulic Loading - annual max (m <sup>3</sup> /day)	602.1
Average Hydraulic loading to the Treatment Plant (m <sup>3</sup> /day)	125.44
Organic Capacity (PE) - As Constructed	150
Organic Capacity (PE) - Collected Load (peak week) <sup>Note1</sup>	451
Organic Capacity (PE) - Remaining	0
Will the capacity be exceeded in the next three years? (Yes/No)	Yes

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

## 2.1.5 SLUDGE / OTHER INPUTS - CAMPILE WWTP - 2020

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

## 3 COMPLAINTS AND INCIDENTS

### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2020.			

### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Breach of ELV	WWTP upgrade required to meet ELV	1	Yes	No
Uncontrolled release	EO caused by ragging or blocking	1	No	Yes

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2020	2
Number of Incidents reported to the EPA via EDEN in 2020	2
Explanation of any discrepancies between the two numbers above	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2020 (No. of events)	Total volume discharged in 2020 (m3)	Monitoring Status
SW2	272297, 115645	Yes	Low	Meeting	Unknown	Unknown	Not Monitored
TBC	272179, 115569	No	Low	Meeting	Unknown	Unknown	Not Monitored
TBC	272104, 115526	No	Low	Meeting	Unknown	Unknown	Not Monitored

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes

## SWO Summary

Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?

No

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0409-SIP:01</b>	Provision of Primary Treatment	C	31/12/2013	Yes	Not Started		Capital works not funded in RC3. Capital works funding post 2024 will be contingent on the project being included in the 2025-2029 investment period.
<b>D0409-SIP:02</b>	Provision of secondary Treatment	C	31/12/2015	Yes	Not Started		Capital works not funded in RC3. Capital works funding post 2024 will be contingent on the project being included in the 2025-2029 investment period.

A summary of the status of any improvements identified by under Condition 5.2 is included below.

### 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
<b>There are no Improvements Programme for this Agglomeration.</b>				

### 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.

## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
Priority Substances Assessment	Yes	2014	No	
Shellfish Impact Assessment	Yes		No	

### 5.1 PRIORITY SUBSTANCES ASSESSMENT

The Priority Substances Assessment Report has been included in the AER 2014

### 5.2 SHELLFISH IMPACT ASSESSMENT

Shellfish Impact assessment Stage 4a submitted via Licensee Return.

## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	Yes
List reason e.g. additional SWO identified	SWOs
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	No
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	n/a

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed:    Date: 30/06/2021

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Katherine Walshe

Acting Head of Environmental Regulation.

## 7 APPENDIX

Appendix

Appendix 7.1 - Ambient monitoring summary

		Ammonia N	Ortho-Phosphate P	pH	Temperature	Dissolved Oxygen	Visual Inspection	Faecal Coliforms	Biological Oxygen Demand
Station Reference	Sample Date	mg/l	mg/l	pH units	Degrees C	mg/l	Descriptive	no./100mls	mg/l
TW33002097SR6001	7-Jan-2020	0.02	0.04	8.13	10.3	11.07	Clear, Low SS No Tarry residue, mineral oil or detergents	120	2
TW33002097SR6001	2-July-2020	0.02	0.03	7.68	11.5	9.82	Clear, No SS, No Tarry residue, mineral oil or detergents	2420	2
<b>Annual Mean</b>		<b>0.02</b>	<b>0.035</b>	<b>7.905</b>	<b>10.9</b>	<b>10.445</b>		<b>1270</b>	<b>2</b>

Ambient Points

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	EPA Feature Coding Tool code	Receiving Waters Designation (Y/N)				WFD Status
			Bathing Water	Drinking Water	FWPM	Shellfish	
RS13C220990	272288, 115649	TPEFFD0409SW001	No	No	No	No	Unassigned
TW33002097SR6001	272014, 115445	TPEFFD0409SW001	No	No	No	No	Unassigned

Ambient Impact Assessment Table

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	%EQS
cBOD mg/l	RS13C220990	2.55	TW33002097SR6001	2.0	1.5	-21.15
Ortho-Phosphate (as P) mg/l	RS13C220990	0.022	TW33002097SR6001	0.035	0.035	17.33
Ammonia (as N) mg/l	RS13C220990	0.014	TW33002097SR6001	0.02	0.065	42.86