

Annual Environmental Report

2020



Glengarriff

D0471-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 GLENGARRIFF SEPTIC TANK - 2020 - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - GLENGARRIFF SEPTIC TANK - 2020
 - 2.1.2 EFFLUENT MONITORING SUMMARY - GLENGARRIFF SEPTIC TANK - 2020 -
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR GLENGARRIFF SEPTIC TANK - 2020
 - 2.1.5 SLUDGE/OTHER INPUTS TO GLENGARRIFF SEPTIC TANK - 2020

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 SHELLFISH IMPACT ASSESSMENT

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

7.1 AMBIENT MONITORING SUMMARY

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

This Annual Environmental Report has been prepared for D0471-01, Glengarriff, in Cork in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- GLENGARRIFF SEPTIC TANK - 2020 with a Plant Capacity PE of 1000, the treatment type is 1 - Primary treatment

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF0500D0471SW001	GLENGARRIFF SEPTIC TANK - 2020	Treated	N/A	N/A

1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
There are no Licence Specific Reports included in the AER.	

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 GLENGARRIFF SEPTIC TANK - 2020 - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - GLENGARRIFF SEPTIC TANK - 2020

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
There is no Influent data included in the AER.			

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is greater than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF0500D0471SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
BOD, 5 days with Inhibition (Carbonaceo mg/l)	N/A	N/A	N/A	2	N/A	N/A	275.5	Monitoring of the licence is not required until the completion of the new wastewater treatment plant or 22/12/2020 (whichever is sooner)
COD-Cr mg/l	N/A	N/A	N/A	2	N/A	N/A	647	
Nitrate (as N) mg/l	N/A	N/A	N/A	2	N/A	N/A	0.35	
Enterococci (Intestinal) no./100mls	N/A	N/A	N/A	2	N/A	N/A	24197	
pH pH units	N/A	N/A	N/A	2	N/A	N/A	6.9	
Total Phosphorus (as P) mg/l	N/A	N/A	N/A	2	N/A	N/A	3.59	
Total Oxidised Nitrogen (as N) mg/l	N/A	N/A	N/A	2	N/A	N/A	0.35	
Ammonia-Total (as N) mg/l	N/A	N/A	N/A	2	N/A	N/A	22.6	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Suspended Solids mg/l	N/A	N/A	N/A	2	N/A	N/A	254.5	
E. Coli no./100mls	N/A	N/A	N/A	2	N/A	N/A	24197	
Faecal coliforms no./100mls	N/A	N/A	N/A	2	N/A	N/A	N/A	
Total Nitrogen mg/l	N/A	N/A	N/A	2	N/A	N/A	14.84	
ortho-Phosphate (as P) - unspecified mg/l	N/A	N/A	N/A	2	N/A	N/A	2.13	
Dissolved Inorganic Nitrogen (as N) mg/l	N/A	N/A	N/A	2	N/A	N/A	22.6	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

Cause of Exceedance(s):

Not applicable

Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF0500D0471SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Downstream	93674, 56501	TW05003194GF1001	No	No	No	Yes	Unassigned

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**

Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - GLENGARRIFF SEPTIC TANK - 2020

2.1.4.1 Treatment Efficiency Report - GLENGARRIFF SEPTIC TANK - 2020

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
TN	N/A	980	N/A
TP	N/A	237	N/A
SS	N/A	16814	N/A
COD	N/A	42744	N/A
cBOD	N/A	18201	N/A

Note: The above data is based on sample results for the number of dates reported

2.1.4.2 Treatment Capacity Report Summary - GLENGARRIFF SEPTIC TANK - 2020

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

GLENGARRIFF SEPTIC TANK - 2020	
Peak Hydraulic Capacity (m ³ /day) - As Constructed	N/A
DWF to the Treatment Plant (m ³ /day)	225
Current Hydraulic Loading - annual max (m ³ /day)	N/A

GLENGARRIFF SEPTIC TANK - 2020	
Average Hydraulic loading to the Treatment Plant (m ³ /day)	32
Organic Capacity (PE) - As Constructed	1000
Organic Capacity (PE) - Collected Load (peak week) ^{Note1}	802
Organic Capacity (PE) - Remaining	198
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - GLENGARRIFF SEPTIC TANK - 2020

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2020.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
There were no reportable incidents in 2020.				

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2020	0
Number of Incidents reported to the EPA via EDEN in 2020	0
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2020 (No. of events)	Total volume discharged in 2020 (m3)	Monitoring Status
TBC	93614, 56566	No	Low	Meeting	Unknown	Unknown	Not Monitored
TBC	93306, 56322	No	Low	Meeting	Unknown	Unknown	Not Monitored
TBC	92797, 56274	No	Low	Meeting	Unknown	Unknown	Not Monitored

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	No
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes

SWO Summary

Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?

N/A

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0471-SIP:01	Waste water treatment plant and ancillary works	C	22/12/2020	Yes	Not Started		Capital works not funded in RC3. Capital works funding post 2024 will be contingent on the project being included in the 2025-2029 investment period.

A summary of the status of any improvements identified by under Condition 5.2 is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
There are no Improvements Programme for this Agglomeration.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
Shellfish Impact Assessment	Yes		No	

5.1 SHELLFISH IMPACT ASSESSMENT

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	N/A
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	Yes

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 01/06/2021

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Katherine Walshe

Acting Head of Environmental Regulation.

7 APPENDIX


Appendix

Appendix 7.1 - Ambient monitoring summary

Glengarriff	Transitional		12/03/2020 13:00	20/05/2020 12:40	19/08/2020 10:45	07/10/2020 12:00	Median	Mean	95%ile
	EQS								
	Mean	95%ile							
D.O % O ₂	80%<95%ile<120%		106.5	103.2	99.4	99.4			106.005
Temperature C°	≤ 1.5 C° increase		9	15.9	17.2	12.5			
pH	6 < pH < 9		8	8.2	7.9	8			
BOD mg/L	n/a	≤ 4	1.7	2	2.8	1.3			2.68
Orthophosphate (P) mg/l	≤0.04 @35 PSU (Median)		0.005		0.005	0.02	0.005		
Ammonia (N) mg/l	≤ 0.065	≤ 0.140	0.01	0.0175	0.0175	0.038		0.02075	0.034925
DIN (N) mg/l	≤ 2.6 @ 0 PSU ≤ 0.25 @ 34 PSU		0.0175	0.05	0.081	0.078	0.064	0.056625	0.08055
TON (N) mg/l	n/a		0.19	0.05	0.07	0.04			
E.Coli MPN/100mls	n/a		30	5	2481	109			
Faecal Coliforms MPN/100mls	n/a		20	5	2481	228			
Intestinal enterococci CFU/100mls	n/a		5	5	74	151			

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	EPA Feature Coding tool Code	Bathing Water	Drinking Water	FWPM	Shellfish	Current WFD Status
Downstream Monitoring Point	E93674 N56501	TW05003194GF1001	No	No	No	Yes	Unassigned

Significance of Results	
Did the ambient monitoring results meet the EQS Required?	Yes
Is there an observable negative impact on water quality?	Unknown - "observable" TBC
List the parameters causing the impact?	N/A
A deterioration has been identified, but it is not known if it is caused by the TP	N/A
Do the discharges from the WWTP have an observable negative impact on the WFD?	Unknown - "observable" TBC
Any other known impacts	Catchment Pressures



WaterbodyName	WaterbodyCode	Waterbodytyp	MonitoringStationCode	MonitoringStationName	MonitoringStatio	Monitoring	SampleCod	SampleDate	SampleMe	ParameterName	ParameterI	ParameterUnitName	Result	TextResult	ResultStrin	LimitOfDet	ReportResu	ReportText	ReportRest	ReportLimit
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	92157	07/10/2020	Grab	Ammonia-Total (as N)	mg/l	milligrams per litre	0.038			0	0.038			
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	87208	12/03/2020	Grab	Ammonia-Total (as N)	mg/l	milligrams per litre		<0.02		0	0.01	<0.02		0.02
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	88187	20/05/2020	Grab	BOD - 5 days (Total)	mg/l	milligrams per litre	2			1	2			1
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	88187	20/05/2020	Grab	Ammonia-Total (as N)	mg/l	milligrams per litre		<0.035		0	0.0175	<0.035		0.035
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	90819	19/08/2020	Grab	Ammonia-Total (as N)	mg/l	milligrams per litre		<0.035		0	0.0175	<0.035		0.035
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	87208	12/03/2020	Grab	BOD - 5 days (Total)	mg/l	milligrams per litre	1.7			1	1.7			1
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	87208	12/03/2020	Grab	Dissolved Inorganic Nitroge	mg/l	milligrams per litre		<0.035		0	0.0175	<0.035		0.035
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	92157	07/10/2020	Grab	Dissolved Inorganic Nitroge	mg/l	milligrams per litre	0.078			0	0.078			
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	90819	19/08/2020	Grab	Dissolved Oxygen	% Saturatic	Percentage Saturation	99.4			0	99.4			
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	90819	19/08/2020	Grab	BOD - 5 days (Total)	mg/l	milligrams per litre	2.8			1	2.8			1
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	92157	07/10/2020	Grab	BOD - 5 days (Total)	mg/l	milligrams per litre	1.3			1	1.3			1
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	90819	19/08/2020	Grab	Dissolved Inorganic Nitroge	mg/l	milligrams per litre	0.081			0	0.081			
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	87208	12/03/2020	Grab	Dissolved Oxygen	% Saturatic	Percentage Saturation	106.5			0	106.5			
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	92157	07/10/2020	Grab	E. Coli	no./100mls	Number per one hundred	109			0	109			
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	88187	20/05/2020	Grab	E. Coli	no./100mls	Number per one hundred millilitres		<10		0	5	<10		10
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	87208	12/03/2020	Grab	Enterococci (Intestinal)	no./100mls	Number per one hundred millilitres		<10		0	5	<10		10
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	87208	12/03/2020	Grab	Faecal coliforms	no./100mls	Number per one hundred	20			0	20			
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	88187	20/05/2020	Grab	Faecal coliforms	no./100mls	Number per one hundred millilitres		<10		0	5	<10		10
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	88187	20/05/2020	Grab	ortho-Phosphate (as P) - un	mg/l	milligrams per litre		<10.00		0	5	<10.00		10
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	90819	19/08/2020	Grab	ortho-Phosphate (as P) - un	mg/l	milligrams per litre		<0.01		0	0.005	<0.01		0.01
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	88187	20/05/2020	Grab	pH	pH units	pH Units	8.2			2	8.2			2
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	87208	12/03/2020	Grab	pH	pH units	pH Units	8			2	8			2
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	90819	19/08/2020	Grab	pH	pH units	pH Units	7.9			2	7.9			2
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	92157	07/10/2020	Grab	Total Oxidised Nitrogen (as	mg/l	milligrams per litre	0.04			0	0.04			
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	88187	20/05/2020	Grab	Dissolved Inorganic Nitroge	mg/l	milligrams per litre	0.05			0	0.05			
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	87208	12/03/2020	Grab	Total Oxidised Nitrogen (as	mg/l	milligrams per litre	0.19			0	0.19			
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	88187	20/05/2020	Grab	Dissolved Oxygen	% Saturatic	Percentage Saturation	103.2			0	103.2			
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	87208	12/03/2020	Grab	E. Coli	no./100mls	Number per one hundred	30			0	30			
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	90819	19/08/2020	Grab	E. Coli	no./100mls	Number per one hundred	2481			0	2481			
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	88187	20/05/2020	Grab	Enterococci (Intestinal)	no./100mls	Number per one hundred millilitres		<10		0	5	<10		10
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	87208	12/03/2020	Grab	ortho-Phosphate (as P) - un	mg/l	milligrams per litre		<0.01		0	0.005	<0.01		0.01
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	88187	20/05/2020	Grab	Temperature	Â°C	Degrees centigrade	15.9			0	15.9			
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	88187	20/05/2020	Grab	Total Oxidised Nitrogen (as	mg/l	milligrams per litre	0.05			0	0.05			
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	90819	19/08/2020	Grab	Total Oxidised Nitrogen (as	mg/l	milligrams per litre	0.07			0	0.07			
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	92157	07/10/2020	Grab	Dissolved Oxygen	% Saturatic	Percentage Saturation	99.4			0	99.4			
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	90819	19/08/2020	Grab	Enterococci (Intestinal)	no./100mls	Number per one hundred	74			0	74			
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	92157	07/10/2020	Grab	Enterococci (Intestinal)	no./100mls	Number per one hundred	151			0	151			
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	90819	19/08/2020	Grab	Faecal coliforms	no./100mls	Number per one hundred	2481			0	2481			
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	92157	07/10/2020	Grab	Faecal coliforms	no./100mls	Number per one hundred	228			0	228			
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	92157	07/10/2020	Grab	ortho-Phosphate (as P) - un	mg/l	milligrams per litre	0.02			0	0.02			
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	92157	07/10/2020	Grab	pH	pH units	pH Units	8			2	8			2
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	87208	12/03/2020	Grab	Temperature	Â°C	Degrees centigrade	9			0	9			
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	90819	19/08/2020	Grab	Temperature	Â°C	Degrees centigrade	17.2			0	17.2			
Glengarriff Harbour	IE_SW_170_0400	Transitional	TW05003194GF1001	Glengarriff Ambient	Investigative	Cork Count	92157	07/10/2020	Grab	Temperature	Â°C	Degrees centigrade	12.5			0	12.5			