

Annual Environmental Report

2020



Navan

D0059-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 NAVAN WWTP - 2020 - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - NAVAN WWTP - 2020
 - 2.1.2 EFFLUENT MONITORING SUMMARY - NAVAN WWTP - 2020 -
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR NAVAN WWTP - 2020
 - 2.1.5 SLUDGE/OTHER INPUTS TO NAVAN WWTP - 2020

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 PRIORITY SUBSTANCES ASSESSMENT
- 5.2 TOXICITY OF FINAL EFFLUENT

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

This Annual Environmental Report has been prepared for D0059-01, Navan, in Meath in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

Two new inlet screens were installed in Navan WWTP in 2020.

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- NAVAN WWTP - 2020 with a Plant Capacity PE of 50000, the treatment type is 3NP - Tertiary N&P removal

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF2300D0059SW001	NAVAN WWTP - 2020	Treated	Compliant	N/A

1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
Toxicity of Final Effluent	Yes

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 NAVAN WWTP - 2020 - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - NAVAN WWTP - 2020

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
BOD, 5 days with Inhibition (Carbonaceous) mg/l	28	436	287.62
Suspended Solids mg/l	28	470	228.1
COD-Cr mg/l	28	828	563.48
Total Phosphorus mg/l	28	8.38	5.96
Total Nitrogen mg/l	28	64.4	39.08
Hydraulic Capacity	N/A	23137	13479

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF2300D0059SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included ^{Note 1}	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Chemical Oxygen Demand mg/l	100	200	N/A	27	N/A	N/A	31.86	Pass
Suspended Solids mg/l	35	87.5	N/A	27	N/A	N/A	9.58	Pass
BOD, 5 days with Inhibition (Carbonaceous) mg/l	13	26	N/A	27	N/A	N/A	6.77	Pass
pH pH units	6-9	6-9	N/A	6	N/A	N/A	6.94	Pass
Ammonia-Total (as N) mg/l	3	3.6	N/A	27	N/A	N/A	0.04	Pass
Total Phosphorus mg/l	1	1.2	N/A	27	N/A	N/A	0.56	Pass
Total Nitrogen mg/l	N/A	N/A	N/A	27	N/A	N/A	15.59	
ortho-Phosphate (as P) - unspecified mg/l	N/A	N/A	N/A	27	N/A	N/A	0.33	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

Cause of Exceedance(s):

Not applicable

Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF2300D0059SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	288486, 269101	RS07B041900	No	No	No	No	Unassigned
Downstream	291858, 271311	RS07B042000	No	No	No	No	Moderate

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**.

Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - NAVAN WWTP - 2020

2.1.4.1 Treatment Efficiency Report - NAVAN WWTP - 2020

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
cBOD	1349920	26994	98
COD	2635826	125900	95
SS	1027489	38178	96
TN	187380	63170	66
TP	28166	2274	92

Note: The above data is based on sample results for the number of dates reported

2.1.4.2 Treatment Capacity Report Summary - NAVAN WWTP - 2020

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

NAVAN WWTP - 2020	
Peak Hydraulic Capacity (m³/day) - As Constructed	33750
DWF to the Treatment Plant (m³/day)	12500
Current Hydraulic Loading - annual max (m³/day)	23137
Average Hydraulic loading to the Treatment Plant (m³/day)	13479
Organic Capacity (PE) - As Constructed	50000
Organic Capacity (PE) - Collected Load (peak week)^{Note1}	37522
Organic Capacity (PE) - Remaining	12478
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - NAVAN WWTP - 2020

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
Landfill Leachate (delivered by tanker)	5701	Weight (Tonnes)	69	1.66	Yes	Yes	Yes
Waterworks Sludge	5153	Weight (Tonnes)	63	1	Yes	Yes	Yes

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2020.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Abatement Equipment offline	Plant or equipment breakdown at WWTP	1	No	Yes
Abatement Equipment offline	Plant or equipment breakdown at WWTP	1	No	Yes
Abatement Equipment offline	Adverse Weather	1	No	Yes

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Abatement Equipment offline	Plant or equipment breakdown at WWTP	1	No	Yes
Abatement Equipment offline	Plant or equipment breakdown at WWTP	1	No	Yes
Abatement Equipment offline	Screen not operating	1	No	Yes
Abatement Equipment offline	Plant or equipment breakdown at WWTP	1	Yes	Yes
Abatement Equipment offline	Plant or equipment breakdown at WWTP	1	Yes	Yes
Spillage	Blocked Sewer	1	No	No
Uncontrolled release	EO caused by pump failure	1	No	Yes
Uncontrolled release	Adverse Weather	1	No	Yes
Uncontrolled release	EO caused by power failure	1	No	Yes

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2020	12
Number of Incidents reported to the EPA via EDEN in 2020	12
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2020 (No. of events)	Total volume discharged in 2020 (m ³)	Monitoring Status
SW004	TBC, TBC	Yes	Unknown	Not yet Assessed	Unknown	Unknown	Unknown
SW11	287969, 266644	Yes	Medium	Meeting	0	0	Monitored
SW12	288482, 265674	Yes	Medium	Meeting	0	0	Monitored
SW2	288376, 268810	Yes	Medium	Meeting	Unknown	Unknown	Not Monitored
SW3	288083, 268256	Yes	Medium	Not Meeting	27	Unknown	Monitored
SW5	287209, 267986	Yes	Medium	Meeting	Unknown	Unknown	Not Monitored

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2020 (No. of events)	Total volume discharged in 2020 (m ³)	Monitoring Status
SW6	286591, 268367	Yes	Medium	Meeting	Unknown	Unknown	Not Monitored
SW7	287187, 267931	Yes	Medium	Not yet Assessed	Unknown	Unknown	Not Monitored
SW8	287251, 267761	Yes	Medium	Meeting	2	Unknown	Monitored
SW9	286816, 266103	Yes	Medium	Meeting	0	0	Monitored

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m ³)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/N/A/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0059-SIP:01	Upgrading of sewer network to ensure all SWO's comply with criteria set out in DoEHLG.....	C	31/01/2011	Yes	Works Completed		
D0059-SIP:02	Waste water sewer network rehabilitation works and improvements	C	31/01/2011	Yes	Works Completed		

A summary of the status of any improvements identified by under Condition 5.2 is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
There are no Improvements Programme for this Agglomeration.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
Priority Substances Assessment	Yes	2015	No	N/A
Toxicity of Final Effluent	Yes	2016	Yes	Appendix 7.2

5.1 PRIORITY SUBSTANCES ASSESSMENT

The Priority Substances Assessment Report has been included in the AER 2015.

5.2 TOXICITY OF FINAL EFFLUENT

The Toxicity of Final Effluent Report is included in Appendix 7.2. A summary of the findings of this report is included below.

Parameter	Value
Are any procedural and/or infrastructural works to reduce the toxicity of the final discharge included?	No
Does the report identify that the discharge is toxic to any of the species in the study?	No
Has the study been carried out against 4 species in 3 trophic levels?	Yes

Parameter	Value
Is a Toxicity report required?	Yes
List species impacted	None
Recommendations	None
Status of any improvement measures required	No

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	Yes

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Date: 28/02/2021

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of,

Katherine Walshe

Acting Head of Environmental Regulation.

7 APPENDIX

Appendix
Appendix 7.1 - Ambient Monitoring Summary
Appendix 7.2 - Toxicity of Final Effluent Report

Navan 2020 Ambient Monitoring Summary

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish National Grid Reference (Easting, Northing)	EPA Feature Coding Tool code	Receiving Waters Designation (Yes/No)			
			Bathing Water	Drinking Water	FWPM	Shellfish
Upstream Monitoring Point	288486, 269101	RS07B041900	No	No	No	No
Downstream Monitoring Point	291858, 271311	RS07B042000	No	No	No	No

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Current WFD Status	cBOD (Mean mg/l)	o-Phosphate (as P) (Mean mg/l)	Ammonia (as N) (mean mg/l)
Upstream Monitoring Point	Unassigned	1.268	0.033	0.031
Downstream Monitoring Point	Moderate	1.249	0.031	0.026
<i>Difference</i>		<i>-0.019</i>	<i>-0.002</i>	<i>-0.005</i>
EQS		1.500	0.035	0.065
% of EQS		-1.267%	-6.000%	-8.368%

Navan 2020 Ambient Monitoring Data

Station	Sample Date	D.O. mg/l	D.O. % Sat.	pH pH units	B.O.D. mg/l	Ortho-P mg/l	Coliform Bacteria no./100mls	Temp	Total N mg/l	Ammonia mg/l
u/s Navan WWTP	19-Mar-2020	11.8	96	8.10	1.21	0.052			3.51	0.040
u/s Navan WWTP	6-May-2020	11.7	112	8.01	0.89	0.016			3.42	0.023
u/s Navan WWTP	19-May-2020	10.0	96	8.10	1.62	0.019			2.54	0.044
u/s Navan WWTP	24-June-2020						290.00			
u/s Navan WWTP	22-July-2020	9.0	93	8.02	0.93	0.042			2.05	0.043
u/s Navan WWTP	16-Sep-2020	10.1	102	8.08	0.66	0.033			2.18	0.028
u/s Navan WWTP	23-Sep-2020	9.7	94	8.04	2.56	0.023			2.60	0.046
u/s Navan WWTP	28-Oct-2020	11.2	99	8.08	1.58	0.033		8.30	3.18	0.015
	29-Oct-2020						410.00			
u/s Navan WWTP	27-Nov-2020	11.9	100	8.14	0.95	0.028		7.40	2.95	0.015
u/s Navan WWTP	4-Dec-2020	12.0	100	8.07	0.99	0.035		5.70	3.44	< 0.015
u/s Navan WWTP	16-Dec-2020	11.6	99	8.09	1.29	0.050		7.50	3.64	0.050
	Mean	10.9	99	8.07	1.268	0.033	350.000	7.225	2.95	0.031
	95%ile	12.0	108	8.12	2.137	0.051	404.000	8.180	3.58	0.048
d/s Navan WWTP	19-Mar-2020	11.6	97	8.10	1.00	0.055			3.29	0.039
d/s Navan WWTP	6-May-2020	13.5	129	8.04	1.19	0.017			3.07	0.014
d/s Navan WWTP	19-May-2020	10.1	98	8.10	1.54	0.018			2.60	0.033
	24-June-2020						420.000			
d/s Navan WWTP	22-July-2020	9.0	93	8.02	0.80	0.038			2.31	0.034
d/s Navan WWTP	16-Sep-2020	10.3	104	8.11	0.76	0.029			2.28	0.024
d/s Navan WWTP	23-Sep-2020	9.8	95	8.05	2.38	0.021			3.63	0.031
d/s Navan WWTP	28-Oct-2020	11.4	100	8.09	1.53	0.033		8.500	2.81	0.022
	29-Oct-2020						590.000			
d/s Navan WWTP	27-Nov-2020	11.9	99	8.14	0.75	0.023		7.200	3.33	< 0.015
d/s Navan WWTP	4-Dec-2020	12.1	101	8.10	1.21	0.032		5.600	3.39	< 0.015
d/s Navan WWTP	16-Dec-2020	11.6	99	8.09	1.33	0.044		7.200	3.35	0.042
	Mean	11.1	102	8.08	1.249	0.031	505.000	7.125	3.01	0.026
	95%ile	12.9	118	8.13	2.002	0.050	581.500	8.305	3.52	0.041

Note: Where the concentration in the result is less than the limit of detection (LOD), a value of $LOD/\sqrt{2}$ was used in calculating the mean and 95%ile concentrations.

A copy of this certificate is available on www.fitzsci.ie

Customer	Kieran Cunningham Meath Co. Co. Environmental Section Farganstown Navan Co. Meath	Lab Report Ref. No.	0490/508/01
Customer PO	51527304	Date of Receipt	24/06/2020
Customer Ref	20-0318 (Navan FE)	Sampled On	24/06/2020
Ref 2	24/06/20 10:20	Date Testing Commenced	24/06/2020
Ref 3		Received or Collected	By Fitz: Pick up DS
		Condition on Receipt	Acceptable
		Date of Report	28/07/2020
		Sample Type	Effluent

CERTIFICATE OF ANALYSIS

Test Parameter	SOP	Analytical Technique	Result	Units	Acc.
Toxicity (Daphnia Magna) 24hrs	0	LC50	>100	% v/v	
Toxicity (Daphnia magna) 48 hrs	0	LC50	>100	% v/v	

Signed : 
Aoife Harmon - Laboratory Supervisor

Date : 28/07/2020

Acc. : Accredited Parameters by ISO/IEC 17025:2017

PVL - Parametric Value Limit as per EU (Drinking water) Regulations (SI 122 2014)

For bacterial analysis a result of 0 means none detected in volume examined

All organic results are analysed as received and all results are corrected for dry weight at 104 C

Results shall not be reproduced, except in full, without the approval of Fitz Scientific

Results contained in this report relate only to the samples tested (P) : Presumptive Results

** : The test result for this parameter may be invalid as it has exceeded the recommended holding time (BS EN ISO 5667-3:2018)



Monitoring and Testing Services

Unit 35,
Boyne Business Park,
Drogheda,
Co. Louth
Ireland

Tel: +353 41 9845440
Fax: +353 41 9846171
Web: www.fitzsci.ie
email info@fitzsci.ie

A copy of this certificate is available on www.fitzsci.ie

Table with 4 columns: Customer, Lab Report Ref. No., Date of Receipt, Sampled On, Date Testing Commenced, Received or Collected, Condition on Receipt, Date of Report, Sample Type. Includes details for Kieran Cunningham and sample 0490/508/02.

CERTIFICATE OF ANALYSIS

Table with 6 columns: Test Parameter, SOP, Analytical Technique, Result, Units, Acc. Row 1: *Toxicity (Vibrio Fischeri)*, 0, By Subcontractor, >45, % v/v, Yes. Below Result: <2.2 Toxic units

Signed : [Signature]
Aoife Harmon - Laboratory Supervisor

Date : 03/07/2020

Acc. : Accredited Parameters by ISO/IEC 17025:2017
PVL - Parametric Value Limit as per EU (Drinking water) Regulations (SI 122 2014)
For bacterial analysis a result of 0 means none detected in volume examined
All organic results are analysed as received and all results are corrected for dry weight at 104 C
Results shall not be reproduced, except in full, without the approval of Fitz Scientific
Results contained in this report relate only to the samples tested (P) : Presumptive Results
** : The test result for this parameter may be invalid as it has exceeded the recommended holding time (BS EN ISO 5667-3:2018)