

Annual Environmental Report

2020



Kilmadthomas

D0275-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 KILMACTHOMAS - 2020 - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - KILMACTHOMAS - 2020
 - 2.1.2 EFFLUENT MONITORING SUMMARY - KILMACTHOMAS - 2020 -
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR KILMACTHOMAS - 2020
 - 2.1.5 SLUDGE/OTHER INPUTS TO KILMACTHOMAS - 2020

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 DRINKING WATER ABSTRACTION POINT RISK ASSESSMENT
- 5.2 PEARL MUSSEL REPORT
- 5.3 SMALL STREAM RISK SCORE ASSESSMENT

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

7.1 AMBIENT MONITORING SUMMARY

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

This Annual Environmental Report has been prepared for D0275-01, Kilmacthomas, in Waterford in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

No Capital Works presently identified

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Kilmacthomas - 2020 with a Plant Capacity PE of 2110, the treatment type is 3P - Tertiary P removal

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF3100D0275SW001	Kilmacthomas - 2020	Treated	Compliant	N/A

1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
There are no Licence Specific Reports included in the AER.	

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 KILMACTHOMAS - 2020 - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - KILMACTHOMAS - 2020

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	11	299	159.27
Total Phosphorus (as P) mg/l	11	7.01	4.92
Total Nitrogen mg/l	1	39.2	39.2
COD-Cr mg/l	11	562	367.27
Suspended Solids mg/l	11	203	129.27
Hydraulic Capacity	N/A	1725	399

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the section 'Operational Performance Summary'.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF3100D0275SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	11	N/A	N/A	18.42	Pass
Suspended Solids mg/l	35	87.5	N/A	11	N/A	N/A	5.19	Pass
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	25	50	N/A	11	N/A	N/A	2.04	Pass
pH pH units	9	9	N/A	12	N/A	N/A	7	Pass
Ammonia-Total (as N) mg/l	5	6	N/A	11	N/A	N/A	0.34	Pass
ortho-Phosphate (as P) - unspecified mg/l	2	2.4	N/A	11	N/A	N/A	0.52	Pass
Arsenic - unfiltered µg/l	N/A	N/A	N/A	1	N/A	N/A	2.3	
Antimony - unfiltered µg/l	N/A	N/A	N/A	1	N/A	N/A	0.3	
Anthracene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.01	
Acenaphthylene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.01	
Benzene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.1	
Benzo(a)anthracene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.01	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Dieldrin µg/l	N/A	N/A	N/A	1	N/A	N/A	0.05	
Chrysene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.01	
Diuron µg/l	N/A	N/A	N/A	1	N/A	N/A	0.5	
Ethylbenzene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.5	
Dibenzo(a,h)anthracene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.01	
Dichlobenil µg/l	N/A	N/A	N/A	1	N/A	N/A	0.05	
Cyanide (unspecified) µg/l	N/A	N/A	N/A	1	N/A	N/A	1	
Copper - unfiltered mg/l	N/A	N/A	N/A	1	N/A	N/A	14	
Conductivity @20°C µS/cm	N/A	N/A	N/A	2	N/A	N/A	342.50	
Cobalt - filtered µg/l	N/A	N/A	N/A	1	N/A	N/A	3	
Isoproturon µg/l	N/A	N/A	N/A	1	N/A	N/A	0.5	
Cadmium - unfiltered µg/l	N/A	N/A	N/A	1	N/A	N/A	0.5	
MCPA µg/l	N/A	N/A	N/A	1	N/A	N/A	0.05	
Linuron µg/l	N/A	N/A	N/A	1	N/A	N/A	0.5	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Magnesium - filtered mg/l	N/A	N/A	N/A	1	N/A	N/A	6	
Simazine µg/l	N/A	N/A	N/A	1	N/A	N/A	0.02	
Nickel - unfiltered µg/l	N/A	N/A	N/A	1	N/A	N/A	1.5	
Hexachlorobenzene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.05	
Fluorene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.01	
Isodrin µg/l	N/A	N/A	N/A	1	N/A	N/A	0.05	
Polyaromatic Hydrocarbons (PAH) - Sum µg/l	N/A	N/A	N/A	1	N/A	N/A	0.01	
Selenium - unfiltered µg/l	N/A	N/A	N/A	1	N/A	N/A	3	
Zinc - filtered mg/l	N/A	N/A	N/A	1	N/A	N/A	6	
Tetrachloroethene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.1	
Pyrene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.01	
gamma-BHC / HCH (Lindane) µg/l	N/A	N/A	N/A	1	N/A	N/A	0.05	
ortho-Xylene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.5	
Benzo(g,h,i)perylene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.01	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Benzo(k)fluoranthene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.01	
1,2,3-Trichlorobenzene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.01	
1,1-Dichloroethane µg/l	N/A	N/A	N/A	1	N/A	N/A	0.1	
Beta-BHC /Beta-HCH µg/l	N/A	N/A	N/A	1	N/A	N/A	0.05	
1,2,4-Trimethylbenzene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.01	
Benzo(a)pyrene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.01	
alpha BHC / Alpha-HCH µg/l	N/A	N/A	N/A	1	N/A	N/A	0.05	
Atrazine µg/l	N/A	N/A	N/A	1	N/A	N/A	0.02	
Benzo(b)fluoranthene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.01	
Barium - unfiltered µg/l	N/A	N/A	N/A	1	N/A	N/A	5	
Chromium - unfiltered µg/l	N/A	N/A	N/A	1	N/A	N/A	0.3	
Boron - unfiltered µg/l	N/A	N/A	N/A	1	N/A	N/A	500	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Chloroform µg/l	N/A	N/A	N/A	1	N/A	N/A	1	
Calcium - filtered mg/l	N/A	N/A	N/A	1	N/A	N/A	21.8	
Chloromethane µg/l	N/A	N/A	N/A	1	N/A	N/A	100	
1,2,4-Trichlorobenzene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.01	
Chloride mg/l	N/A	N/A	N/A	1	N/A	N/A	49	
Naphthalene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.01	
Faecal coliforms no./100mls	N/A	N/A	N/A	9	N/A	N/A	N/A	
Fluoride mg/l	N/A	N/A	N/A	1	N/A	N/A	0.1	
Fluoranthene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.01	
Indeno(1,2,3-c,d)pyrene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.01	
Mercury - unfiltered µg/l	N/A	N/A	N/A	1	N/A	N/A	0.5	
Molybdenum - filtered µg/l	N/A	N/A	N/A	1	N/A	N/A	800	
Acenaphthene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.01	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Hexachlorobutadiene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.5	
Glyphosate µg/l	N/A	N/A	N/A	1	N/A	N/A	0.1	
Mecoprop µg/l	N/A	N/A	N/A	1	N/A	N/A	0.05	
Lead - unfiltered µg/l	N/A	N/A	N/A	1	N/A	N/A	1	
meta + para-Xylene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.5	
Vanadium - filtered µg/l	N/A	N/A	N/A	1	N/A	N/A	3	
Toluene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.5	
Total Oxidised Nitrogen (as N) mg/l	N/A	N/A	N/A	11	N/A	N/A	3.32	
Total Phosphorus (as P) mg/l	N/A	N/A	N/A	11	N/A	N/A	0.65	
Trichloroethene (all isomers) µg/l	N/A	N/A	N/A	1	N/A	N/A	0.1	
Total Nitrogen mg/l	N/A	N/A	N/A	9	N/A	N/A	4.75	
Tin - filtered µg/l	N/A	N/A	N/A	1	N/A	N/A	3	
Carbon Tetrachloride µg/l	N/A	N/A	N/A	1	N/A	N/A	1	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
2,4-D µg/l	N/A	N/A	N/A	1	N/A	N/A	0.05	
2,6-Dichlorobenzamide µg/l	N/A	N/A	N/A	1	N/A	N/A	0.1	
Total Hardness (as CaCO3) mg/l	N/A	N/A	N/A	1	N/A	N/A	78.9	
Phenanthrene µg/l	N/A	N/A	N/A	1	N/A	N/A	0.01	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

Cause of Exceedance(s):

Not applicable

Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF3100D0275SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	239406, 106142	RS17M010180	No	Yes	Yes	No	Moderate
Downstream	239724, 105581	RS17M010200	No	Yes	Yes	No	Moderate

The table below provides a summary of monitoring results for designated ambient monitoring points. The upstream and downstream annual mean values are shown (mg/l), and the difference between both monitoring stations is given as a percentage of the Environmental Quality Standard (EQS) where relevant.

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
Total Nitrogen mg/l	RS17M010180	4.9	RS17M010200	2.975		
ortho-Phosphate (as P) - unspecified mg/l	RS17M010180	0.025	RS17M010200	0.029	0.035	11%
Dissolved Oxygen mg/l	RS17M010180	11.375	RS17M010200	11.433		
Ammonia-Total (as N) mg/l	RS17M010180	0.013	RS17M010200	0.023	0.065	15%
pH pH units	RS17M010180	7.47	RS17M010200	7.248		
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	RS17M010180	1	RS17M010200	1	1.5	0
Temperature °C	RS17M010180	11.25	RS17M010200	11.089		
Dissolved Oxygen % O2	RS17M010180	104	RS17M010200	106.75		

Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - KILMACTHOMAS - 2020

2.1.4.1 Treatment Efficiency Report - Kilmacthomas - 2020

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
cBOD	18048	243	99
SS	17631	588	97
TN	7912	505	94
TP	591	62	90
COD	44529	1633	96

Note: The above data is based on sample results for the number of dates reported

2.1.4.2 Treatment Capacity Report Summary - Kilmacthomas - 2020

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Kilmacthomas - 2020	
Peak Hydraulic Capacity (m ³ /day) - As Constructed	1424.25
DWF to the Treatment Plant (m ³ /day)	474.75
Current Hydraulic Loading - annual max (m ³ /day)	1725
Average Hydraulic loading to the Treatment Plant (m ³ /day)	399
Organic Capacity (PE) - As Constructed	2110
Organic Capacity (PE) - Collected Load (peak week) ^{Note1}	1186
Organic Capacity (PE) - Remaining	924
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - KILMACTHOMAS - 2020

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2020.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Uncontrolled release	SWO exceptional rainfall and overflow expected	1	Yes	No

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2020	1
Number of Incidents reported to the EPA via EDEN in 2020	1
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2020 (No. of events)	Total volume discharged in 2020 (m3)	Monitoring Status
SW002	239555, 105729	Yes	Low	Meeting	23	6642	Monitored

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	6642
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0275-SIP:01	SW1 (Primary discharge point until provision of secondary WWTP)	A	31/10/2014	Yes	Works Completed		
D0275-SIP:02	SW2 - Provision of Storm Water Overflows to comply with the criteria outlined in the DoEHLG "Procedures and Criteria in relation to Storm Water Overflows, 1995".	C	31/10/2014	Yes	Works Completed		
D0275-SIP:03	Waste Water treatment plant and ancillary works	C	31/10/2014	Yes	Works Completed		

A summary of the status of any improvements identified by under Condition 5.2 is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
There are no Improvements Programme for this Agglomeration.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
Drinking Water Abstraction Point Risk Assessment	Yes	2012	No	
Pearl Mussel Report	Yes	2011	No	
Small Stream Risk Score Assessment	Yes	2016	No	

5.1 DRINKING WATER ABSTRACTION POINT RISK ASSESSMENT

The Drinking Water Abstraction Point Risk Assessment Report has been included in the AER 2012

5.2 PEARL MUSSEL REPORT

The Pearl Mussel Report Report has been included in the AER 2011

5.3 SMALL STREAM RISK SCORE ASSESSMENT

The Small Stream Risk Score Assessment Report has been included in the AER 2016

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	Yes

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 20/05/2021

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Katherine Walshe

Acting Head of Environmental Regulation.

7 APPENDIX

Appendix
Appendix 7.1 - Ambient monitoring summary

Ambient Monitoring Summary

Annual ambient monitoring results [undertaken by WCCC] show that the discharge from the WWTP is having a low impact on the receiving waters and does not affect the EQS status of the River Mahon.

Table 1 Ambient Monitoring Results SW1u							
Parameter	SW0u	SW0u	SW0u	SW0u	SW0u	SW0u	EQS (River Water Body)
Date	30/06/2020	10/09/2020	13/10/2020	22/10/2020	18/11/2020	15/12/2020	-
pH	7.39	7.49	7.4	7.6	7.21	7.29	6.0 < pH < 9.0
DO%	98	106	106	106	92	105	120% > 95%ile > 80%
Temp	12.6	12.9	10.2	9.3	9.8	8.3	
BOD	0.5	0.5	0.5	1	0	0.5	High Status ≤1.3
							Good Status ≤1.5
Orthophosphate (as P)	0.02	0.02	0.03	0.03	0.02	0.02	High Status ≤0.025
							Good Status ≤0.035
Total Nitrogen (as N)	8.9	3.5	4.3	2.9	3	5.7	Not specified
Total Ammonia (as N)	0.005	0.01	0.005	0.02	0.02	0.02	High Status ≤0.040
							Good Status ≤0.065

Table 2 Ambient Monitoring Results SW1d							
Parameter	SW0d	SW0d	SW0d	SW0d	SW0d	SW0d	EQS (River Water Body)
Date	30/06/2020	10/09/2020	13/10/2020	22/10/2020	18/11/2020	15/12/2020	-
pH	7.52	7.51	7.57	7.73	7.27	7.32	6.0 < pH < 9.0
DO%	101	106	110	110	92	107	120% > 95%ile > 80%
Temp	13	13.2	10.5	9.5	9.7	8.3	
BOD	0.5	0	0.5	1	0	0.5	High Status ≤1.3
							Good Status ≤1.5
Orthophosphate (as P)	0.04	0.06	0.04	0.03	0.02	0.02	High Status ≤0.025
							Good Status ≤0.035
Total Nitrogen (as N)	2.8	4.5	2.7	1.9	2.8	2.4	Not specified
Total Ammonia (as N)	0.005	0.03	0.04	0.005	0.02	0.01	High Status ≤0.040
							Good Status ≤0.065