

Annual Environmental Report

2020



Caherconlish

D0308-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 CAHERCONLISH WWTP - 2020 - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - CAHERCONLISH WWTP - 2020
 - 2.1.2 EFFLUENT MONITORING SUMMARY - CAHERCONLISH WWTP - 2020 -
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR CAHERCONLISH WWTP - 2020
 - 2.1.5 SLUDGE/OTHER INPUTS TO CAHERCONLISH WWTP - 2020

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 PRIORITY SUBSTANCES ASSESSMENT

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

7.1 AMBIENT MONITORING SUMMARY

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

This Annual Environmental Report has been prepared for D0308-01, Caherconlish, in Limerick in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

Upgrades to aeration system.

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Caherconlish WWTP - 2020 with a Plant Capacity PE of 2500, the treatment type is 3P - Tertiary P removal

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF1900D0308SW001	Caherconlish WWTP - 2020	Treated	Non-Compliant	Ammonia-Total (as N) mg/l BOD, 5 days with Inhibition (Carbonaceo mg/l ortho-Phosphate (as P) - unspecified mg/l Suspended Solids mg/l

1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
There are no Licence Specific Reports included in the AER.	

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 CAHERCONLISH WWTP - 2020 - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - CAHERCONLISH WWTP - 2020

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
BOD, 5 days with Inhibition (Carbonaceo mg/l)	6	229	88.78
Suspended Solids mg/l	6	322	107.92
COD-Cr mg/l	6	623	237.66
Hydraulic Capacity	N/A	1501	619

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF1900D0308SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	6	N/A	N/A	32.63	Pass
Suspended Solids mg/l	35	87.5	N/A	6	1	1	17.31	Fail
pH pH units	9	9	N/A	6	N/A	N/A	7.71	Pass
BOD, 5 days with Inhibition (Carbonaceo mg/l	7	14	N/A	6	3	N/A	7.42	Fail
Ammonia-Total (as N) mg/l	0.3	0.6	N/A	6	4	4	9.46	Fail
ortho-Phosphate (as P) - unspecified mg/l	0.15	0.3	N/A	6	2	N/A	0.07	Fail

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

Cause of Exceedance(s):

Mechanical breakdown.

Significance of Results:

Plant has failed two parameters ammonia and suspended solids.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF1900D0308SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	168166, 149693	RS25H030660	No	No	No	No	Moderate
Downstream	168332, 149947	RS25G050030	No	No	No	No	Moderate

The table below provides a summary of monitoring results for designated ambient monitoring points. The upstream and downstream annual mean values are shown (mg/l), and the difference between both monitoring stations is given as a percentage of the Environmental Quality Standard (EQS) where relevant.

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
BOD - 5 days (Total) mg/l	RS25H030660	2	RS25G050030	2.932	1.5	62.1
Ammonia-Total (as N) mg/l	RS25H030660	0.042	RS25G050030	1.804	0.065	2711.1

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
ortho-Phosphate (as P) - unspecified mg/l	RS25H030660	0.081	RS25G050030	0.073	0.035	-23.8
pH pH units	RS25H030660	8.2	RS25G050030	8.1		
Suspended Solids mg/l	RS25H030660	10	RS25G050030	12.75		
Temperature °C	RS25H030660	11.967	RS25G050030	11.867		
Dissolved Oxygen % O2	RS25H030660	93.517	RS25G050030	93.033		

Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results does not meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in Ammonia and BOD, concentrations downstream of the effluent discharge is noted.

The discharge from the wastewater treatment plant does have an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - CAHERCONLISH WWTP - 2020

2.1.4.1 Treatment Efficiency Report - Caherconlish WWTP - 2020

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
SS	24962	4004	84
cBOD	20533	1716	92
TP	N/A	N/A	N/A
TN	N/A	N/A	N/A
COD	54968	7547	86

Note: The above data is based on sample results for the number of dates reported

2.1.4.2 Treatment Capacity Report Summary - Caherconlish WWTP - 2020

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Caherconlish WWTP - 2020	
Peak Hydraulic Capacity (m³/day) - As Constructed	2442
DWF to the Treatment Plant (m³/day)	575
Current Hydraulic Loading - annual max (m³/day)	1501
Average Hydraulic loading to the Treatment Plant (m³/day)	619
Organic Capacity (PE) - As Constructed	2500
Organic Capacity (PE) - Collected Load (peak week)^{Note1}	1628
Organic Capacity (PE) - Remaining	872
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - CAHERCONLISH WWTP - 2020

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2020.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Breach of ELV	Inadequate Infrastructure	1	Yes	No
Spillage	Adverse Weather	1	No	Yes
Spillage	Plant or equipment maintenance at WWTP	1	No	Yes

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Breach of ELV	Dosing pump failure or maintenance at WWTP	1	No	Yes
Uncontrolled release	Adverse Weather	1	No	Yes
Abatement Equipment offline	Plant or equipment breakdown at WWTP	1	No	No
Spillage	Blocked Sewer	1	No	Yes

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2020	7
Number of Incidents reported to the EPA via EDEN in 2020	7
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2020 (No. of events)	Total volume discharged in 2020 (m3)	Monitoring Status
SW002	168216, 149714	Yes	Low	Meeting	Unknown	Unknown	Not Monitored
TBC	168223, 149721	No	Medium	Not Meeting	Unknown	Unknown	Unknown

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	No
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0308-SIP:01	Appropriate works to ensure compliance with the ELV's specified in Schedule A: Discharges and Discharge Monitoring.	C	31/12/2015	Yes	Works Completed		

A summary of the status of any improvements identified by under Condition 5.2 is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
There are no Improvements Programme for this Agglomeration.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
Priority Substances Assessment	Yes	2015	No	

5.1 PRIORITY SUBSTANCES ASSESSMENT

The Priority Substances Assessment Report has been included in the AER 2015

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	Yes

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 06/05/2021

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Katherine Walshe

Acting Head of Environmental Regulation.

7 APPENDIX

Appendix
Appendix 7.1 - Ambient monitoring summary

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish National Grid Reference (Easting, Northing)	EPA Feature Coding Tool code	Receiving Waters Designation (Yes/No)				Current WFD Status	Mean (mg/l)		
			Bathing Water	Drinking Water	FWPM	Shellfish		cBOD	o-Phosphate (as P)	Ammonia (as N)
Upstream Monitoring Point	168063, 149412	RS25H030660					Poor	1.000	0.081	0.033
Downstream Monitoring Point	168323, 149767	RS25G050030	No	No	No	No	Poor	2.300	0.073	1.802
<i>Difference</i>								1.300	-0.008	1.769
EQS								1.500	0.035	0.065
% of EQS								86.667%	-22.857%	2721.538%

River Groody Upstream of Caherconlish WWTP

Location						Parameter					
Station	Station Reference	Station Easting	Station Northing	Sample Reference	Sample Date	Ammonia NH3-N	pH	Biological Oxygen Demand	Dissolved Oxygen % Saturation	Ortho-Phosphate PO4-P	Temperature
						mg/l	pH units	mg/l	% O2	mg/l	Degrees C
U/S Caherconlish STP WDLE26	RS25H030660	168063	149412	20370155	14-Jan-2020	0.1	7.9	1.00	97.5	0.059	7.1
U/S Caherconlish STP WDLE26	RS25H030660	168063	149412	20370971	10-Mar-2020	0.02	8	1.00	89.5	0.055	8.9
U/S Caherconlish STP WDLE26	RS25H030660	168063	149412	20371572	09-Jun-2020	0.02	8.5	1.00	94	0.144	16.5
U/S Caherconlish STP WDLE26	RS25H030660	168063	149412	20371943	14-Jul-2020	0.02	8.3	1.00	91.2	0.13	13.7
U/S Caherconlish STP WDLE26	RS25H030660	168063	149412	20372503	08-Sep-2020	0.02	8.3	1.00	89.9	0.053	16.5
U/S Caherconlish STP WDLE26	RS25H030660	168063	149412	20373317	10-Nov-2020	0.02	8.2	1.00	99	0.045	9.1
		EQS Std	individual value				6-9				
		EQS Std	good status mean			≤0.065	n/a	≤1.5		≤0.035	n/a
		EQS Std	good status 95%ile			≤0.14	n/a	≤2.6	>80, <120	≤0.075	n/a
			mean			0.033	8.2	1.0	93.5	0.081	12.0
			95%ile			0.080	8.5	1.0	98.6	0.141	16.5
			mean compliance			yes	yes	yes	yes	No	
			95%ile compliance			yes	yes	yes	yes	No	--

half of level of detection for statistical purposes
exceeds Surface Waters Regulations good status
Note: Individual results which exceed the good status mean are highlighted in red

River Groody downstream of Caherconlish WWTP

Location						Parameter					
Station	Station Reference	Station Easting	Station Northing	Sample Reference	Sample Date	Ammonia NH3-N	pH	Biological Oxygen Demand	Dissolved Oxygen % Saturation	Ortho-Phosphate PO4-P	Temperature
						mg/l	pH units	mg/l	% O2	mg/l	Degrees C
D/S of Caherconlish STP WDLE RS25G050030	RS25G050030	168323	149767	20370156	14-Jan-2020	0.24	7.9	1	99.2	0.054	7.1
D/S of Caherconlish STP WDLE RS25G050030	RS25G050030	168323	149767	20370972	10-Mar-2020	0.08	7.9	2.13	89.2	0.058	8.9
D/S of Caherconlish STP WDLE RS25G050030	RS25G050030	168323	149767	20371573	09-Jun-2020	10.4	8.2	7.46	90	0.135	16.4
D/S of Caherconlish STP WDLE RS25G050030	RS25G050030	168323	149767	20371944	14-Jul-2020	0.02	8.2	1	89.3	0.096	13.2
D/S of Caherconlish STP WDLE RS25G050030	RS25G050030	168323	149767	20372504	08-Sep-2020	0.05	8.2	1	91.5	0.051	16.6
D/S of Caherconlish STP WDLE RS25G050030	RS25G050030	168323	149767	20373318	10-Nov-2020	0.02	8.2	1	99	0.042	9
		EQS Std	individual value				6-9				
		EQS Std	good status mean			≤0.065	n/a	≤1.5		≤0.035	n/a
		EQS Std	good status 95%ile			≤0.14	n/a	≤2.6	>80, <120	≤0.075	n/a
			mean			1.802	8.1	2.3	93.0	0.073	11.9
			95%ile			7.860	8.2	6.1	99.2	0.125	16.6
			mean compliance			No	yes	No	yes	No	
			95%ile compliance			No	yes	No	yes	No	--

half of level of detection for statistical purposes
exceeds Surface Waters Regulations good status
Note: Individual results which exceed the good status mean are highlighted in red