

Annual Environmental Report

2020



Adare

D0312-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 ADARE WWTP - 2020 - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - ADARE WWTP - 2020
 - 2.1.2 EFFLUENT MONITORING SUMMARY - ADARE WWTP - 2020 -
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR ADARE WWTP - 2020
 - 2.1.5 SLUDGE/OTHER INPUTS TO ADARE WWTP - 2020

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

- 7.1 AMBIENT MONITORING SUMMARY

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

This Annual Environmental Report has been prepared for D0312-01, Adare, in Limerick in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

New Ferric Dosing Installed.

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- ADARE WWTP - 2020 with a Plant Capacity PE of 2500, the treatment type is 3P - Tertiary P removal

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF1900D0312SW001	ADARE WWTP - 2020	Treated	Non-Compliant	Ammonia-Total (as N) mg/l Total Nitrogen mg/l

1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
There are no Licence Specific Reports included in the AER.	

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 ADARE WWTP - 2020 - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - ADARE WWTP - 2020

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
BOD, 5 days with Inhibition (Carbonaceo mg/l)	12	416	164.54
Total Nitrogen mg/l	12	53.7	26.19
COD-Cr mg/l	12	818	380.11
Suspended Solids mg/l	12	430	229.11
Total Phosphorus (as P) mg/l	12	7.73	3.76
Hydraulic Capacity	N/A	1789	333

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF1900D0312SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	12	1	N/A	36.63	Pass
Suspended Solids mg/l	35	87.5	N/A	12	1	N/A	14.41	Pass
BOD, 5 days with Inhibition (Carbonaceous) mg/l	25	50	N/A	12	1	N/A	6.52	Pass
Total Nitrogen mg/l	15	18	N/A	12	5	3	10.97	Fail
pH pH units	9	9	N/A	12	N/A	N/A	7.99	Pass
ortho-Phosphate (as P) - unspecified mg/l	1	1.2	N/A	12	N/A	N/A	0.16	Pass
Ammonia-Total (as N) mg/l	0.5	1	N/A	12	2	2	1.53	Fail
Total Oxidised Nitrogen (as N) mg/l	N/A	N/A	N/A	12	N/A	N/A	7.49	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

Cause of Exceedance(s):

PLC problem with this plant.

Significance of Results:

Two ammonia breaches.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF1900D0312SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	147364, 146036	RS24M010960	No	No	No	No	Unassigned
Downstream	145979, 146639	TW36004127SN6001	No	No	No	No	Moderate

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**

Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results does not meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - ADARE WWTP - 2020

2.1.4.1 Treatment Efficiency Report - ADARE WWTP - 2020

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
TN	3683	1990	46
cBOD	23139	1183	95
TP	528	N/A	N/A
COD	53453	6646	88
SS	32219	2615	92

Note: The above data is based on sample results for the number of dates reported

2.1.4.2 Treatment Capacity Report Summary - ADARE WWTP - 2020

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

ADARE WWTP - 2020	
Peak Hydraulic Capacity (m ³ /day) - As Constructed	1608
DWF to the Treatment Plant (m ³ /day)	450
Current Hydraulic Loading - annual max (m ³ /day)	1789

ADARE WWTP - 2020	
Average Hydraulic loading to the Treatment Plant (m ³ /day)	333
Organic Capacity (PE) - As Constructed	2500
Organic Capacity (PE) - Collected Load (peak week) ^{Note1}	2137
Organic Capacity (PE) - Remaining	363
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - ADARE WWTP - 2020

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2020.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Breach of ELV	Inadequate Infrastructure	1	Yes	No
Abatement Equipment offline	Plant or equipment breakdown at WWTP	1	No	Yes
Spillage	Adverse Weather	1	No	Yes

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Abatement Equipment offline	Plant or equipment breakdown at WWTP	1	No	Yes
Spillage	Plant or equipment breakdown at WWTP	1	Yes	No

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2020	5
Number of Incidents reported to the EPA via EDEN in 2020	5
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2020 (No. of events)	Total volume discharged in 2020 (m3)	Monitoring Status
TBC	145962, 146457	No	Low	Meeting	Unknown	Unknown	Not Monitored

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	No
The SWO Assessment included the requirements of relevant of WWDL schedules?	No
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	No

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NAY)	Status of Works	Timeframe for Completing the Work	Comments
D0312-SIP:01	Grease removal at WWTP	C	01/01/2014	Yes	Works Completed		
D0312-SIP:02	Outfall And flap valve repair	C	01/01/2014	Yes	At Planning Stage		
D0312-SIP:03	Storm water holding facilities at WWTP	C	01/01/2014	Yes	At Planning Stage		

A summary of the status of any improvements identified by under Condition 5.2 is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
There are no Improvements Programme for this Agglomeration.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
There is no Licence Specific Report Required in this AER Annual Review.				

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	Yes

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 06/05/2021

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Katherine Walshe

Acting Head of Environmental Regulation.

7 APPENDIX

Appendix
Appendix 7.1 - Ambient monitoring summary

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish National Grid Reference (Easting, Northing)	EPA Feature Coding Tool code	Receiving Waters Designation (Yes/No)				Current WFD Status	Mean (mg/l)		
			Bathing Water	Drinking Water	FWPM	Shellfish		cBOD	o-Phosphate (as P)	Ammonia (as N)
Upstream Monitoring Point	147363, 146037	RS24M010960					Moderate	1.200	0.066	0.037
Downstream Monitoring Point	145979, 146639	TW36004127SN6001	No	No	No	No	Moderate	1.300	0.062	0.051
<i>Difference</i>								0.100	-0.004	0.014
EQS								1.500	0.035	0.065
% of EQS								6.667%	-11.429%	21.538%

Adare Upstream

Location						Parameter						
Station	Station Reference	Station Easting	Station Northing	Sample Reference	Sample Date	Ammonia NH3-N	pH	Biological Oxygen Demand	Dissolved Oxygen % Saturated	Ortho-Phosphate PO4-P	Temperature	
						mg/l	pH units	mg/l	% O2	mg/l	Degrees C	
WDLM25	Maigue Adare Manor u/s Adare STP	RS24M010960	147363	146037	20370166	14-Jan-2020	0.14	8.1	2.3	91	0.109	6.1
WDLM25	Maigue Adare Manor u/s Adare STP	RS24M010960	147363	146037	20370524	11-Feb-2020	0.05	7.8		81	0.12	4.6
WDLM25	Maigue Adare Manor u/s Adare STP	RS24M010960	147363	146037	20370980	10-Mar-2020	0.07	8.1	2.17	90	0.094	9.2
WDLM25	Maigue Adare Manor u/s Adare STP	RS24M010960	147363	146037	20371283	05-May-2020	0.02	8.4	1	95.6	0.02	9
WDLM25	Maigue Adare Manor u/s Adare STP	RS24M010960	147363	146037	20371339	12-May-2020	0.02	8.2	1	106	0.021	11.3
WDLM25	Maigue Adare Manor u/s Adare STP	RS24M010960	147363	146037	20371581	09-Jun-2020	0.02	8.3	1	103	0.01	13.2
WDLM25	Maigue Adare Manor u/s Adare STP	RS24M010960	147363	146037	20371952	14-Jul-2020	0.02	8.4	1	97.1	0.065	15.5
WDLM25	Maigue Adare Manor u/s Adare STP	RS24M010960	147363	146037	20372215	11-Aug-2020	0.02	8.3	1	94.7	0.087	17.1
WDLM25	Maigue Adare Manor u/s Adare STP	RS24M010960	147363	146037	20372514	08-Sep-2020	0.02	8.2	1	97	0.088	15.7
WDLM25	Maigue Adare Manor u/s Adare STP	RS24M010960	147363	146037	20372845	06-Oct-2020	0.02	8.3	1	96.9	0.047	11.4
WDLM25	Maigue Adare Manor u/s Adare STP	RS24M010960	147363	146037	20373328	10-Nov-2020	0.02	8.2	1	101	0.078	11
WDLM25	Maigue Adare Manor u/s Adare STP	RS24M010960	147363	146037	20373648	08-Dec-2020	0.02	8.2	1	96.5	0.058	5.5
EQS Std	individual value						6-9					
EQS Std	good status mean					≤0.065	n/a	≤1.5		≤0.035	n/a	
EQS Std	good status 95%ile					≤0.14	n/a	≤2.6	>80, <120	≤0.075	n/a	
	mean					0.037	8.2	1.2	95.8	0.066	10.8	
	95%ile					0.102	8.4	2.2	104.4	0.114	16.3	
	mean compliance					yes	yes	yes	yes	No		
	95%ile compliance					yes	yes	yes	yes	No	--	

half of level of detection for statistical purposes

exceeds Surface Waters Regulations good status

Note: Individual results which exceed the good status mean are highlighted in red

Adare Downstream

Location						Parameter						
Station	Station Reference	Station Easting	Station Northing	Sample Reference	Sample Date	Ammonia NH3-N	pH	Biological Oxygen Demand	Dissolved Oxygen % Saturated	Ortho-Phosphate PO4-P	Temperature	
						mg/l	pH units	mg/l	% O2	mg/l	Degrees C	
Maigue Railway Br d/s Adare STP Adare WDLM2 TW36004127SN6001	145979	146639	20370165	14-Jan-2020		0.32	8.1	3.17	92	0.122	6.2	
Maigue Railway Br d/s Adare STP Adare WDLM2 TW36004127SN6001	145979	146639	20370523	11-Feb-2020		0.02	7.9		81	0.117	4.4	
Maigue Railway Br d/s Adare STP Adare WDLM2 TW36004127SN6001	145979	146639	20370979	10-Mar-2020		0.07	8	2.24	88	0.092	8.8	
Maigue Railway Br d/s Adare STP Adare WDLM2 TW36004127SN6001	145979	146639	20371282	05-May-2020		0.02	8.4	1	99.2	0.014	9.1	
Maigue Railway Br d/s Adare STP Adare WDLM2 TW36004127SN6001	145979	146639	20371338	12-May-2020		0.02	8.2	1	88	0.017	12.1	
Maigue Railway Br d/s Adare STP Adare WDLM2 TW36004127SN6001	145979	146639	20371580	09-Jun-2020		0.02	8.3	1	102	0.011	14.2	
Maigue Railway Br d/s Adare STP Adare WDLM2 TW36004127SN6001	145979	146639	20371951	14-Jul-2020		0.02	8.4	1	126	0.044	15.4	
Maigue Railway Br d/s Adare STP Adare WDLM2 TW36004127SN6001	145979	146639	20372214	11-Aug-2020		0.02	8.3	1	92	0.089	14.8	
Maigue Railway Br d/s Adare STP Adare WDLM2 TW36004127SN6001	145979	146639	20372513	08-Sep-2020		0.04	8.3	1	93	0.08	10.9	
Maigue Railway Br d/s Adare STP Adare WDLM2 TW36004127SN6001	145979	146639	20373327	10-Nov-2020		0.02	8.2	1	98.1	0.075	8.4	
Maigue Railway Br d/s Adare STP Adare WDLM2 TW36004127SN6001	145979	146639	20373647	08-Dec-2020		0.02	8.2	1	97.6	0.057	10.6	
WDLE 22 Pontoon at boat club d/s Castletroy ST RS25S012570	160519	158490	20373642	08-Dec-2020		0.02	8	1	95.6	0.021	5.7	
EQS Std	individual value						6-9					
EQS Std	good status mean					≤0.065	n/a	≤1.5		≤0.035	n/a	
EQS Std	good status 95%ile					≤0.14	n/a	≤2.6	>80, <120	≤0.075	n/a	
	mean					0.051	8.2	1.3	96.0	0.062	10.1	
	95%ile					0.183	8.4	2.7	112.8	0.119	15.1	
	mean compliance					yes	yes	yes	yes	No		
	95%ile compliance					No	yes	No	yes	No	--	

half of level of detection for statistical purposes

exceeds Surface Waters Regulations good status

Note: Individual results which exceed the good status mean are highlighted in red