

# Annual Environmental Report

2020



St Johnston

D0538-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 ST. JOHNSTON WWTP - 2020 - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - ST. JOHNSTON WWTP - 2020
  - 2.1.2 EFFLUENT MONITORING SUMMARY - ST. JOHNSTON WWTP - 2020 -
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR ST. JOHNSTON WWTP - 2020
  - 2.1.5 SLUDGE/OTHER INPUTS TO ST. JOHNSTON WWTP - 2020

### **3 COMPLAINTS SUMMARY**

- 3.1 REPORTED INCIDENTS SUMMARY
  - 3.1.1 SUMMARY OF INCIDENTS
  - 3.1.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

- 5.1 PRIORITY SUBSTANCES ASSESSMENT

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

### **7 APPENDIX**

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

This Annual Environmental Report has been prepared for D0538-01, St Johnston, in Donegal in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

WWTP Upgrade works completed. DBO Process proving completed. Plant handed over to LA Ops to operate plant in 2020.

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- St. Johnston WWTP - 2020 with a Plant Capacity PE of 1050, the treatment type is 3NP - Tertiary N&P removal

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF0600D0538SW001	St. Johnston WWTP - 2020	Treated	Non-Compliant	Suspended Solids mg/l

## 1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
<b>There are no Licence Specific Reports included in the AER.</b>	

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 ST. JOHNSTON WWTP - 2020 - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - ST. JOHNSTON WWTP - 2020

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
<b>BOD, 5 days with Inhibition (Carbonaceo mg/l)</b>	6	342	135.28
<b>COD-Cr mg/l</b>	6	568	237.98
<b>Suspended Solids mg/l</b>	6	1728	474.79
<b>Hydraulic Capacity</b>	N/A	981	244

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

#### **Significance of Results:**

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

## 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF0600D0538SW002

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>COD-Cr mg/l</b>	125	250	N/A	6	N/A	N/A	49.02	Pass
<b>Suspended Solids mg/l</b>	35	87.5	N/A	6	1	1	59.1	Fail
<b>BOD, 5 days with Inhibition (Carbonaceo mg/l</b>	25	50	N/A	6	1	N/A	12.38	Pass
<b>Total Oxidised Nitrogen (as N) mg/l</b>	15	18	N/A	6	N/A	N/A	4.46	Pass
<b>Ammonia-Total (as N) mg/l</b>	10	12	N/A	6	N/A	N/A	1.25	Pass
<b>pH pH units</b>	9	9	N/A	6	N/A	N/A	7.11	Pass
<b>ortho-Phosphate (as P) - unspecified mg/l</b>	8	9.6	N/A	6	N/A	N/A	1.09	Pass
<b>Nitrite (as N) mg/l</b>	N/A	N/A	N/A	6	N/A	N/A	0.05	
<b>Nitrate (as N) mg/l</b>	N/A	N/A	N/A	6	N/A	N/A	4.4	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>Conductivity @20°C µS/cm</b>	N/A	N/A	N/A	6	N/A	N/A	361.81	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

### Cause of Exceedance(s):

ELV Exceedance caused due to location of composite sampler point. Additional maintenance required at sampling point chamber and to sampling line.

### Significance of Results:

The WWTP is non compliant with the ELV's set in the Wastewater Discharge Licence for 2020.

## 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF0600D0538SW002

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
<b>Upstream</b>	234223, 410072	RS01S010260	No	No	No	No	Poor

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	234796, 409888	RS01S010300	No	No	No	No	Poor
Downstream	234562, 409921	RS01S010280	No	No	No	No	Poor
Downstream	234908, 409786	RS01S010400	No	No	No	No	Poor

The table below provides a summary of monitoring results for designated ambient monitoring points. The upstream and downstream annual mean values are shown (mg/l), and the difference between both monitoring stations is given as a percentage of the Environmental Quality Standard (EQS) where relevant.

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
BOD - 5 days (Total) mg/l	RS01S010300	1.67	RS01S010280	1.02	1.5	
BOD - 5 days (Total) mg/l	RS01S010260	1	RS01S010400	1.17	1.5	
BOD - 5 days (Total) mg/l	RS01S010260	1	RS01S010280	1.02	1.5	
BOD - 5 days (Total) mg/l	RS01S010300	1.67	RS01S010400	1.17	1.5	
Ammonia-Total (as N) mg/l	RS01S010300	0.05	RS01S010280	0.04	0.07	
Ammonia-Total (as N) mg/l	RS01S010300	0.05	RS01S010400	0.05	0.07	
Ammonia-Total (as N) mg/l	RS01S010260	0.04	RS01S010280	0.04	0.07	

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
<b>Ammonia-Total (as N) mg/l</b>	RS01S010260	0.04	RS01S010400	0.05	0.07	
<b>ortho-Phosphate (as P) - unspecified mg/l</b>	RS01S010300	0.05	RS01S010400	0.05	0.04	
<b>ortho-Phosphate (as P) - unspecified mg/l</b>	RS01S010260	0.04	RS01S010280	0.04	0.04	
<b>ortho-Phosphate (as P) - unspecified mg/l</b>	RS01S010260	0.04	RS01S010400	0.05	0.04	
<b>ortho-Phosphate (as P) - unspecified mg/l</b>	RS01S010300	0.05	RS01S010280	0.04	0.04	
<b>Dissolved Oxygen % Saturation</b>	RS01S010260	98.75	RS01S010400	101.9		
<b>Dissolved Oxygen % Saturation</b>	RS01S010300	95.77	RS01S010400	101.9		
<b>Dissolved Oxygen % Saturation</b>	RS01S010300	95.77	RS01S010280	98.22		
<b>Dissolved Oxygen % Saturation</b>	RS01S010260	98.75	RS01S010280	98.22		
<b>Temperature °C</b>	RS01S010260	11	RS01S010280	10.03		
<b>Suspended Solids mg/l</b>	RS01S010260	10	RS01S010400	9		
<b>Temperature °C</b>	RS01S010300	11.17	RS01S010280	10.03		

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
Temperature °C	RS01S010300	11.17	RS01S010400	11.45		
Suspended Solids mg/l	RS01S010300	9.5	RS01S010400	9		
Suspended Solids mg/l	RS01S010260	10	RS01S010280	9.17		
Nitrite (as N) mg/l	RS01S010260	0.01	RS01S010280	0.01		
Temperature °C	RS01S010260	11	RS01S010400	11.45		
pH pH units	RS01S010260	7.83	RS01S010280	7.76		
Suspended Solids mg/l	RS01S010300	9.5	RS01S010280	9.17		
Nitrate (as N) mg/l	RS01S010260	1.68	RS01S010280	1.72		
Conductivity @20°C µS/cm	RS01S010300	327	RS01S010400	329.5		
Nitrate (as N) mg/l	RS01S010260	1.68	RS01S010400	1.76		
Conductivity @20°C µS/cm	RS01S010300	327	RS01S010280	321.17		
Nitrate (as N) mg/l	RS01S010300	1.72	RS01S010400	1.76		
Conductivity @20°C µS/cm	RS01S010260	325.83	RS01S010400	329.5		
Conductivity @20°C µS/cm	RS01S010260	325.83	RS01S010280	321.17		
Nitrate (as N) mg/l	RS01S010300	1.72	RS01S010280	1.72		

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
Nitrite (as N) mg/l	RS01S010300	0.01	RS01S010400	0.01		
Nitrite (as N) mg/l	RS01S010260	0.01	RS01S010400	0.01		
pH pH units	RS01S010260	7.83	RS01S010400	7.73		
pH pH units	RS01S010300	7.67	RS01S010400	7.73		
pH pH units	RS01S010300	7.67	RS01S010280	7.76		
Total Oxidised Nitrogen (as N) mg/l	RS01S010300	1.74	RS01S010400	1.77		
Nitrite (as N) mg/l	RS01S010300	0.01	RS01S010280	0.01		
Total Oxidised Nitrogen (as N) mg/l	RS01S010260	1.39	RS01S010400	1.77		
Total Oxidised Nitrogen (as N) mg/l	RS01S010260	1.39	RS01S010280	1.73		
Total Oxidised Nitrogen (as N) mg/l	RS01S010300	1.74	RS01S010280	1.73		

### Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results does not meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - ST. JOHNSTON WWTP - 2020

### 2.1.4.1 Treatment Efficiency Report - St. Johnston WWTP - 2020

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
TP	N/A	N/A	N/A
cBOD	12040	1168	90
COD	21180	4628	78
SS	42256	5580	87
TN	N/A	N/A	N/A

Note: The above data is based on sample results for the number of dates reported

### 2.1.4.2 Treatment Capacity Report Summary - St. Johnston WWTP - 2020

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

St. Johnston WWTP - 2020	
Peak Hydraulic Capacity (m <sup>3</sup> /day) - As Constructed	1050
DWF to the Treatment Plant (m <sup>3</sup> /day)	0
Current Hydraulic Loading - annual max (m <sup>3</sup> /day)	981

St. Johnston WWTP - 2020	
Average Hydraulic loading to the Treatment Plant (m <sup>3</sup> /day)	244
Organic Capacity (PE) - As Constructed	1050
Organic Capacity (PE) - Collected Load (peak week) <sup>Note1</sup>	338
Organic Capacity (PE) - Remaining	712
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

## 2.1.5 SLUDGE / OTHER INPUTS - ST. JOHNSTON WWTP - 2020

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

## 3 COMPLAINTS AND INCIDENTS

### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
<b>There were no relevant environmental complaints in 2020.</b>			

### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Other	Other	1	No	No

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2020	1
Number of Incidents reported to the EPA via EDEN in 2020	1
Explanation of any discrepancies between the two numbers above	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2020 (No. of events)	Total volume discharged in 2020 (m3)	Monitoring Status
SW003	234997, 409755	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
SW004	234921, 409752	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	Yes
The SWO Assessment included the requirements of relevant of WWDL schedules?	No
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0538-SIP:01</b>	Provide appropriate treatment to ensure compliance with the emission limit values as specified in Schedule A: Discharges and Discharge Monitoring.	C	31/12/2019	Yes	Works Completed		

A summary of the status of any improvements identified by under Condition 5.2 is included below.

### 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
<b>There are no Improvements Programme for this Agglomeration.</b>				

### **4.2.3 SEWER INTEGRITY RISK ASSESSMENT**

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.

## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
Priority Substances Assessment	Yes	2015	No	

### 5.1 PRIORITY SUBSTANCES ASSESSMENT

The Priority Substances Assessment Report has been included in the AER 2015

## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	Yes

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed:    Date: 12/07/2021

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Katherine Walshe

Acting Head of Environmental Regulation.

## **7 APPENDIX**

There are no Appendices included