

# Annual Environmental Report

2021



Athlone

D0007-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2021 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 ATHLONE WWTP - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - ATHLONE WWTP
  - 2.1.2 EFFLUENT MONITORING SUMMARY - ATHLONE WWTP -
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR ATHLONE WWTP
  - 2.1.5 SLUDGE/OTHER INPUTS TO ATHLONE WWTP

### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

### **7 APPENDIX**

- 7.1 AMBIENT MONITORING SUMMARY

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2021 AER

This Annual Environmental Report has been prepared for D0007-01, Athlone, in Westmeath in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There were no capital works, significant changes or operational improvements undertaken in 2021.

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Athlone WWTP with a Plant Capacity PE of 36000, the treatment type is 3P - Tertiary P removal.

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

| Discharge Point Reference | Treatment Plant | Discharge Type | Compliance Status | Parameters failing if relevant |
|---------------------------|-----------------|----------------|-------------------|--------------------------------|
| TPEFF3200D0007SW001       | Athlone WWTP    | Treated        | Compliant         | N/A                            |

## 1.4 LICENCE SPECIFIC REPORTING

| Assessment / Report  |
|--|
| <b>There are no Licence Specific Reports included in this AER.</b> |

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 ATHLONE WWTP - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - ATHLONE WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

| Parameters                                      | Number of Samples | Annual Max | Annual Mean |
|---|-------------------|------------|-------------|
| Ammonia-Total (as N) mg/l                       | 12                | 37         | 12          |
| ortho-Phosphate (as P) - unspecified mg/l       | 12                | 2.82       | 0.969       |
| BOD - 5 days (Total) mg/l                       | 12                | 507        | 78          |
| Total Phosphorus (as P) mg/l                    | 12                | 3.85       | 1.78        |
| COD-Cr mg/l                                     | 12                | 404        | 142.26      |
| Suspended Solids mg/l                           | 12                | 175        | 39.07       |
| BOD, 5 days with Inhibition (Carbonaceous) mg/l | 12                | 166        | 58          |
| Total Nitrogen mg/l                             | 12                | 62         | 18          |
| pH pH units                                     | 12                | 7.80       | 7.43        |

| Parameters         | Number of Samples | Annual Max | Annual Mean |
|--------------------|-------------------|------------|-------------|
| Hydraulic Capacity | N/A               | 20930      | 11278       |

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

### Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

## 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF3200D0007SW001

| Parameter                                       | WWDL ELV (Schedule A) | ELV with Condition 2 Interpretation included <sup>Note 1</sup> | Interim % reduction from influent concentration | Number of sample results | Number of exceedances | Number of exceedances with Condition 2 Interpretation included | Annual Mean | Overall Compliance (Pass/Fail) |
|---|-----------------------|--|---|--------------------------|-----------------------|--|-------------|--------------------------------|
| COD-Cr mg/l                                     | 125                   | 250  | N/A   | 12                       | N/A                   | N/A  | 29          | Pass                           |
| Suspended Solids mg/l                           | 35                    | 87.5   | N/A   | 12                       | N/A                   | N/A  | 6.14        | Pass                           |
| BOD, 5 days with Inhibition (Carbonaceous) mg/l | 25                    | 50   | N/A   | 12                       | N/A                   | N/A  | 3.45        | Pass                           |
| pH pH units                                     | 6.00                  | 9.00   | N/A   | 12                       | N/A                   | N/A  | 7.54        | Pass                           |
| Ammonia-Total (as N) mg/l                       | 5.00                  | 6.00   | N/A   | 12                       | N/A                   | N/A  | 0.075       | Pass                           |

| Parameter  | WWDL ELV (Schedule A) | ELV with Condition 2 Interpretation included <sup>Note 1</sup> | Interim % reduction from influent concentration | Number of sample results | Number of exceedances | Number of exceedances with Condition 2 Interpretation included | Annual Mean | Overall Compliance (Pass/Fail) |
|--|-----------------------|--|---|--------------------------|-----------------------|--|-------------|--------------------------------|
| <b>Total Phosphorus (as P) mg/l</b>              | 2.00                  | 2.40   | N/A   | 12                       | N/A                   | N/A  | 0.270       | Pass                           |
| <b>Total Oxidised Nitrogen (as N) mg/l</b>       | N/A                   | N/A  | N/A   | 11                       | N/A                   | N/A  | 7.73        |                                |
| <b>Nitrate (as N) mg/l</b>                       | N/A                   | N/A  | N/A   | 12                       | N/A                   | N/A  | 7.03        |                                |
| <b>Total Nitrogen mg/l</b>                       | N/A                   | N/A  | N/A   | 12                       | N/A                   | N/A  | 9.52        |                                |
| <b>ortho-Phosphate (as P) - unspecified mg/l</b> | N/A                   | N/A  | N/A   | 12                       | N/A                   | N/A  | 0.107       |                                |
| <b>Conductivity @20°C µS/cm</b>                  | N/A                   | N/A  | N/A   | 12                       | N/A                   | N/A  | 516         |                                |
| <b>Nitrite (as N) mg/l</b>                       | N/A                   | N/A  | N/A   | 12                       | N/A                   | N/A  | 0.092       |                                |

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

### Cause of Exceedance(s):

Not applicable

## Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

### 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF3200D0007SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

| Ambient Monitoring Point from WWDL (or as agreed with EPA) | Irish Grid Reference | River Station Code | Bathing Water | Drinking Water | FWPM | Shellfish | WFD Ecological Status |
|--|----------------------|--------------------|---------------|----------------|------|-----------|-----------------------|
| Upstream   | 204112, 240975       | RS26S021706        | No            | No             | No   | No        | Poor                  |
| Downstream   | 204008, 240237       | RS26S021725        | No            | Yes            | No   | No        | Poor                  |

*\*It should be noted that Irish Waste is unable to access the downstream sampling location as prescribed under Schedule B.3 Ambient Monitoring. The lands adjacent to all the sample locations are underwater for at least a period of 6-8 months of the year. Westmeath County Council/Irish Water are in the process of selecting a suitable alternative downstream monitoring point.*

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**.

## Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

Based on ELV compliance, it is not considered that the discharge from the wastewater treatment plant is having an observable impact on the water quality.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - ATHLONE WWTP

### 2.1.4.1 Treatment Efficiency Report - Athlone WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

| Parameter | Influent mass loading (kg/year) | Effluent mass emission (kg/year) | Efficiency (% reduction of influent load) |
|-----------|---------------------------------|----------------------------------|---|
| TP        | 7315                            | 1218                             | 83  |
| TN        | 75438                           | 42996                            | 43  |
| SS        | 160212                          | 27732                            | 83  |
| COD       | 583302                          | 131952                           | 77  |
| cBOD      | 238742                          | 15578                            | 93  |

Note: The above data is based on sample results for the number of dates reported

### 2.1.4.2 Treatment Capacity Report Summary - Athlone WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

| Athlone WWTP   |       |
|--|-------|
| Peak Hydraulic Capacity (m <sup>3</sup> /day) - As Constructed | 20250 |
| DWF to the Treatment Plant (m <sup>3</sup> /day)               | 6750  |
| Current Hydraulic Loading - annual max (m <sup>3</sup> /day)   | 20930 |

| Athlone WWTP   |          |
|--|----------|
| Average Hydraulic loading to the Treatment Plant (m <sup>3</sup> /day) | 11278.46 |
| Organic Capacity (PE) - As Constructed                                 | 36000    |
| Organic Capacity (PE) - Collected Load (peak week) <sup>Note1</sup>    | 22556    |
| Organic Capacity (PE) - Remaining                                      | 13444    |
| Will the capacity be exceeded in the next three years? (Yes/No)        | No       |

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

## 2.1.5 SLUDGE / OTHER INPUTS - ATHLONE WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

| Input type                              | Quantity | Unit                     | P.E. | % of load to WWTP | Included in Influent Monitoring (Y/N)? | Is there a leachate/sludge acceptance procedure for the WWTP? | Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N) |
|---|----------|--------------------------|------|-------------------|--|---|--|
| Landfill Leachate (delivered by tanker) | 3372     | Volume (m <sup>3</sup> ) | 41.5 | 0.1               | Yes                                    | Yes   | Yes  |
| Waterworks Sludge                       | 8162     | Volume (m <sup>3</sup> ) | 100  | 0.2               | Yes                                    | Yes   | Yes  |

## 3 COMPLAINTS AND INCIDENTS

### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

| Number of Complaints | Nature of Complaint | Number Open Complaints | Number Closed Complaints |
|----------------------|---------------------|------------------------|--------------------------|
| 1                    | Discharge to waters | 0                      | 1                        |

### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

### 3.2.1 SUMMARY OF INCIDENTS

| Incident Type               | Cause                                | No. of incident occurrences | Recurring (Y/N) | Closed (Y/N) |
|-----------------------------|--------------------------------------|-----------------------------|-----------------|--------------|
| Abatement Equipment offline | Plant or equipment breakdown at WWTP | 1                           | No              | No           |
| Uncontrolled release        | Network Infrastructure               | 1                           | No              | Yes          |
| Uncontrolled release        | EO caused by power failure           | 1                           | No              | Yes          |

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

| Question   | Answer |
|--|--------|
| Number of Incidents in 2021                                    | 3      |
| Number of Incidents reported to the EPA via EDEN in 2021       | 3      |
| Explanation of any discrepancies between the two numbers above | N/A    |

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

| WWDL Name / Code for Storm Water Overflow (chamber) where applicable | Irish Grid Ref. (outfall) | Included in Schedule of the WWDL | Significance of the overflow(High / Medium / Low) | Assessed against DoEHLG Criteria | No. of times activated in 2021 (No. of events) | Total volume discharged in 2021 (m <sup>3</sup> ) | Monitoring Status |
|--|---------------------------|----------------------------------|---|----------------------------------|--|---|-------------------|
| <b>S.0.16</b>  | 204640, 241085            | Yes                              | Medium  | Meeting                          | Unknown  | Unknown   | Not Monitored     |
| <b>S.0.17</b>  | 204640, 241085            | Yes                              | Medium  | Meeting                          | Unknown  | Unknown   | Not Monitored     |
| <b>S.0.2</b>   | 204640, 241085            | Yes                              | Medium  | Meeting                          | Unknown  | Unknown   | Not Monitored     |
| <b>S.O.11</b>  | 203477, 242023            | Yes                              | Medium  | Meeting                          | Unknown  | Unknown   | Not Monitored     |
| <b>S.O.8</b>   | 203631, 240857            | Yes                              | Medium  | Meeting                          | Unknown  | Unknown   | Not Monitored     |
| <b>S014</b>  | 203564, 242099            | Yes                              | Medium  | Meeting                          | Unknown  | Unknown   | Not Monitored     |

| WWDL Name / Code for Storm Water Overflow (chamber) where applicable | Irish Grid Ref. (outfall) | Included in Schedule of the WWDL | Significance of the overflow(High / Medium / Low) | Assessed against DoEHLG Criteria | No. of times activated in 2021 (No. of events) | Total volume discharged in 2021 (m <sup>3</sup> ) | Monitoring Status |
|--|---------------------------|----------------------------------|---|----------------------------------|--|---|-------------------|
| <b>S04</b>   | 204022, 242676            | Yes                              | Medium  | Meeting                          | Unknown  | Unknown   | Not Monitored     |
| <b>SW005</b>   | 203685, 242668            | Yes                              | Medium  | Meeting                          | Unknown  | Unknown   | Not Monitored     |
| <b>SW009</b>   | 203202, 241788            | Yes                              | Medium  | Meeting                          | Unknown  | Unknown   | Not Monitored     |
| <b>SW010</b>   | 203126, 241986            | Yes                              | Medium  | Meeting                          | Unknown  | Unknown   | Not Monitored     |

| SWO Summary   |         |
|---|---------|
| How much sewage was discharged via monitored SWOs in the agglomeration in the year (m <sup>3</sup> )? | Unknown |
| Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?      | N/A     |
| The SWO Assessment included the requirements of relevant of WWDL schedules?                           | Yes     |
| Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7? | N/A     |

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

| Specified Improvement Programmes (under Schedule A and C of WWDL) | Description   | Licence Schedule | Licence Completion Date | Date Expired? (N/NAY) | Status of Works   | Timeframe for Completing the Work | Comments |
|---|---|------------------|-------------------------|-----------------------|-------------------|-----------------------------------|----------|
| <b>D0007-SIP:01</b>   | Installation of Abbey Road to Golden Island tunnel sewer  | C                | 31/05/2011              | Yes                   | At Planning Stage | 31/12/2025                        |          |
| <b>D0007-SIP:02</b>   | Installation of new Coosan pumping station and installation of new rising main and new sewer to Abbey Road                              | C                | 31/05/2011              | Yes                   | At Planning Stage | 31/12/2025                        |          |
| <b>D0007-SIP:03</b>   | Installation of storm water storage tank at Golden Island pumping station and associated rising main to WWTP                            | C                | 31/05/2011              | Yes                   | At Planning Stage | 31/12/2025                        |          |
| <b>D0007-SIP:04</b>   | Rehabilitation of sewers including installation of Roslevin Lawns surface water culvert , completion of A1 river improvement scheme and | C                | 31/12/2014              | Yes                   | At Planning Stage | 31/12/2025                        |          |

| Specified Improvement Programmes (under Schedule A and C of WWDL) | Description   | Licence Schedule | Licence Completion Date | Date Expired? (N/NAY) | Status of Works   | Timeframe for Completing the Work | Comments |
|---|---|------------------|-------------------------|-----------------------|-------------------|-----------------------------------|----------|
|   | installation of Retreat Road surface water sewer                            |                  |                         |                       |                   |                                   |          |
| <b>D0007-SIP:05</b>   | SW019 (204156E, 241041N) (formerly S.O.1)                                   | C                | 31/05/2011              | Yes                   | At Planning Stage | 31/12/2025                        |          |
| <b>D0007-SIP:06</b>   | Discharge to discontinue: SW010, Location 203111E 241984N (Athlone Canal)   | A                | 30/11/2011              | Yes                   | At Planning Stage | 31/12/2025                        |          |
| <b>D0007-SIP:07</b>   | Discharge to discontinue: SW014, Location 203716E 242200N (River Shannon)   | A                | 30/11/2011              | Yes                   | At Planning Stage | 31/12/2025                        |          |
| <b>D0007-SIP:08</b>   | SW015 (204040E, 240941N) formerly (S.O.15)                                  | C                | 30/11/2011              | Yes                   | At Planning Stage | 31/12/2025                        |          |
| <b>D0007-SIP:09</b>   | Discharge to discontinue: SW003, Location - 203943E 241685N (River Shannon) | A                | 31/05/2011              | Yes                   | At Planning Stage | 31/12/2025                        |          |
| <b>D0007-SIP:10</b>   | Discharge to discontinue: SW004, Location - 204328E 242628N (River Shannon) | A                | 31/05/2011              | Yes                   | At Planning Stage | 31/12/2025                        |          |
| <b>D0007-SIP:11</b>   | Discharge to discontinue: SW005, Location 203685E 242655N (River Shannon)   | A                | 31/05/2011              | Yes                   | At Planning Stage | 31/12/2025                        |          |
| <b>D0007-SIP:12</b>   | SW007 (203984E, 241226N) formerly S.O.7                                     | C                | 30/11/2011              | Yes                   | At Planning Stage | 31/12/2025                        |          |

| Specified Improvement Programmes (under Schedule A and C of WWDL) | Description   | Licence Schedule | Licence Completion Date | Date Expired? (N/N/A/Y) | Status of Works   | Timeframe for Completing the Work | Comments |
|---|---|------------------|-------------------------|-------------------------|-------------------|-----------------------------------|----------|
| <b>D0007-SIP:13</b>   | Discharge to discontinue: SW009, Location 203198E 241781N (Athlone Canal)   | A                | 30/11/2011              | Yes                     | At Planning Stage | 31/12/2025                        |          |
| <b>D0007-SIP:14</b>   | Upgrade and replacement of West Bank, West Side, Canal and Siphon sewers, upgrade of sewer connection to Golden Island pumping station and installation of sewer across The Meadows | C                | 30/11/2011              | Yes                     | At Planning Stage | 31/12/2025                        |          |
| <b>D0007-SIP:16</b>   | Upgrade of Golden Island pumping station  | C                | 31/12/2014              | Yes                     | At Planning Stage | 31/12/2025                        |          |
| <b>D0007-SIP:17</b>   | Upgrade of WWTP and ancillary works   | C                | 31/12/2014              | Yes                     | Works Completed   |                                   |          |

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

## 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

| Improvement Identifier                                  | Improvement Description / or any Operational Improvements | Improvement Source | Expected Completion Date | Comments |
|---|---|--------------------|--------------------------|----------|
| <b>No additional improvements planned at this time.</b> |   |                    |                          |          |

## 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.

## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

| Licence Specific Report                          | Required by licence | Year included in AER | Included in this AER |
|--|---------------------|----------------------|----------------------|
| Drinking Water Abstraction Point Risk Assessment | Yes                 | 2010                 | No                   |
| Priority Substances Assessment                   | Yes                 | 2010                 | No                   |
| Toxicity of Final Effluent                       | Yes                 | 2010                 | No                   |
| Toxicity/Leachate Management                     | Yes                 | 2010                 | No                   |

## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

| Parameter   | Answer                              |
|---|-------------------------------------|
| Does the AER include an Executive Summary?  | Yes                                 |
| Does the AER include an assessment of the performance of the Waste Water Works (i.e., have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)? | Yes                                 |
| Has a Technical amendment/licence review application been submitted to the Agency by IW?  | N/A                                 |
| List reason e.g., additional SWO identified   | N/A                                 |
| Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc  | Yes                                 |
| List reason e.g., changes to monitoring requirements  | Ambient Monitoring Location Changes |
| Have these processes commenced?   | No                                  |
| Are all outstanding reports and assessments from previous AERs included as an appendix to this AER  | N/A                                 |

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Date: 14/07/2022

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of,

Katherine Walshe

Acting Head of Environmental Regulation.

## 7 APPENDIX

Appendix

**Appendix 7.1 - Ambient monitoring summary**

## Athlone 2021 Ambient Monitoring Summary

| Ambient Monitoring Point from WWDL (or as agreed with EPA) | Irish National Grid Reference (Easting, Northing) | EPA Feature Coding Tool code | Receiving Waters Designation (Yes/No) |                |      |           | Current WFD Status |
|--|---|------------------------------|---------------------------------------|----------------|------|-----------|--------------------|
|  |   |                              | Bathing Water                         | Drinking Water | FWPM | Shellfish |                    |
| Upstream Monitoring Point                                  | 204112, 240975                                    | RS26S021706                  | No                                    | No             | No   | No        | Poor               |
| Downstream Monitoring Point                                | 204008, 240237                                    | RS26S021725                  | No                                    | Yes            | No   | No        | Poor               |

\*It should be noted that Irish Waste is unable to access the downstream sampling location as prescribed under Schedule B.3 Ambient Monitoring. The lands adjacent to all the sample locations are underwater for at least a period of 6-8 months of the year. Westmeath County Council/Irish Water are in the process of selecting a suitable alternative downstream monitoring point.

## 2021 Athlone Ambient Monitoring Data

| UPSTREAM      |               |                          |                            |                     |                  |                               |                     |               |                |                  |                    |
|---------------|---------------|--------------------------|----------------------------|---------------------|------------------|-------------------------------|---------------------|---------------|----------------|------------------|--------------------|
|               | Ammonia N     | Biological Oxygen Demand | COD Chemical Oxygen Demand | Conductivity @ 20°C | Dissolved Oxygen | Dissolved Oxygen % Saturation | Ortho-Phosphate MRP | pH            | Temperature    | Total Nitrogen N | Total Phosphorus P |
| Sample Date   | mg/l          | mg/l                     | mg/l                       | µS/cm               | mg/l             | % Sat.                        | mg/l                | pH units      | Degrees C      | mg/l             | mg/l               |
| 12/01/2021    | 0.005         | 1.1                      | 36                         | 310                 | 11.8             | 91.2                          | 0.012               | 8.3           | 4.8            | <2.5             | 0.02               |
| 03/02/2021    | 0.021         | 1.2                      | 33                         | 300                 | 11.79            | 74.7                          | 0.018               | 8.3           | 5.2            | <2.5             | 0.02               |
| 03/03/2021    | 0.02          | <1                       | 23                         | 303                 | 11.62            | 92.3                          | 0.03                | 8.2           | 6.1            | 1.7              | 0.02               |
| 07/04/2021    | 0.019         | <1                       | 19                         | 318                 | 10.92            | 87.1                          | 0.016               | 8.3           | 7.5            | 2.1              | 0.02               |
| 11/05/2021    | 0.015         | <1                       | 36                         | 332                 | 11.05            | 112.9                         | 0.006               | 8.5           | 15.4           | <2.5             | 0.01               |
| 02/06/2021    | 0.007         | <1                       | 26                         | 342                 | 11.86            | 120.4                         | 0.009               | 8.4           | 16.9           | 1.1              | 0.02               |
| 13/07/2021    | 0.01          | <1                       | 21                         | 372                 | 10.55            | 112.5                         | 0.008               | 8.5           | 17.8           | <1               | 0.01               |
| 18/08/2021    | 0.015         | <1                       | 19                         | 326                 | 8.85             | 91                            | 0.006               | 8.3           | 17.1           | <1               | <0.05              |
| 07/09/2021    | <0.05         | <1                       | 34                         | 352.4               | 8.54             | 88.6                          | <0.05               | 8.2           | 17.4           | <1               | <0.1               |
| 06/10/2021    | <0.05         | 1                        | 22                         | 295.4               | 9.63             | 81.8                          | <0.05               | 8.2           | 13.4           | 1.992            | <0.1               |
| 03/11/2021    | <0.05         | <1                       | 18                         | 271.8               | 9.97             | 91.4                          | <0.05               | 8             | 11.5           | <1               | <0.1               |
| 14/12/2021    | <0.05         | 2.3                      | 25                         | 316.7               | 11.11            | 89.7                          | <0.05               | 7.7           | 6.5            | 2.1              | <0.1               |
| <b>Mean</b>   | <b>0.0211</b> | <b>0.9381</b>            | <b>26.0000</b>             | <b>319.9417</b>     | <b>10.6408</b>   | <b>94.4667</b>                | <b>0.0131</b>       | <b>8.2417</b> | <b>11.6333</b> | <b>1.4270</b>    | <b>0.0365</b>      |
| <b>95%ile</b> | <b>0.0354</b> | <b>1.6950</b>            | <b>36.0000</b>             | <b>361.2200</b>     | <b>11.8270</b>   | <b>116.2750</b>               | <b>0.0258</b>       | <b>8.5000</b> | <b>17.5800</b> | <b>2.1000</b>    | <b>0.0707</b>      |

Note: Where the concentration in the result is less than the limit of detection (LOD), a value of  $LOD/\sqrt{2}$  was used in calculating the mean and 95%ile concentrations.