

Annual Environmental Report

2021



Dunfanaghy Portnablagh

D0211-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2021 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 DUNFANAGHY/ PORTNABLAGH WWTP - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - DUNFANAGHY/ PORTNABLAGH WWTP
 - 2.1.2 EFFLUENT MONITORING SUMMARY - DUNFANAGHY/ PORTNABLAGH WWTP -
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR DUNFANAGHY/ PORTNABLAGH WWTP
 - 2.1.5 SLUDGE/OTHER INPUTS TO DUNFANAGHY/ PORTNABLAGH WWTP

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 PRIORITY SUBSTANCES ASSESSMENT

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

- 7.1 AMBIENT MONITORING SUMMARY

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2021 AER

This Annual Environmental Report has been prepared for D0211-01, Dunfanaghy Portnablagh, in Donegal in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There was no major capital or operational changes undertaken

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Dunfanaghy/ Portnablagh WWTP with a Plant Capacity PE of 900, the treatment type is 1 - Primary treatment

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF0600D0211SW001	Dunfanaghy/ Portnablagh WWTP	Treated	Non-compliant	Suspended Solids mg/l and cBOD (Carbonaceous BOD) mg/l

1.4 LICENCE SPECIFIC REPORTING

Assessment / Report
There are no Licence Specific Reports included in this AER.

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 DUNFANAGHY/ PORTNABLAGH WWTP - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - DUNFANAGHY/ PORTNABLAGH WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Suspended Solids mg/l	6	1322	219
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	6	243	48
ortho-Phosphate (as P) - unspecified mg/l	6	6.83	1.77
COD-Cr mg/l	6	459	130
pH pH units	6	7.80	7.33
Ammonia-Total (as N) mg/l	6	78	19
Total Nitrogen mg/l	1	13	13
Hydraulic Capacity	N/A	1275	527

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is greater than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF0600D0211SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
pH pH units	9.00	9.00	N/A	6	N/A	N/A	7.32	Pass
Enterococci (Intestinal) cfu/100ml	N/A	N/A	N/A	5	N/A	N/A	56486	
COD-Cr mg/l	N/A	N/A	N/A	6	N/A	N/A	80	
Suspended Solids mg/l	N/A	N/A	50%	6	3	N/A	41	Fail
Nitrate (as N) mg/l	N/A	N/A	N/A	6	N/A	N/A	0.402	
E. Coli MPN/100ml	N/A	N/A	N/A	5	N/A	N/A	1374445	
Faecal coliforms cfu/100ml	N/A	N/A	N/A	5	N/A	N/A	943459	
Conductivity @20°C µS/cm	N/A	N/A	N/A	6	N/A	N/A	1287	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Ammonia-Total (as N) mg/l	N/A	N/A	N/A	6	N/A	N/A	11	
ortho-Phosphate (as P) - unspecified mg/l	N/A	N/A	N/A	6	N/A	N/A	1.18	
Nitrite (as N) mg/l	N/A	N/A	N/A	6	N/A	N/A	0.039	
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	N/A	N/A	20%	6	3	N/A	29	Fail
Total Oxidised Nitrogen (as N) mg/l	N/A	N/A	N/A	6	N/A	N/A	0.429	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

Cause of Exceedance(s):

Not applicable

Significance of Results:

The WWTP is not compliant with the ELV's set in the Wastewater Discharge Licence.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF0600D0211SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Upstream	204506, 437200	TW06007067SH1002	Yes	No	No	No	Unassigned
Downstream	204506, 437200	CW06007067SH1003	Yes	No	No	Yes	Unassigned

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**

Significance of Results:

The WWTP discharge was non-compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - DUNFANAGHY/ PORTNABLAGH WWTP

2.1.4.1 Treatment Efficiency Report - Dunfanaghy/ Portnablagh WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
cBOD	8475	5112	40
TN	2499	N/A	N/A
TP	N/A	N/A	N/A
COD	23096	14166	39
SS	38802	7349	81

Note: The above data is based on sample results for the number of dates reported

2.1.4.2 Treatment Capacity Report Summary - Dunfanaghy/ Portnablagh WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Dunfanaghy/ Portnablagh WWTP	
Peak Hydraulic Capacity (m³/day) - As Constructed	518
DWF to the Treatment Plant (m³/day)	200
Current Hydraulic Loading - annual max (m³/day)	1275

Dunfanaghy/ Portnablagh WWTP	
Average Hydraulic loading to the Treatment Plant (m ³ /day)	527
Organic Capacity (PE) - As Constructed	900
Organic Capacity (PE) - Collected Load (peak week) ^{Note¹}	2310
Organic Capacity (PE) - Remaining	0
Will the capacity be exceeded in the next three years? (Yes/No)	Yes

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - DUNFANAGHY/ PORTNABLAGH WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2021.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Specified % Reduction Value not achieved	WWTP operating above capacity	1	Yes	No

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2021	1
Number of Incidents reported to the EPA via EDEN in 2021	1
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2021 (No. of events)	Total volume discharged in 2021 (m3)	Monitoring Status
TBC	201820, 437386	No	Low	Meeting	Unknown	Unknown	Monitored
TBC	202524, 437100	No	Low	Meeting	Unknown	Unknown	Monitored
TBC	203646, 436672	No	Low	Meeting	Unknown	Unknown	Monitored
TBC	204959, 436093	No	Low	Meeting	Unknown	Unknown	Monitored
SW002	204659, 436968	Yes	Low	Meeting	Unknown	Unknown	Not Monitored
SW003	204398, 436846	Yes	Low	Meeting	Unknown	Unknown	Not Monitored

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2021 (No. of events)	Total volume discharged in 2021 (m3)	Monitoring Status
SW004	204285, 436833	Yes	Low	Meeting	Unknown	Unknown	Not Monitored
SW005	201823, 437394	Yes	Low	Meeting	Unknown	Unknown	Not Monitored
SW006	201800, 437428	Yes	Low	Meeting	Unknown	Unknown	Not Monitored

Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	N/A
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0211-SIP:01	Provision of sufficient organic and hydraulic primary treatment to treat all of the influent from the agglomeration to ensure compliance with Condition 1.7 of the RD.	C	31/12/2015	Yes	At Planning Stage		

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
No additional improvements planned at this time.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Year included in AER	Included in this AER
Priority Substances Assessment	Yes	2015	No

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Has a Technical amendment/licence review application been submitted to the Agency by IW?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 04/05/2022

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Katherine Walshe

Acting Head of Environmental Regulation.

7 APPENDIX

Appendix
Appendix 7.1 - Ambient monitoring summary

MONTH	Category	Station	Lab Ref	Date	Ammonia (as N)	BOD	Chlorophyll	COD Chemical Oxygen Demand	Dissolved Inorganic Nitrogen (as N)	Dissolved Oxygen % Saturation	E coli	Intestinal Enterococci	Faecal Coliforms (E. coli)	Orthophosphate	Temperature	Total Oxidised Nitrogen N	Total Nitrogen N	Salinity	pH	Suspended Solids	Chlorophyll
March	Coastal Water Body	Portnablagh	212501037	02-Mar-21	0.43	<2	NT	NT	0.68	101.7	0	0	0	NT	5.8	<0.5	NT	NT	8.19	146	NT
May	Coastal Water Body	Portnablagh	212501994	19-May-21	0.49	2	NT	NT	0.49	101.6	0	0	0	NT	10.3	<0.5	NT	NT	8.2	133	NT
					(mg/l)	(mg/l)	mg/m3	(mg/l)	(mg/l)	(mg/l)	mpn/100mls	cfu/100	cfu/100mls	(mg/l)	°C	(mg/l)	(mg/l)	PSU	pH units	(mg/l)	µg/L