

# Annual Environmental Report

2018



Carrickmacross

D0062-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2018 AER**

#### 1.1 TREATMENT SUMMARY

##### 1.1.1 CARRICKMACROSS WWTP

#### 1.2 ELV OVERVIEW

#### 1.3 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMAND AND IMPACT SUMMARY**

#### 2.1 CARRICKMACROSS WWTP - TREATED DISCHARGE

##### 2.1.1 INFLUENT SUMMARY - CARRICKMACROSS WWTP

##### 2.1.2 EFFLUENT MONITORING SUMMARY - CARRICKMACROSS WWTP -

##### 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -

##### 2.1.4 OPERATIONAL REPORTS SUMMARY FOR CARRICKMACROSS WWTP

##### 2.1.5 SLUDGE/OTHER INPUTS TO CARRICKMACROSS WWTP

##### 2.1.6 SLUDGE REMOVAL CARRICKMACROSS WWTP

### **3 COMPLAINTS SUMMARY**

#### 3.1 REPORTED INCIDENTS SUMMARY

##### 3.1.1 SUMMARY OF INCIDENTS

##### 3.1.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

#### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

##### 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT

#### 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

##### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

##### 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

##### 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

### **6 CERTIFICATION AND SIGN OFF**

#### 6.1 SUMMARY OF AER CONTENTS

### **7 APPENDIX**

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2018 AER

This Annual Environmental Report has been prepared for D0062-01, Carrickmacross, in Monaghan in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Carrickmacross WWTP with a Plant Capacity PE of 12150

The treatment process includes the following:

### 1.1.1 CARRICKMACROSS WWTP

Treatment type	Yes / No	Details
Preliminary Treatment	Yes	Screening and Grit Removal
Primary Treatment	No	
Secondary Treatment	Yes	Aeration
Nutrient Removal	Yes	Ferric dosing and Anoxic Zone
Tertiary Treatment	No	

## 1.2 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF2400D0062SW001	Carrickmacross WWTP	Treated	Compliant	Not Applicable

## 1.3 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
There is no Licence Specific Reports included in the AER.	

## 2 TREATMENT PLANT PERFORMAND AND IMPACT SUMMARY

### 2.1 CARRICKMACROSS WWTP - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - CARRICKMACROSS WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Total Phosphorus (as P) mg/l	12	14.3	6.05
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	12	624	268.18
COD-Cr mg/l	12	2605	863.4
Total Nitrogen mg/l	12	114.2	41.14
Suspended Solids mg/l	12	875	287.97
Hydraulic Capacity	N/A	5989	2100

#### Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

## 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF2400D0062SW000

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included <sup>Note 1</sup>	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	0	12	0	0	20.99	Pass
Suspended Solids mg/l	10	25	0	12	1	0	5.27	Pass
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	10	20	0	12	0	0	2.13	Pass
Total Phosphorus (as P) mg/l	1	1.2	0	12	0	0	0.24	Pass
Ammonia-Total (as N) mg/l	0.75	1.5	0	12	1	0	0.27	Pass
ortho-Phosphate (as P) - unspecified mg/l	0.4	0.8	0	12	0	0	0.16	Pass
pH pH units	0	0	0	12	0	0	7.75	
Total Nitrogen mg/l	0	0	0	12	0	0	13.16	
Temperature °C	0	0	0	6	0	0	7.61	

Notes:

1- This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 - For parameters where a mean ELV applies

### Cause of Exceedance(s):

**Not Applicable**

### Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

## 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
<b>Upstream</b>	284616, 302845	TPEFF2400D0062SW001	No	No	No	No	Poor
<b>Downstream</b>	285036, 302632	TPEFF2400D0062SW001	No	No	No	No	Poor

The table below provides a summary of monitoring results for designated ambient monitoring points. The upstream and downstream annual mean values are shown (mg/l), and the difference between both monitoring stations is given as a percentage of the Environmental Quality Standard (EQS) where relevant.

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
<b>BOD - 5 days (Total) mg/l</b>	RS06P010240	2.76	RS06P010300	2.61	2.6	-5.9

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
Ammonia-Total (as N) mg/l	RS06P010240	0.02	RS06P010300	0.13	0.14	76.4
ortho-Phosphate (as P) - unspecified mg/l	RS06P010240	0.07	RS06P010300	0.08	0.08	6.4
Total Nitrogen mg/l	RS06P010240	5.62	RS06P010300	7.32		
Dissolved Oxygen mg/l	RS06P010240	10.83	RS06P010300	9.85		
Temperature °C	RS06P010240	10.48	RS06P010300	10.75		
pH pH units	RS06P010240	7.99	RS06P010300	7.79		

### Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results meet the required EQS.

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

Any other known impacts: Upstream catchment urban influences are impacting on upstream results.

## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY

### 2.1.4.1 Treatment Efficiency Report

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)	Comment
TP	0	192.39	95.89	
SS	0	4144.89	98.14	
TN	0	10352.73	67.46	
COD	0	16516.16	97.53	
cBOD	0	1677.54	99.19	

Note: The above data is based on sample results for the number of dates reported

#### 2.1.4.2 Treatment Capacity Report Summary

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Carrickmacross WWTP	
Peak Hydraulic Capacity (m3/day) - As Constructed	8274
DWF to the Treatment Plant (m3/day)	2758
Current Hydraulic Loading - annual max (m3/day)	5989
Average Hydraulic loading to the Treatment Plant (m3/day)	2100
Organic Capacity (PE) - As Constructed	12150
Organic Capacity (PE) - Collected Load (peak week)	7478
Organic Capacity (PE) - Remaining	4672

## Carrickmacross WWTP

Will the capacity be exceeded in the next three years? (Yes/No)

No

### 2.1.5 SLUDGE / OTHER INPUTS

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
Domestic /Septic Tank Sludge	183	Volume (m3)	2	0.02	No	Yes	Yes
Industrial / Commercial Sludge	2870	Volume (m3)	35	0.3	No	Yes	Yes
Other	1720	Volume (m3)	21	0.2	No	Yes	Yes

### 2.1.6 SLUDGE REMOVAL

The amount of sludge removed from the wastewater treatment plant is shown below along with the transported destination of the sludge from the treatment plant.

Treatment Plant	Sludge type	Quantity	Unit	% Dry Solids	Destination
Carrickmacross WWTP	Cake Sludge	1198.72	Weight (Tonnes)	14.6	Biocore

## 3 COMPLAINTS AND INCIDENTS

### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
6	Blocked Sewer	0	6

### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Uncontrolled release	Other	1	Yes	Yes
Other	Other	1	No	Yes
Other	Plant or equipment breakdown at WWTP	1	No	Yes

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Uncontrolled release	EO casued by power failure	1	No	Yes
Uncontrolled release	Shock load to WWTP	1	No	No

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2018	5
Number of Incidents reported to the EPA via EDEN in 2018	5
Explanation of any discrepancies between the two numbers above	

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2018 (No. of events)	Total volume discharged in 2018 (m3)	Monitoring Status
SW-2	284588, 302860	Yes	High	Not Meeting	31	14299	Monitored

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	14299
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	Yes
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	Yes

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0062-SIP:01</b>	SW-3 - SW-12 Discharges to be Discontinued	A	31/12/2011	Yes	Works Completed		
<b>D0062-SIP:02</b>	Advance Works at waste water treatment plant, including (1) effluent outfall pipeline and associated works, (2) Pumping Station (inlet and outlet), (3) Storm tanks, and (4) Inlet works.	C	01/01/2015	Yes	Not Started	30/09/2020	
<b>D0062-SIP:03</b>	SW-1 (Existing)	A	31/12/2014	Yes	Not Started	30/09/2020	
<b>D0062-SIP:04</b>	Upgrading of Storm Water Overflows to comply with the criteria outlined in the DoECLG "Procedures and Criteria in relation to Storm Water Overflows, 1995"	C	01/01/2015	Yes	Not Started	30/09/2020	

A summary of the status of any improvements identified by under Condition 5.2 is included below.

## 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description	Improvement Source	Expected Completion Date	Comments
<b>There are no Improvements Programme for this Agglomeration.</b>				

## 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.

## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

### 5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
<b>There is no Licence Specific Report Required in this AER Annual Review.</b>				

## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	
Is there a need to request/advise the EPA of any modifications to the existing WWDL?	No
List reason e.g. changes to monitoring requirements	
Have these processes commenced?	No
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed:

Date: 14/06/2019

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Acting Head of Environmental Regulation.

## **7 APPENDIX**

There are no Appendices included