



Headquarters  
P.O. Box 3000  
Johnstown Castle Estate  
County Wexford  
Ireland

WASTE WATER DISCHARGE LICENCE  
TECHNICAL AMENDMENT B

<b>Licence Register Number:</b>	D0436-01
<b>Licensee:</b>	Irish Water
<b>Agglomeration:</b>	Ringaskiddy village

## ***Reasons for the Decision***

The purpose of this Technical Amendment is to update the Glossary of Terms, Conditions and Schedules of the licence, as appropriate.

The Environmental Protection Agency (the Agency) is satisfied, on the basis of the information available, that subject to compliance with the conditions of licence Reg. No. D0436-01 granted on the 20/07/2010 (and amended on 27/09/2010) as well as any amendments noted herein any discharge from the activity will comply with and not contravene any of the requirements of Regulation 6(3) of the *Waste Water Discharge (Authorisation) Regulations, 2007*, as amended.

A screening for Appropriate Assessment was undertaken to assess, in view of best scientific knowledge and the conservation objectives of the site, if the activity, individually or in combination with other plans or projects is likely to have a significant effect on a European Site(s). In this context, for the reasons set out below, the activity is not directly connected with or necessary to the management of the site as a European Site and it can be excluded on the basis of objective scientific information, that the activity, individually or in combination with other plans or projects, will have a significant effect on a European site, and accordingly the Agency determined that an Appropriate Assessment of the activity is not required, for the following reasons; the proposed amendments will not result in a material change to the nature or volume of the discharge(s) from the agglomeration.

## ***Technical Amendment***

In pursuance of the powers conferred on it by Regulation 33(1)(c) of the *Waste Water Discharge (Authorisation) Regulations, 2007*, as amended, the Agency amends Licence Reg. No. D0436-01, granted to Irish Water, Colvill House, 24/26 Talbot Street, Dublin 1, by virtue of Section 17(4) of the *Water Services (No. 2) Act 2013*.

Henceforth, the licence shall be read in conjunction with the amendments set out below.

This technical amendment is limited to the following Glossary of Terms, Conditions and Schedules of Licence Reg. No. D0436-01.

# Amendments

## Glossary of Terms

Amend the Glossary terms as follows:

<b>Maintain</b>	Keep equipment, plant and infrastructure in a fit state, including such regular inspection, servicing, calibration and repair as may be necessary to perform its function.
<b>Sample(s)</b>	Unless the context of this licence indicates to the contrary, the term sample(s) shall include measurements taken by electronic instruments.
<b>SSRS</b>	Small Streams Risk Score.
<b>Standard Method</b>	A relevant CEN, ISO, National, or other internationally recognized test procedure such as detailed in the current edition of "Standard Methods for the Examination of Water and Wastewater" (published jointly by A.P.H.A. / A.W.W.A. / W.E.F.), a documented and validated in-house procedure based on the above sources that will ensure the provision of data of an equivalent scientific quality, or an alternative method as may be agreed with the Agency.

Insert new Glossary terms as follows:

<b>BIM</b>	Bord Iascaigh Mhara.
<b>Competent Laboratory</b>	A testing facility meeting the general management and technical requirements of EN ISO/IEC-17025 standard, or other equivalent standards accepted at international level and utilising methods of analysis, including laboratory, field, and on-line methods, which are validated and documented in accordance with the above standard(s) for the specific tests.
<b>Environmental Pollution</b>	Means, in relation to waste water discharges, the direct or indirect introduction, as a result of human activity, of waste water discharges, substances (including any explosive, liquid or gas) or polluting matter (including any poisonous or noxious matter) into waters which may endanger human health or harm the aquatic environment, and in particular— (a) create a risk to waters, sediment, plants or animals, (b) deleteriously interfere with the quality of aquatic ecosystems or terrestrial ecosystems directly depending on aquatic ecosystems including by— (i) rendering those or any other waters poisonous or injurious to fish, shellfish, spawning grounds or the food

	<p>of any fish, or</p> <p>(ii) impairing the usefulness of the bed and soil of any waters as spawning grounds or impairing their capacity to produce the food of fish or shellfish,</p> <p>(c) impair or interfere with amenities and other legitimate uses of the water, or</p> <p>(d) result in the water failing to meet any environmental quality standards prescribed in regulations for the purpose of giving effect to the requirements of any Directive relating to the quality or use of water for the time being in force.</p>
<b>FSAI</b>	Food Safety Authority of Ireland.
<b>Priority Substances</b>	Those substances or groups of substances, identified by the Commission in accordance with Article 16(2) of the Water Framework Directive and listed in Tables 11 and 12 of Schedule 6 of the European Communities Environmental Objectives (Surface Waters) Regulations, 2009 that have been prioritised for action by the setting of environmental quality standards at Community level.
<b>SFPA</b>	Sea Fisheries Protection Authority.

## Conditions of Licence

Delete Condition 1.1.2:

This licence shall be technically amended, as and when considered by the Agency, to ensure compliance with such environmental quality standard as may be prescribed for surface water classification of the receiving water body.

Insert new Condition 3.6:

No discharge from the waste water works is permitted save under and in accordance with this licence.

Amend Condition 4.1 as follows:

- 4.1 The licensee shall carry out such sampling, analyses, measurements, examinations, maintenance and calibrations as set out below and in accordance with *Schedule B: Monitoring*, of this licence.
- 4.1.1 Analyses shall be undertaken by competent staff in accordance with documented operating procedures. Analysis for compliance purposes, including any sub-contracted analysis, shall be done by a competent laboratory.
- 4.1.2 Such procedures shall be assessed for their suitability for the test matrix and performance characteristics shall be determined.
- 4.1.3 Such procedures shall be subject to a programme of Analytical Quality Control, verified by a competent third party using control standards with evaluation of test responses.

Amend Condition 4.2 as follows:

- 4.2 The licensee shall ensure that:
- (i) Sampling and analysis for all parameters listed in the Schedules to this licence, and
  - (ii) Any reference measurement methods to calibrate automated measurement system

shall be carried out by an appropriate Standard Method.

Insert new Condition 4.8:

The licensee shall ensure that a person in charge or a nominated deputy shall be available to meet with authorised person(s) of the Agency at all reasonable times and shall allow access to the waste water works or other premises that the Agency reasonably considers may contain information pertaining to a discharge from those works.

Insert new Condition 4.9:

Where such ambient monitoring results are available from any other statutory body, including the Agency, the licensee may submit those results in fulfillment of the requirements of *Schedule B.4 Ambient Monitoring* of this licence.

Replace Condition 6.1 to Condition 6.5 inclusive with the following new Condition 6.1:

The licensee shall notify the Agency's headquarters in Wexford, or to such other Agency office, as soon as practicable after the occurrence of any incident (as defined in this licence). This notification shall be in such format as specified in Guidance to Licensees/COA holders on the Notification, Management and Communication of Environmental Incidents issued by the Agency and as a minimum shall include the following: the date, time, location, details, nature, cause, extent and ranking of the incident, details on any vulnerable receptors, corrective action taken and plans to prevent a reoccurrence, and the steps taken to minimise any discharges and to carry out any necessary environmental clean-up. The following shall also be notified, as soon as practicable after the occurrence of any incident:

- Department of Agriculture, Food & the Marine in the case of discharges to receiving waters.
- Marine Institute (MI), Sea Fisheries Protection Authority (SFPA), Food Safety Authority (FSAI) and an Bord Iascaigh Mhara (BIM) in the case of discharges to or likely to impact a designated shellfish water.

Amend Condition 6.7 as follows:

The licensee shall as a minimum keep the following documents at the headquarters of the licensee or such office as may be agreed by the Agency:

- (i) the licence application and all associated documentation;
- (ii) the licence(s) relating to the discharge(s) to waters from the waste water works;
- (iii) the previous year's AER;
- (iv) records of all risk assessments, sampling, analyses, measurements, examinations, calibrations and maintenance carried out in accordance with the requirements of this licence and guidance produced by the Agency;
- (v) relevant correspondence with the Agency;
- (vi) up to date drawings/plans showing the location of key process and environmental infrastructure, including monitoring locations and discharge points;
- (vii) up to date operational procedures for all monitoring and control equipment necessary to give effect to this licence.

This documentation shall be available to the Agency for inspection at all reasonable times and shall be submitted to the Agency, as required, in such a format as may be

requested, including electronic submittal of the information or a summary of such information.

**Schedules of the licence**

Amend Schedule A.1. Primary Waste Water Discharge as follows:

EDEN Code	Licence Code	Discharge Location			Receiving water name	WFD Receiving water
TPEFF0500D0436SW001	SW001	E	178202	N	064723	Cork Harbour SW 060 0000

Parameter	Emission Limit Value
	mg/l
CBOD	25
COD	125
Suspended Solids	35

Amend Schedule A.3 Discharges to be discontinued as follows:

EDEN Code	Licence Code	Location			Name of Receiving Waters	Discharge shall cease from
TPEFF0500D0436SW001	SW001	E	178202	N	064723	Cork Harbour 1 <sup>st</sup> January 2015

*e*

This technical amendment shall be cited as Amendment B to Waste Water Discharge Licence Register No. D0436-01 dated 20/07/2010 and is to be read in conjunction with that licence and all previous amendments.

**Sealed by the seal of the Agency on this the 1<sup>st</sup> day of July, 2014**

**PRESENT when the seal of the Agency  
was affixed hereto:**

*Karen Creed*

Dr Karen Creed, Authorised Person

